

From: "Fallin, Michael" <Michael.Fallin@constellation.com>
To: "Ngoc Le" <NBL@nrc.gov>
Date: 5/15/06 5:07PM
Subject: Fire Doors

Tommy,

Relative to our phone conversation, the paragraph we discussed from the "Discussion" Column in the item on ALRA P. 3.3-104 (Item 3.3.1.B-20) was meant to address only those buildings that are not specifically included in the GALL. As such, since the Aux. Bldg fire doors (VII.G.3-d), the DG Bldg fire doors (VII.G.4-d), the Screenwell Bldg fire doors (VII.G.1-d), and the Turbine Bldg fire doors (VII.G.2-d) are specifically addressed in the GALL, those bldgs should not have been included in that paragraph. Only the rated doors for the Reactor Bldg, Control Room Bldg, Essential Yard Structures, Radwaste Bldg, and Standby Gas Treatment Bldg should have been included in the paragraph. The fire doors for those Bldgs are not specifically addressed in the GALL; however, since the material, environment, AERMs, and AMP for those fire doors are the same as GALL Items VII. G.1-d, VII.G.2-d, VII.G.3-d, and VII.G.4-d, they are consistent with the GALL as well. That is what the paragraph was trying to convey.

Similarly, with Item 3.3.1.A-20, the Screen & Pump House and Turbine Bldgs should not have been included in that list of Bldgs in the 1st paragraph of the "Discussion" Column. They are addressed in GALL Items VII.G.1-d and VII.G.2-d, respectively.

If you have any further questions, give me a call.

Michael R. Fallin
Technical Consultant
Constellation Generation Group
1997 Annapolis Exchange Parkway
Suite 500
Annapolis, MD 21401
(410)897-5165 (ph.)
(315)349-7020 (NMP ph.)
(410)382-4399 (cell)
(410)897-5110 (fax)
michael.fallin@constellation.com

>>> This e-mail and any attachments are confidential, may contain legal, professional or other privileged information, and are intended solely for the addressee. If you are not the intended recipient, do not use the information in this e-mail in any way, delete this e-mail and notify the sender. CEG-IP2

CC: "Mazzaferro, Peter A" <Peter.Mazzaferro@constellation.com>

Mail Envelope Properties (4468ED7A.BDF : 5 : 48095)

Subject: Fire Doors
Creation Date: 5/15/06 5:06PM
From: "Fallin, Michael" <Michael.Fallin@constellation.com>

Created By: Michael.Fallin@constellation.com

Recipients

nrc.gov
TWGWPO01.HQGWDO01
NBL (Ngoc Le)

constellation.com
Peter.Mazzaferro CC (Peter A Mazzaferro)

Post Office

TWGWPO01.HQGWDO01

Route

nrc.gov
constellation.com

Files	Size	Date & Time
MESSAGE	1883	05/15/06 05:06PM
TEXT.htm	3055	
Mime.822	6989	

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard