OAK RIDGE INSTITUTE FOR SCIENCE AND EDUCATION

2005

2 Pil 1: 52

December 09, 2005

Mr. Jim Kottan U.S. Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

#### SUBJECT: REPORT FOR ANALYSIS OF CONCRETE AND SOIL SAMPLES FROM THE YANKEE NUCLEAR POWER STATION, ROWE, MASSACHUSETTS [INSPECTION NO. 50-029/2005-002] [RFTA NO. 05-001/06-001]

Dear Mr. Kottan:

The Environmental Survey and Site Assessment Program (ESSAP) of the Oak Ridge Institute for Science and Education (ORISE) received one concrete sample on June 27, 2005, one concrete sample on July 28, 2005, and four soil samples on June 29, 2005 from the Yankee Nuclear Power Station in Rowe, Massachusetts. The sample identifications and sampling dates are in Table 1. The soil and concrete samples were analyzed by gamma spectroscopy (GS) (Procedure CP1, Revision 15). The concrete samples were also analyzed by liquid scintillation analysis for tritium (H-3) and carbon-14 (C-14) (Procedure AP6, Revision 15; Procedure CP4, Revision 3), by liquid scintillation analysis for nickel-59/63 (Ni-59/63), (Non-Routine Procedure AP17, Revision 0; Procedure CP4, Revision 3), by liquid scintillation analysis for iron-55 (Fe-55), (Non-Routine Procedure AP16, Revision 0; Procedure AP4, Revision 13; Procedure CP3, Revision 2). The GS results are presented in Table 2. The results for H-3, C-14, Fe-55, Ni-59/63, and Sr-90 have been combined and are presented in Table 3.

The completion of all analyses was delayed due to the request to develop analytical procedures to measure Fe-55 and Ni-59/63 in solid matrices. The Fe procedure received the require approvals on September 29, 2005 and the Ni procedure received the required approvals on November 10, 2005.

ESSAP's Quality Control (QC) requirements were met for these analyses. The QC files are available for your review upon request.

P. O. BOX 117, OAK RIDGE, TENNESSEE 37831-0117

Operated by Oak Ridge Associated Universities for the U.S. Department of Energy



Mr. Jim Kottan

ŝ

-2-

December 09, 2005

Please contact me at (865) 241-3242 or Wade Ivey at (865) 576-9184 should you have any questions.

Sincerely,

Jule Condra

Dale Condra Laboratory Manager Environmental Survey and Site Assessment Program

RDC:WPI:ar

Enclosures

cc: T. McLaughlin, NRC/NMSS/TWFN 7F27 E. Knox-Davin, NRC/NMSS/TWFN 8A23 J. Hickman, NRC/DWMEP/TWFN 7F27 E. Abelquist, ORISE/ESSAP S. Kirk, ORISE/ESSAP File/1621

Distribution approval and concurrence :	Initials
Technical Management Team Member	(12)
Quality Manager	ATP

## **ORISE TABLE 1**

# SAMPLE IDENTIFICATIONS AND COLLECTION DATES YANKEE NUCLEAR POWER STATION ROWE, MASSACHUETTS

ESSAP Sample ID	NRC Region I Sample ID	Collection Date	Collection Time	
1621M0002	TDS-100-GR-S	6/23/2005	9:30	
1621M0003	TDS-201-GR-S2	7/21/2005	9:20	
1621S0018	TBN-02-001	4/28/2005	10:00	
1621S0019	TBN-02-005	4/28/2005	14:00	
1621S0020	CWP-2	4/16/2005	9:50	
1621S0021	CWP-7	4/27/2005	14:00	

1

2

### **ORISE TABLE 2**

# CONCENTRATIONS OF SELECTED GAMMA EMITTING RADIONUCLIDES IN TWO CONCRETE SAMPLES AND FOUR SOIL SAMPLES BY GAMMA SPECTROSCOPY CP1, REVISION 15 YANKEE NUCLEAR POWER STATION ROWE, MASSACHUSETTS

ESSAP	NRC Region I	Radionuclide Concentrations (pCi/g dry weight) <sup>a</sup>						
Sample ID	Sample ID	Co-60	Ag-108m	Sb-125	Cs-137	Eu-152	Eu-154	Eu-155
1621M0002	TDS-100-GR-S	$0.05 \pm 0.04^{b}$	$-0.02 \pm 0.02$	$0.01 \pm 0.05$	$0.09 \pm 0.05$	$0.00^{\rm c}~\pm~0.05$	$0.00 \pm 0.02$	$0.04 \pm 0.05$
1621M0003	TDS-201-GR-S2	$0.01 \pm 0.02$	$0.01 \pm 0.01$	$0.01 \pm 0.04$	$0.03 \pm 0.03$	$0.03 \pm 0.04$	$0.00 \pm 0.02$	$0.02 \pm 0.03$
1621S0018A	TBN-02-001	81.5 ± 2.7	$1.33 \pm 0.25$	$0.17 \pm 0.50$	$6.31 \pm 0.59$	$0.00 \pm 0.48$	$0.07 \pm 0.14$	$0.52 \pm 0.40$
1621S0018B	TBN-02-001	87.8 ± 2.9	$1.27 \pm 0.23$	$0.40 \pm 0.53$	$7.29 \pm 0.65$	$-0.19 \pm 0.46$	$0.01 \pm 0.15$	$0.20 \pm 0.28$
1621S0019	TBN-02-005	$3.80 \pm 0.24$	$0.09 \pm 0.06$	$0.05 \pm 0.13$	$0.65 \pm 0.12$	$-0.14 \pm 0.13$	$-0.03 \pm 0.06$	$0.22 \pm 0.17$
1621S0020	CWP-2	$0.19 \pm 0.09$	$-0.02 \pm 0.04$	$0.03 \pm 0.14$	$1.00 \pm 0.15$	$0.00 \pm 0.15$	$-0.03 \pm 0.08$	$0.55 \pm 0.25$
1621S0021	CWP-7	$0.02 \pm 0.03$	$-0.01 \pm 0.01$	$0.03 \pm 0.04$	$0.13 \pm 0.03$	$0.07 \pm 0.06$	$0.02 \ \pm \ 0.02$	$0.07 \pm 0.06$

<sup>a</sup>The range of MDCs for the selected radionuclides is 0.10 pCi/g to 0.30 pCi/g.

<sup>b</sup>Uncertainties represent the 95% confidence level, based on total propagated uncertainties.

<sup>c</sup>Zero values are due to rounding.

#### **ORISE TABLE 3**

### CONCENTRATIONS OF SELECTED BETA EMITTERS IN CONCRETE SAMPLES YANKEE NUCLEAR POWER STATION ROWE, MASSACHUSETTS

ESSAP Sample	NRC Region I	Concentrations and MDCs <sup>a</sup> (pCi/g)					
ID	Sample ID	H-3 <sup>b</sup>	C-14 <sup>b</sup>	Fe-55 <sup>c</sup>	Ni-59 <sup>d</sup>	Ni-63 <sup>d</sup>	Sr-90 <sup>e</sup>
1621M0002	TDS-100-GR-S	$23.9 \pm 4.1^{\rm f} (5.5)$	55.6 ± 3.0 (3.1)	2.8 ± 3.6 (6.1)	$-1.0 \pm 1.1$ (1.8)	$0.5 \pm 1.1 (1.9)$	$-0.15 \pm 0.23(0.43)$
1621M0003	TDS-201-GR-S2	23.8 ± 4.1 (5.5)	70.6 ± 3.4 (3.1)	$5.5 \pm 3.7$ (6.1)	$0.5 \pm 1.1 (1.9)$	$-0.2 \pm 1.1 (1.9)$	$-0.04 \pm 0.23 \ (0.42)$

<sup>a</sup>MDCs are in parenthesis

<sup>b</sup>Analyed by Procedures. AP6, Revision 15 and CP4, Revision 3.

<sup>c</sup>Analyzed by Non-Routine Procedure AP16, Revision 0 and Procedure CP4, Revision 3.

<sup>d</sup>Analyzed by Non-Routine Procedure AP17, Revision 0 and Procedure CP4, Revision 3.

<sup>e</sup>Analyzed by Procedures AP4, Revision 13 and CP3, Revision 2.

<sup>f</sup>Uncertainties represent the 95% confidence level, based on total propagated uncertainties.