

July 11, 2006

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - NRC RECEIPT OF NEBRASKA PUBLIC
POWER DISTRICT'S RESPONSE TO GENERIC LETTER 2006-03,
"POTENTIALLY NONCONFORMING HEMYC AND MT FIRE BARRIER
CONFIGURATIONS" (TAC NO. MD1568)

Dear Mr. Edington:

The Nuclear Regulatory Commission acknowledges the receipt of your response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." In your letter dated May 30, 2006, you stated, under oath or affirmation, that Cooper Nuclear Station does not rely on either the Hemyc or MT fire barrier system or any other 1 or 3-hour fire barrier that separates redundant safe shutdown trains located within the same fire area. Based on your response, no further action is requested of you at this time.

If you have any questions regarding this response, please contact me at (301) 415-3764.

Sincerely,

/RA/

Brian Benney, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc: see next page

Mr. Randall K. Edington
 Vice President-Nuclear and CNO
 Nebraska Public Power District
 P.O. Box 98
 Brownville, NE 68321

July 11, 2006

SUBJECT: COOPER NUCLEAR STATION - NRC RECEIPT OF NEBRASKA PUBLIC POWER DISTRICT'S RESPONSE TO GENERIC LETTER 2006-03, "POTENTIALLY NONCONFORMING HEMYC AND MT FIRE BARRIER CONFIGURATIONS" (TAC NO. MD1568)

Dear Mr. Edington:

The Nuclear Regulatory Commission acknowledges the receipt of your response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." In your letter dated May 30, 2006, you stated, under oath or affirmation, that Cooper Nuclear Station does not rely on either the Hemyc or MT fire barrier system or any other 1 or 3-hour fire barrier that separates redundant safe shutdown trains located within the same fire area. Based on your response, no further action is requested of you at this time.

If you have any questions regarding this response, please contact me at (301) 415-3764.

Sincerely,

/RA/
 Brian Benney, Project Manager
 Plant Licensing Branch IV
 Division of Operating Reactor Licensing
 Office of Nuclear Reactor Regulation

Docket No. 50-298

cc: see next page

DISTRIBUTION:

PUBLIC	RidsNrrPMBBenney	RidsAcrsAcnwMailCenter
LPLIV r/f	RidsNrrLALFeizollahi	RidsOgcRp
RidsNrrDorl	RidsNrrPMBSingal	DFrumkin, DRA
RidsNrrLpl4	RidsNrrDraAfpb	RidsNrrDprPgcb
RidsRgn4MailCenter		QNguyen, DPR

ACCESSION NUMBER: ML061650200

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	RGCB/BC	AFPB/BC	OGC	NRR/LPL4/BC
NAME	BBenney	LFeizollahi	HChernoff	SWeerakkody		MThadani for DTerao
DATE	7/5/06	7/5/06		7/6/06		7/11/06

OFFICIAL RECORD COPY

Cooper Nuclear Station

cc:

Mr. William J. Fehrman
President and Chief Executive Officer
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

Mr. Gene Mace
Nuclear Asset Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. John C. McClure
Vice President and General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, NE 68602-0499

Mr. Paul V. Fleming
Licensing Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. Michael J. Linder, Director
Nebraska Department of Environmental
Quality
P. O. Box 98922
Lincoln, NE 68509-8922

Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, NE 68305

Ms. Julia Schmitt, Manager
Radiation Control Program
Nebraska Health & Human Services R & L
Public Health Assurance
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. H. Floyd Gilzow
Deputy Director for Policy
Missouri Department of Natural Resources
P. O. Box 176
Jefferson City, MO 65102-0176

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 218
Brownville, NE 68321

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Director, Missouri State Emergency
Management Agency
P. O. Box 116
Jefferson City, MO 65102-0116

Chief, Radiation and Asbestos
Control Section
Kansas Department of Health
and Environment
Bureau of Air and Radiation
1000 SW Jackson
Suite 310
Topeka, KS 66612-1366

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
Lucas State Office Building, 5th Floor
321 East 12th Street
Des Moines, IA 50319

Mr. Keith G. Henke, Planner
Division of Community and Public Health
Office of Emergency Coordination
930 Wildwood P.O. Box 570
Jefferson City, MO 65102

Jerry C. Roberts, Director of Nuclear
Safety Assurance
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. John F. McCann, Director
Licensing, Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601-1813

February 2006