

June 16, 2006

Mr. George A. Williams
Site Vice President
Grand Gulf Nuclear Station
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - NRC RECEIPT OF LICENSEE
RESPONSE TO GENERIC LETTER 2006-03, "POTENTIALLY
NONCONFORMING HEMYC AND MT FIRE BARRIER CONFIGURATIONS"
(TAC NO. MD1584)

Dear Mr. Williams:

The Nuclear Regulatory Commission (NRC) acknowledges the receipt of your response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." Your letter dated June 5, 2006, stated, under oath or affirmation, that Grand Gulf Nuclear Station, Unit 1 does not rely on either the Hemyc or MT fire barrier system and that the other 1 or 3-hour fire barrier (either Thermo-Lag 330 or 3M Interam), that separates redundant safe shutdown trains located within the same fire area, has been designed and installed in accordance with current NRC guidance. Based on your response, the basis for stating that the other fire barrier (either Thermo-Lag 330 or 3M Interam) has been designed and installed in accordance with NRC guidance should be maintained on site, and will be subject to inspection during the normal NRC inspection process.

If you have any questions regarding this response, please contact me at (301) 415-3308.

Sincerely,

/RA/

Bhalchandra Vaidya, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-416

cc: See next page

June 16, 2006

Mr. George A. Williams
Site Vice President
Grand Gulf Nuclear Station
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - NRC RECEIPT OF LICENSEE
RESPONSE TO GENERIC LETTER 2006-03, "POTENTIALLY
NONCONFORMING HEMYC AND MT FIRE BARRIER CONFIGURATIONS"
(TAC NO. MD1584)

Dear Mr. Williams:

The Nuclear Regulatory Commission (NRC) acknowledges the receipt of your response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." Your letter dated June 5, 2006, stated, under oath or affirmation, that Grand Gulf Nuclear Station, Unit 1 does not rely on either the Hemyc or MT fire barrier system and that the other 1 or 3-hour fire barrier (either Thermo-Lag 330 or 3M Interam), that separates redundant safe shutdown trains located within the same fire area, has been designed and installed in accordance with current NRC guidance. Based on your response, the basis for stating that the other fire barrier (either Thermo-Lag 330 or 3M Interam) has been designed and installed in accordance with NRC guidance should be maintained on site, and will be subject to inspection during the normal NRC inspection process.

If you have any questions regarding this response, please contact me at (301) 415-3308.

Sincerely,
/RA/

Bhalchandra Vaidya, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-416

cc: See next page

DISTRIBUTION:

PUBLIC

LPLIV r/f

RidsOgcRp

RidsNrrDorLpI4

DFrumkin, DRA

RidsAcrcAcnwMailCenter

RidsNrrPMBVaidya

RidNrrPMBSingal

RidsRgn4MailCenter (KKennedy)

RidsNrrLALFeizollahi

QNguyen, DPR

ACCESSION NO: ML061650383

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	AFPB/BC	NRR/LPL4/BC
NAME	BVaidya	LFeizollahi	SWeerakkody	DTerao
DATE	6/15/06	6/15/06	6/15/06	6/16/06

OFFICIAL RECORD COPY

Grand Gulf Nuclear Station

cc:

Executive Vice President
& Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

Winston & Strawn LLP
1700 K Street, N.W.
Washington, DC 20006

Chief
Energy and Transportation Branch
Environmental Compliance and
Enforcement Division
Mississippi Department of Environmental
Quality
P. O. Box 10385
Jackson, MS 39289-0385

President
Claiborne County
Board of Supervisors
P. O. Box 339
Port Gibson, MS 39150

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 399
Port Gibson, MS 39150

General Manager, GGNS
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150
Attorney General
Department of Justice

State of Louisiana
P. O. Box 94005
Baton Rouge, LA 70804-9005

State Health Officer
State Board of Health
P. O. Box 139
Jackson, MS 39205

Office of the Governor
State of Mississippi
Jackson, MS 39201

Attorney General
Asst. Attorney General
State of Mississippi
P. O. Box 220
Jackson, MS 39205

Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Director
Nuclear Safety Assurance
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

Director
Nuclear Safety & Licensing
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213-8298

Richard Penrod, Senior Environmental Scientist
State Liaison Officer
Office of Environmental Services
Northwestern State University
Russell Hall, Room 201
Natchitoches, LA 71497

May 2006