

July 5, 2006

Mr. Bruce H. Hamilton
Vice President, Oconee Site
Duke Power Company LLC
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 (OCONEE) - NRC
RECEIPT OF DUKE POWER COMPANY LLC RESPONSE TO GENERIC
LETTER 2006-03, "POTENTIALLY NONCONFORMING HEMYC AND MT FIRE
BARRIER CONFIGURATIONS (TAC NOS. MD1605, MD1606, AND MD1607)

Dear Mr. Hamilton:

We acknowledge receipt of your response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." Under oath or affirmation, you have submitted documentation that Oconee does have Hemyc installed, but that Oconee does not rely on the Hemyc or the MT fire barrier system or any other 1-hour or 3-hour fire barrier that separates redundant safe shutdown trains located within the same fire area. Based on your response, no further action is requested of you at this time.

If you have any questions regarding this matter, please contact me at 301 415-1419.

Sincerely,

/RA/

Leonard N. Olshan, Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

cc: See next page

July 5, 2006

Mr. Bruce H. Hamilton
Vice President, Oconee Site
Duke Power Company LLC
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 (OCONEE) - NRC
RECEIPT OF DUKE POWER COMPANY LLC RESPONSE TO GENERIC
LETTER 2006-03, "POTENTIALLY NONCONFORMING HEMYC AND MT FIRE
BARRIER CONFIGURATIONS (TAC NOS. MD1605, MD1606, AND MD1607)

Dear Mr. Hamilton:

We acknowledge receipt of your response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." Under oath or affirmation, you have submitted documentation that Oconee does have Hemyc installed, but that Oconee does not rely on the Hemyc or the MT fire barrier system or any other 1-hour or 3-hour fire barrier that separates redundant safe shutdown trains located within the same fire area. Based on your response, no further action is requested of you at this time.

If you have any questions regarding this matter, please contact me at 301 415-1419.

Sincerely,

/RA/

Leonard N. Olshan, Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

cc: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDorlDpr(BSingal)	RidsNrrDorlDpr(BSingal)	MMitchell, NRR
LPL2-1 r/f	RidsAcrsAcnwMailCenter	EAndruszkiewicz, NRR	RidsOgcRp
RidsNrrPMLOlshan	RidsNrrDorlLplc(EMarinos)	SWeerakkody, NRR	QNguyen, NRR
RidsNrrLAMO'Brien	RidsRgn2MailCenter(MErnstes)		

ADAMS ACCESSION NUMBER: ML061650421

NRR-106

OFFICE	LPL II-1/PM	LPL II-1/LA	NRR/AFP/BC	LPL II-1/BC
NAME	LOlshan:sxd6	MO'Brien	SWeerakkody	EMarinos
DATE	06/20/06	06/20/06	06/26/06	07/5/06

OFFICIAL RECORD COPY

Oconee Nuclear Station, Units 1, 2, and 3

cc:

Ms. Lisa F. Vaughn
Duke Power Company LLC
526 South Church Street
P. O. Box 1006
Mail Code EC07H
Charlotte, North Carolina 28201-1006

Manager, LIS
NUS Corporation
2650 McCormick Dr., 3rd Floor
Clearwater, FL 34619-1035

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
7812B Rochester Highway
Seneca, SC 29672

Mr. Henry Porter, Director
Division of Radioactive Waste Management
Bureau of Land and Waste Management
Dept. of Health and Env. Control
2600 Bull St.
Columbia, SC 29201-1708

Mr. Michael A. Schoppman
Framatome ANP
1911 North Ft. Myer Dr.
Suite 705
Rosslyn, VA 22209

Mr. B. G. Davenport
Regulatory Compliance Manager
Oconee Nuclear Site
Duke Power Company LLC
ON03RC
7800 Rochester Highway
Seneca, SC 29672

Ms. Karen E. Long
Assistant Attorney General
NC Department of Justice
P.O. Box 629
Raleigh, NC 27602

Mr. R. L. Gill, Jr.
Manager - Nuclear Regulatory
Issues and Industry Affairs
Duke Power Company LLC
526 S. Church St.
Mail Stop EC05P
Charlotte, NC 28202

Division of Radiation Protection
NC Dept of Environment, Health, & Natural
Resources
3825 Barrett Dr.
Raleigh, NC 27609-7721

Mr. Peter R. Harden, IV
VP-Customer Relations and Sales
Westinghouse Electric Company
6000 Fairview Road
12th Floor
Charlotte, NC 28210

Mr. Henry Barron
Group Vice President, Nuclear Generation
and Chief Nuclear Officer
P.O. Box 1006-EC07H
Charlotte, NC 28201-1006