

July 7, 2006

Mr. Karl W. Singer
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNIT 1 — REVIEW OF PENDING
LICENSE AMENDMENT REQUEST (TAC NO. MC4797) (TS-432)

Dear Mr. Singer:

This letter provides status of the U.S. Nuclear Regulatory Commission (NRC) staff's review of the Tennessee Valley Authority's (TVA's) request to remove License Condition 2.C(4) from Browns Ferry Nuclear Plant, Unit 1 (BFN1) license.

In a letter dated September 6, 1996, TVA submitted Technical Specification Change TS-362, a request for conversion to the improved standard technical specifications (ISTS). At that time, TVA had not announced any plans to restart Unit 1. In a letter dated December 29, 1997, TVA stated:

...Unit 1 is currently defueled and will require extensive analyses and modifications to be completed prior to restart. TVA plans to perform the required analyses and modifications on Unit 1 such that on restart, the Unit 1 plant configuration and analysis basis will be the same or similar to Units 2 and 3. Hence, in TS-362, the proposed Unit 1 ITS [improved technical specifications] were the same as those proposed for Units 2 and 3 except for minor intrinsic unit differences.

In that letter, TVA also proposed a License Condition for Unit 1 to ensure the appropriate modifications and analyses are in place prior to entering modes of operation for which the TS applies. The proposed license condition stated:

TVA shall review the Technical Specification (TS) changes made by TS-362 and subsequent TS changes for Unit 1, and verify that the required analyses and modifications needed to support the changes are complete prior to entering the mode for which the TS applies.

In the safety evaluation dated July 14, 1998, issuing Amendment No. 234, which approves the conversion to ISTS for Unit 1, the NRC staff included License Condition 2.C(4). The License Condition states that:

The licensee shall review the technical specification changes made by License Amendment number 234 and any subsequent TS changes, verify that the required analyses and modifications needed to support the changes are complete, and submit them for NRC review and approval prior to entering the mode for which the TS applies. This amendment is effective immediately and shall be implemented prior to entering the mode for which the TS applies.

The TVA submitted a plan for completion of License Condition 2.C(4) in a letter dated October 12, 2004 [ADAMS Accession No. ML042890152]. After review of this submittal, the NRC staff concluded that it does not provide sufficient information to approve removal of the license condition.

For example, in a letter dated July 14, 1997, the NRC staff noted that the proposed Unit 1 ITS included a main steam safety/relief valve setpoint tolerance of plus or minus 3 percent. A TVA letter dated December 11, 1996, states that analyses required to support this tolerance will be completed prior to Browns Ferry Nuclear Plant, Unit 1 restart. TVA did not list and discuss this change in its submittal.

In order to avoid impact on planned BFN1 recovery activities (e.g, Fuel load or startup), the submittal needs to be supplemented by September 1, 2006, with the following:

- C List and discuss the justifications for all changes to the TS made by License Amendment 234 and subsequent license amendments. The discussion should include whether new analyses and/or modifications were required and whether the analyses were provided to the NRC staff for review and approval. The discussion should also include the confirmation that the analyses were approved by the NRC staff at the time the applicable amendment was issued and the modifications were completed, if required.

- C Based on discussions with TVA and the Unit 1 status update dated February 21, 2006 [ADAMS Accession No. ML060520652], the NRC staff understands that TVA is updating the Unit 1 design basis analyses and calculations to support the requested extended power uprate, in lieu of updating the analyses and calculations to support operation at the current licensed thermal power limit. TVA should address how the analyses and calculations to support the uprated condition satisfy the requirements of the license condition, when it is applicable.

K. Singer

- 3 -

July 7, 2006

This information is needed by September 1, 2006, in order to support planned BFN1 recovery activities. If you have any questions, please contact Ms. Margaret Chernoff at 301-415-4041 or Mr. Chandu Patel at 301-415-3025.

Sincerely,

/RA/

Cornelius F. Holden, Deputy Director
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-259

cc: See next page

This information is needed by September 1, 2006, in order to support planned BFN1 recovery activities. If you have any questions, please contact Ms. Margaret Chernoff at 301-415-4041 or Mr. Chandu Patel at 301-415-3025.

Sincerely,

/RA/

Cornelius F. Holden, Deputy Director
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-259

cc: See next page

DISTRIBUTION:

PUBLIC	LPL2-2 R/F	RidsNrrDorlLpl2-2	RidsNrrLABClayton (Hard copy)
RidsNrrPMEBrown		RidsNrrPMMChernoff	RidsNrrPMCPatel
DDuvigneaud		RidsOgcRp	RidsAcrsAcnwMailCenter
RidsRgn2MailCenter		RidsNrrDorl	RidsNrrDorlDpr
RidsNrrAdro		RidsNrrDirRebb	TKobetz
WBearden, SRI		CShulten	

ADAMS Accession No.: ML061650423

NRR-058

OFFICE	LPL2-2/PM	LPL2-2/PM	LPL2-2/LA	LPL2-2/BC	DIRS/ITSB	DORL/DD
NAME	CPatel	MChernoff	RSola for BClayton	MMarshall	TKobetz	CHolden
DATE	7/3/06	7/3/06	7/3/06	7/3/06	7/5/06	7/7/06

OFFICIAL RECORD COPY

BROWNS FERRY NUCLEAR PLANT

Mr. Karl W. Singer
Tennessee Valley Authority
cc:

Mr. Ashok S. Bhatnagar, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Larry S. Bryant, Vice President
Nuclear Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Brian O'Grady, Site Vice President
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Mr. Robert J. Beecken, Vice President
Nuclear Support
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

General Counsel
Tennessee Valley Authority
ET 11A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. John C. Fornicola, Manager
Nuclear Assurance and Licensing
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Bruce Aukland, Plant Manager
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Mr. Masoud Bajestani, Vice President
Browns Ferry Unit 1 Restart
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Mr. Robert G. Jones, General Manager
Browns Ferry Site Operations
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Mr. Larry S. Mellen
Browns Ferry Unit 1 Project Engineer
Division of Reactor Projects, Branch 6
U.S. Nuclear Regulatory Commission
61 Forsyth Street, SW.
Suite 23T85
Atlanta, GA 30303-8931

Mr. Glenn W. Morris, Manager
Corporate Nuclear Licensing
and Industry Affairs
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. William D. Crouch, Manager
Licensing and Industry Affairs
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, AL 35611-6970

State Health Officer
Alabama Dept. of Public Health
RSA Tower - Administration
Suite 1552
P.O. Box 303017
Montgomery, AL 36130-3017

Chairman
Limestone County Commission
310 West Washington Street
Athens, AL 35611