

**From:** <Tony\_Banks@Dom.com>  
**To:** "Nitin Patel" <NXP1@nrc.gov>  
**Date:** 6/8/2006 3:14:12 PM  
**Subject:** Re: References--RAIs 4 AND 6 of RAI Letter dated 5/10/2006

Nitin - attached are the relevant pages from GE correspondence referenced in Dominion's May 24, 2006 responses to NRC's May 10, 2006 RAIs 4 and 6. Content from GEDO letters -0014 and -0026 provide information for RAI 4. Content from GEDO letter -0020 provides information for RAI 6. (This is the same information that was provided in the 5/24/06 response.)

Joe and I will follow up this transmittal with a letter.

Please let me know if you have any questions - thank you.

Tony Banks, MPH, CHMM  
Dominion  
ESP/COL Project  
Project Lead - Environmental  
804/273-2170

(See attached file: 060806 GEDO-SR5-2006-0026-ESBWR\_EAB Dose\_tb.pdf)(See attached file: 060806 GEDO-SR5-2006-0014-ESBWR\_LOCA\_Values\_Report\_tb.pdf)  
(See attached file: 060806 GEDO-SR5-2006-0020-ESBWR Source Term based on MAAP runs\_tb.pdf)

-----  
**CONFIDENTIALITY NOTICE:** This electronic message contains information which may be legally confidential and/or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.

**CC:** "Jack Cushing" <JXC9@nrc.gov>, <Joseph\_Hegner@Dom.com>, <rlbaker@bechtel.com>, "Kingston, Rick E. (GE Infra, Energy)" <Rick.Kingston@ge.com>, <Tony\_Banks@Dom.com>

**Mail Envelope Properties** (448876F5.0F5 : 22 : 61685)

**Subject:** Re: References--RAIs 4 AND 6 of RAI Letter dated 5/10/2006  
**Creation Date** 6/8/2006 3:13:06 PM  
**From:** <[Tony\\_Banks@Dom.com](mailto:Tony_Banks@Dom.com)>

**Created By:** [Tony\\_Banks@Dom.com](mailto:Tony_Banks@Dom.com)

**Recipients**

nrc.gov  
 TWGWPO03.HQGWDO01  
 NXP1 (Nitin Patel)

nrc.gov  
 OWGWPO03.HQGWDO01  
 JXC9 CC (Jack Cushing)

ge.com  
 Rick.Kingston CC (Rick E. (GE Infra Energy) Kingston)

bechtel.com  
 rlbaker CC

Dom.com  
 Joseph\_Hegner CC

**Post Office**

TWGWPO03.HQGWDO01  
 OWGWPO03.HQGWDO01

**Route**

nrc.gov  
 nrc.gov  
 ge.com  
 bechtel.com  
 Dom.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>	
MESSAGE	1601	6/8/2006 3:13:06 PM	
060806 GEDO-SR5-2006-0026-ESBWR_EAB Dose_tb.pdf			93518
060806 GEDO-SR5-2006-0014-ESBWR_LOCA_Values_Report_tb.pdf			110488
060806 GEDO-SR5-2006-0020-ESBWR Source Term based on MAAP runs_tb.pdf			105872
Mime.822	428118		

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**ReplyRequested:** No

**Return Notification:**           None  
**Concealed Subject:**           No  
**Security:**                     Standard

## ENCLOSURE 1

Table 1 - ESBWR Core Inventory ESBWR Core Power is 4500 MWt			
Nuclide	Bq/MWt	Nuclide	Bq/MWt
Co-58	5.10E+12	Te-131m	1.42E+14
Co-60	4.92E+12	Te-132	1.41E+15
Kr-85	1.23E+13	I-131	9.90E+14
Kr-85m	2.73E+14	I-132	1.44E+15
Kr-87	5.27E+14	I-133	2.04E+15
Kr-88	7.42E+14	I-134	2.25E+15
Rb-86	2.35E+12	I-135	1.91E+15
Sr-89	9.93E+14	Xe-133	2.03E+15
Sr-90	9.76E+13	Xe-135	6.72E+14
Sr-91	1.25E+15	Cs-134	1.98E+14
Sr-92	1.34E+15	Cs-136	6.89E+13
Y-90	1.01E+14	Cs-137	1.28E+14
Y-91	1.27E+15	Ba-139	1.84E+15
Y-92	1.34E+15	Ba-140	1.77E+15
Y-93	1.55E+15	La-140	1.82E+15
Zr-95	1.70E+15	La-141	1.68E+15
Zr-97	1.69E+15	La-142	1.62E+15
Nb-95	1.71E+15	Ce-141	1.68E+15
Mo-99	1.89E+15	Ce-143	1.56E+15
Tc-99m	1.68E+15	Ce-144	1.36E+15
Ru-103	1.50E+15	Pr-143	1.53E+15
Ru-105	1.00E+15	Nd-147	6.69E+14
Ru-106	5.21E+14	Np-239	1.93E+16
Rh-105	9.10E+14	Pu-238	3.34E+12
Sb-127	1.03E+14	Pu-239	4.02E+11
Sb-129	3.15E+14	Pu-240	5.21E+11
Te-127	1.05E+14	Pu-241	1.51E+14
Te-127m	1.37E+13	Am-241	1.70E+11
Te-129	3.10E+14	Cm-242	4.01E+13
Te-129m	4.60E+13	Cm-244	1.94E+12

ENCLOSURE 1

<b>Table 2 - Relationship Between MAACS and MAAP Fission Product Groups</b>		
<b>MACCS Release Groups</b>	<b>MAAP Release Groups</b>	<b>MAAP Output Parameter</b>
1-Xe/Kr	noble gases	FREL (1)
2-I	CsI	FREL (2)
3-Cs	CsOH	FREL (6)
4-Te	TeO <sub>2</sub> (Sb & Te <sub>2</sub> fractions are included)	FREL (3), FREL (10) and FREL (11)
5-Sr	SrO	FREL (4)
6-Ru	MoO <sub>2</sub> (Mo is in Ru MACCS category)	FREL (5)
7-La	La <sub>2</sub> O <sub>3</sub>	FREL (8)
8-Ce	CeO <sub>2</sub> (included UO <sub>2</sub> in this category)	FREL (9) and FREL (12)
9-Ba	BaO	FREL (7)

ENCLOSURE 1

Table 3 - Summary of ESBWR Release Categories and Associated Frequencies		
Release Category	Summary Description	Release Frequency (reactor year <sup>-1</sup> )
BYP	Containment is bypassed because of CIS failure with large (>12" diameter hole) opening in containment. Lower drywell debris bed covered.	1E-12
BOC	Break outside of containment.	4E-12
CCID	Containment fails due to core concrete interaction; lower drywell debris bed uncovered.	2.9E-11
CCIW	Containment fails due to core concrete interaction; lower drywell debris bed covered.	2.9E-10
DCH	Direct containment heating (high pressure RPV failure) event damages containment	<1E-12
EVE	Ex-vessel steam explosion fails containment	2.5E-10
FR	Release through controlled (filtered) venting from suppression chamber	2.3E-10
OPVB	Containment fails due to failure of vapor suppression (vacuum breaker) function.	<1E-12
OPW1	Containment fails due to early (<24 hours) loss of containment heat removal.	<1E-12
OPW2	Containment fails due to late (>24 hours) loss of containment heat removal.	1.4E-11
TSL	Containment leakage at Technical Specification limit.	2.8E-8

ENCLOSURE 1

Table 4 - Radionuclide Source Terms (Release Fraction 72 hours after onset of core damage)												
Release Category	Xe/Kr	CsI	TeO <sub>2</sub>	SrO	MoO <sub>2</sub>	CsOH	BaO	La <sub>2</sub> O <sub>3</sub>	CeO <sub>2</sub>	Sb	Te <sub>2</sub>	UO <sub>2</sub>
BOC	1.0E+00	8.5E-01	7.5E-01	1.5E-02	7.2E-02	3.8E-01	1.5E-02	6.1E-04	3.4E-03	1.5E-01	6.1E-03	2.9E-05
BYP	9.8E-01	4.3E-01	2.3E-01	1.6E-02	1.2E-01	3.7E-01	2.9E-02	5.3E-04	3.3E-03	5.0E-01	1.2E-02	2.4E-05
CCID	9.2E-01	5.3E-01	2.3E-01	2.3E-06	5.1E-06	3.2E-01	2.2E-05	1.4E-07	1.1E-06	3.5E-01	1.5E-02	3.0E-07
CCIW	9.2E-01	1.1E-02	2.7E-03	1.4E-06	4.5E-06	2.5E-02	1.1E-06	1.3E-07	7.6E-07	6.8E-03	6.5E-05	7.9E-09
DCH	9.0E-01	8.0E-01	2.2E-01	3.2E-04	2.7E-04	1.5E-01	3.2E-04	3.2E-04	3.2E-04	2.7E-01	1.1E-04	1.6E-07
EVE	8.4E-01	2.5E-01	1.4E-01	1.3E-02	1.1E-04	3.4E-01	5.7E-03	8.2E-04	6.2E-03	5.4E-01	9.8E-03	5.0E-05
FR	1.0E+00	9.8E-06	8.1E-07	1.1E-08	1.9E-07	4.6E-05	3.2E-08	4.1E-10	1.5E-09	2.5E-03	2.9E-05	1.0E-11
OPVB	9.9E-01	2.8E-01	3.9E-02	1.7E-03	1.2E-04	3.4E-02	8.7E-04	1.5E-04	3.1E-04	7.1E-02	3.1E-05	5.2E-07
OPW1	9.9E-01	6.0E-01	2.1E-01	1.6E-03	4.3E-07	1.4E-01	7.5E-04	5.8E-06	1.8E-04	1.6E-01	3.2E-05	5.9E-07
OPW2	9.9E-01	3.8E-02	5.7E-02	1.2E-03	2.0E-07	4.3E-02	5.7E-04	3.9E-06	1.4E-04	1.0E-01	1.5E-05	3.4E-07
TSL	2.0E-03	1.5E-04	9.5E-05	2.1E-06	3.9E-05	5.5E-05	7.7E-06	7.3E-08	2.0E-07	1.2E-04	4.8E-08	1.0E-10

ENCLOSURE 1

<b>Table 5 - ESBWR Plume Characterization MACCS2 Data</b>								
<b>Release Category</b>	<b>OALARM<sup>(1)</sup> (s)</b>	<b>NUMREL<sup>(2)</sup></b>	<b>MAXRIS<sup>(3)</sup></b>	<b>REFTIM<sup>(4)</sup> (s)</b>	<b>PLHEAT<sup>(5)</sup> (W)</b>	<b>PLHITE<sup>(6)</sup> (m)</b>	<b>PLDUR<sup>(7)</sup> (s)</b>	<b>PDELAY<sup>(8)</sup> (s)</b>
BOC	1,200	1	1	0.0	0	47.7	9,000	2,100
BYP	1,200	1	1	0.0	0	47.7	7,800	1,800
CCID	21,100	1	1	0.0	0	47.7	36,000	53,100
CCIW	21,100	1	1	0.0	0	47.7	36,000	69,500
DCH	16,300	1	1	0.0	0	47.7	36,000	16,200
EVE	22,400	1	1	0.0	0	47.7	36,000	22,500
FR	9,800	1	1	0.0	0	47.7	36,000	102,600
OPVB	16,500	1	1	0.0	0	47.7	36,000	65,300
OPW1	16,600	1	1	0.0	0	47.7	36,000	91,500
OPW2	17,600	1	1	0.0	0	47.7	36,000	146,900
TSL	21,000	1	1	0.0	0	47.7	36,000	1,100

Notes:

1. OALARM defines the time notification is given by site personnel to off-site emergency response officials to initiate protective measures for the surrounding population (i.e., General Emergency is declared). This time is a function of the accident sequences and is measured from accident initiation (i.e. SCRAM time). OALARM is a function of the application of Emergency Action Levels by a utility to the unfolding sequence. The OALARM values presented are typical values based on the loss or potential loss of multiple fission product barriers. Typically a General Emergency is declared when there is a loss of two fission product barriers (e.g., fuel cladding, RCS) and the potential loss of a third fission product barrier (e.g., containment). Sensitivity cases using various OALARM values are suggested to test for site-specific impacts related to this variable. The following outlines the OALARM bases for the release categories:
  - a. BOC: The RCS and containment are lost at the start of the event. Loss of the fuel cladding would be expected quickly following the failure of ECCS to initiate. An OALARM = 20 minutes is used for the crew to diagnose the event and declare a General Emergency.
  - b. BYP: The containment is lost at the start of the event. RCS is lost when the DPVs open. Loss of fuel cladding would be expected quickly following the failure of ECCS to initiate. An OALARM = 20 minutes is used for the crew to diagnose the event and declare a General Emergency.
  - c. CCID, CCIW, FR, OPVB, OPW1, OPW2, TSL: The fuel cladding and RCS are lost early in the event. The containment would be considered potentially lost when the containment pressure equals the design pressure. OALARM is based on the time when containment pressure = 60 psia. (design pressure)
  - d. DCH & EVE: The fuel cladding and RCS are lost early in the event. The containment integrity would be challenged at the time of the energetic vessel breach. OALARM is based on the time of vessel breach.
2. NUMREL=1 specifies that one plume is modeled.
3. MAXRIS=1 specifies that Plume 1 (the only plume modeled) is the risk dominant plume.
4. REFTIM=0.0 specifies that the plume leading edge is used as the representative time point for the plume decay, dry deposition, and dispersion calculations (Options include: 0.0=leading edge, 0.5=mid-point, 1.0=trailing edge).
5. PLHEAT=0.0 specifies the rate of release of sensible heat in the plume and is used to determine the amount of buoyant plume rise. This quantity is calculated as the amount of sensible heat in the plume divided by the duration of the plume. A zero value, selected here, represents ambient conditions for the plume and is usually more conservative for potential human impacts. A larger value creates buoyant effects that cause the plume to rise away from the ground. Sensitivity cases using a PLHEAT = 1E5, 1E6, and 1E7 are suggested.
6. PLHITE=47.7 meter specifies the height of the plume release above ground level. This 47.7 m height corresponds to the top of the reactor building.
7. PLDUR specifies the duration in seconds of each plume segment.
8. PDELAY specifies the start time of each plume segment after accident initiation (i.e., SCRAM).