

From: <kenneth.anger@exeloncorp.com>
To: <sko@nrc.gov>
Date: Wed, Dec 7, 2005 1:51 AM
Subject: FW: Names, telephone numbers of residents

Steve,

Here is a re-send of my earlier e-mail to you. I will call you shortly to verify you received it this time.

Ken

> -----Original Message-----

> From: Ainger, Kenneth A.
> Sent: Tuesday, December 06, 2005 5:26 PM
> To: 'sko@nrc.gov'
> Subject: Names, telephone numbers of residents

> Steve,

> Attached, in accordance with your request, is a list of the residents near the plant whose drinking water wells we sampled. It includes their address and telephone numbers.

> Ken Ainger

>> <<Homeowner Well Sampling List - NRC.doc>>

This e-mail and any of its attachments may contain Exelon Corporation proprietary information, which is privileged, confidential, or subject to copyright belonging to the Exelon Corporation family of Companies. This e-mail is intended solely for the use of the individual or entity to which it is addressed. If you are not the intended recipient of this e-mail, you are hereby notified that any dissemination, distribution, copying, or action taken in relation to the contents of and attachments to this e-mail is strictly prohibited and may be unlawful. If you have received this e-mail in error, please notify the sender immediately and permanently delete the original and any copy of this e-mail and any printout. Thank You.

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 6
FOIA- 2006-115

6-52

Homeowner Well Sampling - NRC

Home/Property Owner	Address	Phone	Sample Drawn or Date to be Drawn	Notes
[REDACTED]	[REDACTED] Braidwood, IL 60408	[REDACTED]	Samples of the well were taken Dec. 1 -- no tritium above background was detected. Communicated Results back to resident on Dec. 2.	
[REDACTED]	[REDACTED] Braidwood, IL 60408	[REDACTED]	Samples of the well were taken Dec. 1 -- no tritium above background was detected. Communicated Results back to resident on Dec. 2.	
[REDACTED]	[REDACTED] Braidwood, IL 60408	[REDACTED]	Samples of the well were taken Dec. 1 -- no tritium above background was detected. Communicated Results back to Mr. Keca on Dec. 2.	[REDACTED]
[REDACTED]	[REDACTED] Braidwood, IL 60408	[REDACTED]	Samples of the well were taken Dec. 2 -- no tritium above background was detected. Communicated Results back to resident on Dec. 4.	
[REDACTED]	[REDACTED] Braidwood, IL 60408	[REDACTED]	Samples of the well were taken on Dec 3 -- tritium levels were 1150 pCi/L. Communicated Results back to resident on Dec. 5.	
[REDACTED]	[REDACTED] Braidwood, IL 60408	[REDACTED]	Samples of well taken on Dec. 5. No tritium above background was detected. Communicated Results back to resident on Dec. 6.	
[REDACTED]	[REDACTED] Braidwood, IL 60408	[REDACTED]	Samples of well taken on Dec. 5. Received permission for sampling wells if needed. Communicated Results back to resident on Dec. 6.	