

*R3*

**From:** Steven Orth  
**To:** Monte Phillips  
**Date:** Fri, Feb 3, 2006 8:02 AM  
**Subject:** EDO Call Bullets — BWD and Japanese Visit

As promised.

**CC:** Thomas Kozak

Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions 5 outside scope  
FOIA- 2006-0115

*G-131*

### Braidwood Tritium Contamination

The licensee has extended its communications of the incidents to additional members of the public. On January, 26, 2006, the licensee issued a letter that has been sent out to the three local zip codes surrounding the site (approximately 2700 addressees). The letter provides the message that has been communicated through the licensee's press briefings – accepting responsibility for the contamination, stating that the contamination poses no health or safety hazard, and describing the licensee's current course of action. The licensee has also developed a WEB site ([www.BraidwoodTritium.info](http://www.BraidwoodTritium.info)) to provide updated information to the public and is planning a "Community Information Night" at some time in February 2006, which Region III plans to attend.

The City of Godley, which is a town immediately SouthWest of the site, is also planning a town meeting on February 7, 2006, to discuss the potential impacts from the tritium contamination. The NRC has not been invited to that meeting. The town was previously impacted by diesel fuel oil spills from Braidwood that occurred in the late 1990s.

The licensee is continuing its evaluation of the tritium contamination and its proposals for remediation. Recently, the licensee identified additional contamination in groundwater at an offsite location near Vacuum Breaker No. 4, which is owned by the Forest Preserve District. In one of three groundwater well locations, the licensee measured tritium at about 24,500 picoCuries per liter (shallow well). The licensee has obtained an additional sample to validate that result. Until it can provide confidence that no further leakage will occur, the licensee has suspended all radioactive releases through the blowdown line and is storing radioactive liquid waste in temporary onsite storage tanks.



*eyt*