Simulation Facility	Braidwood	Scenario No.: NRC 06-1	Operating Test No.: 2006	301
Examiners:		Applicant:		<u>SRO</u>
		_		<u>RO</u>
		_		BOP

Initial Conditions: IC-18

Turnover: Unit 1 is at 76% power, steady state, equilibrium xenon, MOL. Online risk is green. 1B Heater Drain Pump is OOS for motor replacement for the past 3 days. Expected back in service in 7 days. 0BwISR 3.3.7.3-201, Surveillance Calibration of Control Room Outside Air Intake Rad Monitor 0PR31J, is in progress. Awaiting IMD supervisor package review. LCOAR 3.3.7, Condition A has been entered. 0 CC pump is mechanically and electrically aligned to Unit 2 due to OOS on 2B CC pump. 1CV8149C was returned to service last shift following maintenance to replace its fuse block. Following completion of turnover, the shift manager requests the BOP swap 75 gpm letdown orifices from 1B to 1C per BwOP CV-9 for an upcoming clearance order on 1CV8149B to replace its fuse block while the RO monitors reactor power.

Event	Malf. No.	Event	Event
No.		Type*	Description
	IOR ZDI1HD01PB PTL		1B HD pump OOS
	IRF CC42 RO		0 CC pump aligned to bus 242
	TRGSET 1		1A SG safety valves stuck open
	ZLO1FW009A(1) = = 1		
	IMF MS03A (1 0) 100 0		
	IMF MS03E (1 0) 100 0		
	IMF MS03I (1 0) 100 0		
	IMF CV32B		
	1 KGSET 2		IB CV pump auto start failure
	$\sum_{i=1}^{n} \sum_{j=1}^{n} \sum_{i=1}^{n} \sum_{i=1}^{n} \sum_{j=1}^{n} \sum_{i=1}^{n} \sum_{i=1}^{n} \sum_{j=1}^{n} \sum_{i=1}^{n} \sum_{i=1}^{n} \sum_{i=1}^{n} \sum_{i=1}^{n} \sum_{i=1}^{n} \sum_{i=1}^{n} \sum_{i=1}^{n} \sum_{i=1}^{n} \sum_{i$		IA CV pump trip
	1000000000000000000000000000000000000		
1	None	N-BOP, US	Swap Letdown orifices
2	IMF PA0253 ON	C-US	SG PORV 1MS018A inoperable (Tech Spec)
	IOR ZDI1MS018A CLS		
3	IMF RX10A 0 15	I-RO, US	Turbine Impulse Pressure channel 1PT-505 failed low
			(Tech Spec)
4	IMF FW35A	C-BOP, US	IB Heater Drain Pump trip
5	TH02A 450 120	K-KU, US	1 A COTD (450 area)
5	1H03A 450 120	M-ALL	1A SG1K (450 gpm)
6	Dualaad	C DO	1 A CV surges trips/1 D CV surges foils to outs start
0	Preioad	C-KU	TACV pump trips/TBCV pump fails to auto start
7	Draland	MALI	Foulted (ruptured) 1A SG
/	I ICIUAU	IVI-ALL	
*(N)ormal.	(R)eactivity (I)nstru	ment. (C)om	ponent. (M)ajor Transient

SCENARIO OVERVIEW

Unit 1 is at 76% power, steady state, equilibrium xenon, MOL. Online risk is green. 1B Heater Drain Pump is OOS for motor replacement for the past 3 days. Expected back in service in 7 days. 0BwISR 3.3.7.3-201, Surveillance Calibration of Control Room Outside Air Intake Rad Monitor 0PR31J, is in progress. Awaiting IMD supervisor package review. LCOAR 3.3.7, Condition A has been entered. 0 CC pump is mechanically and electrically aligned to Unit 2 due to OOS on 2B CC pump. 1CV8149C was returned to service last shift following maintenance to replace its fuse block. Following completion of turnover, the shift manager requests the BOP swap 75 gpm letdown orifices from 1B to 1C per BwOP CV-9 for an upcoming clearance order on 1CV8149B to replace its fuse block while the RO monitors reactor power.

After completing shift turnover and relief, the crew will swap letdown orifices. The RO will manually lower letdown pressure, remove 1B letdown orifice from operation and place 1C letdown orifice on-line. The RO will then restore letdown line pressure and restore letdown to automatic operation

After completing the letdown orifice swap, Steam Generator 1A atmospheric relief valve 1MS018A, will develop a hydraulic leak. The Unit Supervisor will enter Tech Spec 3.7.4, Condition A and Tech Spec 3.6.3, Condition C. The crew will dispatch an operator to close 1MS019A to comply with TS 3.6.3, condition C. 1MS018A will remain unavailable for the remainder of the scenario.

After the 1MS018A failure has been addressed, First Stage Turbine Impulse Pressure channel 1PT-505 will fail low. The RO will diagnose the failure of 1PT-505 and take manual control of rods after verifying turbine load stable. 1BwOA INST 2, OPERATION WITH A FAILED INSTRUMENT CHANNEL-Attachment D will be entered. TS 3.3.1 conditions A and P will be entered. The RO will return rod control to automatic after verifying Tave and Tref are within 1°F.

After the 1PT-505 failure has been addressed, 1A Heater Drain Pump will trip. 1BwOA SEC-1, SECONDARY PUMP TRIP-Attachment C will be entered. The BOP will initiate a turbine load reduction to 780 MW at 20 MW/minute. The RO will borate the RCS as necessary to stabilize RCS temperature.

After the 1A Heater Drain Pump trip has been addressed, a 450 gpm SGTR will occur on the 1A SG. Pressurizer level will drop and a manual reactor trip will be required. When the reactor is tripped, three safety valves on the 1A SG will stick open, causing a faulted/ruptured SG. The crew will implement 1BwEP-0, REACTOR TRIP OR SAFETY INJECTION. When safety injection is actuated, the 1A CV pump will trip. The 1B CV pump must be manually started to establish high head ECCS flow. After determining 1A SG secondary pressure boundary is not intact the crew will transition to 1BwEP-2, FAULTED STEAM GENERATOR ISOLATION. The crew will complete isolation of 1A SG and transition to 1BwEP-3, STEAM GENERATOR TUBE RUPTURE, based on secondary radiation trends on the 1A SG. After determining ruptured SG pressure is less than 320 psig the crew will transition 1BwCA-3.1, SGTR WITH LOSS OF REACTOR COOLANT – SUBCOOLED RECOVERY DESIRED.

Completion criteria is completion of step 6 of 1BwCA-3.1

Critical Tasks

- 1. Manually start the 1B CV pump prior to completion step 6 of 1BwEP-0. (ERG Critical Task number - E-0--I) (K/A number - 013000A4.01 importance - 4.5/4.8)
- Isolate 1A Steam Generator prior to completing step 4 of 1BwEP-2. (ERG Critical Task number - E-2--A) (K/A number - 000040AA1.10 importance - 4.1/4.1)

SIMULATOR SETUP GUIDE:

- Verify/perform TQ-BR-201-0113, BRAIDWOOD TRAINING DEPARTMENT SIMULATOR EXAMINATION SECURITY ACTIONS CHECKLIST.
- Establish the conditions of IC 18, 75% power, steady state, equilibrium xenon.
- Complete items on Simulator Ready for Training Checklist.
- Verify/remove any Equipment Status Tags and Danger Tags not applicable to the scenario.
- Place simulator in RUN (allow simulator to run during board walk down and turnover).
- Place 1B HD pump and 0 CC pumps from 141 and 142 in PTL.
- Run caep NRC 06-1 SETUP from disk and verify the following actuate:
 - IOR ZDI1HD01PB PTL
 - IRF CC42 RO
 - TRGSET 1 "ZLO1FW009A(1) = = 1"
 - IMF MS03A (1 0) 100 0
 - IMF MS03E (1 0) 100 0
 - IMF MS03I (1 0) 100 0
 - IMF CV32B
 - TRGSET 2 "ZLO1SI01PA(3) = = 1"
 - IMF CV01A (2 0)
- Adjust control bank D rod height to 140 steps by performing the following:
 - Place rod bank select switch in manual.
 - Insert control bank D to 130 steps.
 - IRF CV79 684 60
 - Verify Tave Tref within 1°F.
 - Place rod bank select switch to auto.
- Place danger tags on 1B HD pump and 1HD075B.
- Update PARAGON to reflect 1B HD pump OOS.
- Set Δ I Target Curve slopes to 0.02 (2.0%).
- Provide examinees with turnover sheets, 1BwOS NR-1, & critical parameter sheet.

Event 1: Swap Letdown orifices

As SM, acknowledge the completion of letdown orifice swap.

Event 2: SG PORV 1MS018A inoperable (Tech Spec)

Run caep NRC 06-1 EVENT 2 from disk and verify the following actuate:

- IMF PA0252 ON
- IMF PA0253 ON
- IOR ZDI1MS018A CLS

As SM acknowledge the failure, LCO 3.6.3, condition C and LCO 3.7.4, condition A, and requests for on line risk assessment, maintenance support, and IR initiation.

If dispatched as NLO, report 1MS018A has a broken hydraulic line and a small puddle of hydraulic fluid is present beneath the valve.

As WEC supervisor. acknowledge request for EST for 1MS018A C/S, if EST is requested.

If dispatched as NLO to close 1MS019A, perform the following:

• IRF MS51 0

Event 3: Turbine Impulse Pressure channel 1PT-505 failed low.

Insert IMF RX10A 0 15

As SM, acknowledge the failure, 1BwOA INST-2 entry, request for E Plan evaluation, LCO 3.3.1 conditions A & P entry, and requests for on line risk assessment (GREEN), maintenance support, and IR initiation.

If lead examiner desires the bistables tripped, participate in brief and perform the following:

- As assist NSO contact Unit 1 (X-2209)
- Insert the following:
 - MRF RP20 OPEN
 - MRF RX143 TRIP
 - MRF RP20 CLOSE

If lead examiner desires the AMS bistables tripped, participate in brief and perform the following:

- As assist NSO contact Unit 1 (X-2209)
- Insert the following:
 - IMF PN0470 ON to place operating bypass switch in TIP 1 position (On annunciator tab of Action List)
 - MRF RX149 TRIP to place operating bypass input switch to test-trip

Event 3: 1B Heater Drain Pump trip

ENSURE ROD CONTROL IS RETURNED TO AUTOMATIC PRIOR TO INSERTING THE NEXT MALFUNCTION.

Insert IMF FW35A

As SM, acknowledge the failure, 1BwOA SEC-1 entry, request for E Plan evaluation, and requests for on line risk assessment, maintenance support, and IR initiation.

If dispatched as NLO, report 1A Heater Drain pump is seized and report ground overcurrent flag at breaker cubicle.

Event 4: 1A SGTR (450 gpm)

Insert IMF TH03A 450 10

Acknowledge as SM procedure changes, E Plan evaluations, and STA request.

After STA requested, as STA report CSF status:

Event 5: 1A CV pump trips/1B CV pump fails to auto start (preload)

If dispatched as NLO to investigate 1A CV pump, report ground overcurrent flag at breaker cubicle.

Event 6: Faulted ruptured 1A SG (preload)

Acknowledge as SM procedure changes, E Plan evaluations, and STA request.

After STA requested, as STA report CSF status:

Scenario	Scenario No: NRC 06-1 Event No. 1			
Event Description: Swap Letdown orifices				
Time	Position	Applicant's Actions or Behavior		
	CUE	• Shift manager requests swapping letdown orifices from 1B to 1C (from turnover).		
	US	• Directs RO to swap letdown orifices from 1B to 1C per BwOP CV-9		
	RO	 Refers to BwOP CV-9 Lower letdown pressure Place 1PK-131, LTDWN Line Press Cont Vlv 1CV131, to MANUAL Raise demand on 1PK-131, LTDWN Line Press Cont Vlv 1CV131, to lower letdown pressure to ~180 psig (1PI-131) Remove 1B letdown orifice from operation Close 1CV8149B Align 1C letdown orifice Open 1CV8149C Restore letdown pressure to 370 psig Lower demand on 1PK-131, LTDWN Line Press Cont Vlv 1CV131 Restore letdown pressure without causing the following annunciators: LTDWN HX OUTLT PRESSURE HIGH (1-8-B5) LP LTDWN RLF TEMP HIGH (1-9-B1) Restore automatic letdown pressure control Verify letdown temperature 90°F - 115°F (1TI-130) Verify PZR level is being maintained at the program value Inform US letdown orifices swapped 		
	US	 Acknowledge report Notify SM letdown orifices swapped from 1B to 1C 		
		NOTE: After the actions for swapping letdown orifices are complete and with lead examiners concurrence, enter next event		

Scenario	Scenario No: NRC 06-1 Event No. 2		
Event Description:		SG PORV 1MS018A inoperable	
Time	Position	Applicant's Actions or Behavior	
	CUE	 Annunciator S/G 1A PORV TROUBLE (1-15-A10). SER 0252, 1A PORV HYDRAULIC FLUID RESERVOIR LOW. SER 0253, S/G PORV 1A ACCUMULATOR PRESSURE LOW. 	
	BOP	 Identify/report trouble alarm on 1MS018A Refer to BwAR 1-15-A10 Dispatch operator to 1MS018A Place 1MS018A C/S in close to stop hydraulic pump Request Equipment Status Tag for 1MS018A 	
	RO	 Assist US & BOP Refer to BwARs Dispatch operators Refer to Tech Specs Inform SM of 1MS018A failure 	
	US	 Identify entry conditions for TS 3.7.4, condition A. Identify entry conditions for TS 3.6.3, condition C Direct operator to close 1MS019A. 	
	US	 Inform SM of 1MS018A status, TS Status, request IR, On Line Risk Assessment, maintenance support, and clearance order/EST for 1MS019A. 	
		NOTE: After the actions for 1MS018A failure are complete and with lead examiners concurrence, enter next event	

Scenario	No: NRC	2 06-1 Event No. 3
Event De	escription:	Turbine Impulse Pressure Channel 1PT-505 failed low
Time	Position	Applicant's Actions or Behavior
	CUE	Annunciator TAVE CONT DEV HIGH (1-14-D1)
		• 1PI-505, First Stage Pressure, indication lowering.
		Control rod inward motion
		• 1TR-0412, Auct Tave/Tref recorder, Tref indication lowering
		• 1SI-412, Rod Speed, indicates 72 step per minute
	RO	Recognizes 1PT-505 has failed low
		Report failure to US
		• Place rod control in manual
		• Refer to BwAR 1-14-D1
	BOP	• Verifies turbine load not lowering
	CREW	• Identify entry conditions for 1BwOA INST-2, "OPERATION WITH A FAILED INSTRUMENT CHANNEL"
	US	• Notify SM of plant status and procedure entry
		Request evaluation of Emergency Plan conditions
		• Implement 1BwOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL",
		Attachment D "TURBINE IMPULSE PRESSURE CHANNEL FAILURE" and direct operator
		 Direct RO to place rod control in manual
	BOP	Restore steam dumps
		• C-7 NOT lit
		• Place 1PK-507 in manual
		• Lower 1PK-507 demand to 0%
		 Place steam dump mode select switch to STM PRESS mode
		Place 1PK-507 in auto
	RO/	• Defeat 1PT-505
	BOP	• Place 1PS505Z, Turbine Impulse Pressure Defeat Switch, to DEFEAT 505
	US	Perform pre-job brief per HU-AA-1211 for bistable tripping
		• Complete 1BwOL 3.3.1, Attachment A, "INSTRUMENT CONDITION TRACKING LOG"

Scenario No	Scenario No: NRC 06-1 Event No. 3			
Event Description:		Turbine Impulse Pressure Channel 1PT-505 failed low		
Time I	Position	Applicant's Actions or Behavior		
E N B	Extra NSO/ BOP	 Locally trip bistable for 1PT-505 P13 input or P7/BOP verifies correct bistable operation PB505A C1-742 BS-1 		
τ	JS/RO	 Check if rod control can be placed in auto C5 NOT lit Tave/Tref stable and within 1°F. If control rods need to be adjusted to restore Tave – Tref within 1°F, perform the following: Conduct reactivity brief for restoring control rods per OP-AA-300-1004, Reactivity Change Determination Form Obtain SM concurrence to reactivity change Adjust Tave – Tref within 1°F using control rods Place Rod control in auto 		
E N B	Extra NSO/ 3OP	 Check status of AMS system/ BOP verifies correct bistable operation Operating Bypass switch in OFF Place Operating Bypass switch to TIP-1 Place Operating Bypass Input to TEST-TRIP 		
RB	RO/ BOP	 Check P13 interlock Turbine power > 10% - P13 NOT lit 		
U	JS	 Determine TS 3.3.1 conditions A and P are applicable. Contact SM to perform risk assessment, initiate IR, and contact maintenance to investigate/correct instrument failure and rod control malfunction 		
		The next event is to be inserted following the above actions by the US and Lead Examiner concurrence.		

Scenario	No: NRC	06-1 Event No. 4
Event Description: 1B Heater Drain Pump trip		
Time	Position	Applicant's Actions or Behavior
	CUE	Annunciator HD PUMP TRIP (1-17-D2)
		 HD Tank level rising HD Pump discharge volves epering
		• The Fully discharge valves opening
	BOP	Recognizes 1B HD pump tripped
		• Refer to BwAR 1-17-D2
		Reports failure to US
		• Recognizes one Heater Drain Pump running
	CREW	• Identify entry conditions for 1BwOA SEC-1, "SECONDARY PUMP TRIP"
	US	 Acknowledge 1B HD pump trip Contact SM to perform risk assessment, initiate IR, and contact maintenance to investigate/correct failure Implement 1BwOA SEC-1, "SECONDARY PUMP TRIP" Attachment C "HD PUMP TRIP" and direct operator actions of 1BwOA SEC-1 to establish the following conditions.
	BOP	 Recognizes standby HD pump NOT AVAILABLE Check HD pump status ONLY 1C HD pump running Initiate turbine load reduction to 780MW at 20 MW/min Depress LOAD RATE MW/MIN Enter desired load rate (20 MW/min) Depress REF Enter desired MW on REFERENCE DEMAND Window (780 MW) Depress GO pushbutton Verify turbine load lowering

Scenario	No: NRC	E 06-1 Event No. 4
Event Description:		1B Heater Drain Pump trip
Time	Position	Applicant's Actions or Behavior
	BOP	 Check HD Tank level Level > 72% and rising Maintain HD tank level Verify 1HD046A &B in AUTO Open 1CB113A-D Manually open 1HD117, HD tank overflow valve Lower turbine load as necessary to maintain HD tank level <72% Check 1HD117, HD tank overflow valve in auto and closed Lower turbine load as necessary to close 1HD117 Check 1C HD pump parameters 1C HD pump flow < 2950 KLB/HR Lower turbine load as necessary to restore 1C HD pump parameters
	US/RO	 Check PDMS operable Annunciator PDMS INOPERABLE not lit (1-10-E8) 1BwOS PDMS-1A not implemented Annunciator PDMS LIMIT EXCEEDED not lit (1-10-D7)
	RO	 Control ΔI near target Operate control rods in manual to restore ΔI near target Monitor RCS parameters If RCS pressure lowers < 2209 psig, notify US to enter TS 3.4.1, RCS DNB Limits If control rods < low – 2 rod insertion limit, notify US to enter TS 3.1.6, Control Bank Insertion Limits

Scenario	No: NRC	06-1 Event No. 4
Event Description:		1B Heater Drain Pump trip
Time	Position	Applicant's Actions or Behavior
	RO	 Initiate RCS boration Determine required boric acid volume (approximate band: 50 gal – 300 gal) Perform boration boundary calculation per 1BwGP 100-4T2 Determine from ReMa Determine desired boric acid flow rate Set 1FK-110 BA Flow Control to desired boration rate Set 1FY-0110 BA Blender Predet Counter to desired volume. Place MAKE-UP MODE CONT SWITCH to STOP position Place MODE SELECT SWITCH to BORATE position Place MAKE-UP MODE CONT SWITCH to START Verify proper operation of valves and BA transfer pump (1CV110B open, Boric Acid Transfer Pump running, 1CV110A throttles open, proper BA flow indicated on recorder). Turn on PZR backup heaters OR Batch addition of Boric Acid: Open 1CV110B Open 1CV110A Start the BA Transfer pump When desired amount of BA has been added, stop the BA Transfer Pump Close 1CV110B
	BOP	 Verify running CB pump recirc valves in auto 1CB113A-D on running pumps Dispatch operators to perform BwOP HD-2 for 1B HD pump Shutdown CD/CB pump (if started during procedure performance)

Scenario	No: NRC	06-1 Event No. 4
Event De	scription:	1B Heater Drain Pump trip
Time	Position	Applicant's Actions or Behavior
	US	 Notify chemistry to monitor secondary plant chemistry Notify SM to perform risk assessment Check reactor power change > 15% in one hour Notify chemistry to perform TS 3.4.16 sampling Notify rad protection to perform RETS 12.4.1.A sampling Refer to BwOP FW-26 to evaluate FW venturi fouling Determine TS 3.1.6, condition A entry required if control rods below low – 2 rod insertion limit
		The next event (SGTR) is to be inserted following the above actions by the US and Lead Examiner concurrence.

Scenario	No: NRC	06-1 Event No. 5, 6, & 7
Event Description:		1A SGTR (450 gpm), 1A CV pump trips/1B CV pump fails to auto start, Faulted ruptured 1A SG
Time	Position	Applicant's Actions or Behavior
	CUE	 Annunciator CHARGING LINE FLOW HIGH LOW (1-9-D3) RM-11 Rad Monitor ALERT/HI RAD Alarms 1PR08J SG Blowdown 1PR27J SJAE/GS 1AR 22/23B & 1AR22/23C, 1B & 1C Main steam line PZR pressure lowering in an uncontrolled manner Inability to maintain > 17% PZR level Level rise/FW flow drop noted on 1A S/G
		Examiners Note: Crew may elect to initially go to 1BwOA SEC-8, 'STEAM GENERATOR TUBE LEAK'. Either flowpath should result in the crew manually tripping the reactor. Actions for 1BwOA SEC-8 are in italics below:
	CREW	• Transitions to 1BwOA SEC-8 based on entry symptoms
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwOA SEC-1 and direct operator actions to establish the following conditions:
	RO	 Throttle 1CV121 and 1CV182 to attempt to maintain PZR level Check PZR level NOT stable or rising Establish 75 gpm letdown Recognize PZR level CANNOT be maintained > 17% Notify US for concurrence and initiate a manual reactor trip
	CREW	 Initiate a manual reactor trip and transition to 1BwEP-0 Initiate a manual SI
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwEP-0 and direct operator actions of 1BwEP-0

Scenario	No: NRC	Event No. 5 & 7
Event De	scription:	1A SGTR (450 gpm), Faulted ruptured 1A SG
Time	Position	Applicant's Actions or Behavior
	RO	 Perform immediate operator actions of 1BwEP-0: Verify reactor trip Rod bottom lights - ALL LIT Reactor trip & Bypass breakers - OPEN Neutron flux - DROPPING
	BOP	 Perform immediate operator actions of 1BwEP-0: Verify Turbine Trip All Turbine throttle valves - CLOSED All Turbine governor valves - CLOSED
	BOP	 Perform immediate operator actions of 1BwEP-0: Verify power to 4KV busses ESF Buses – BOTH ENERGIZED (141 & 142)
	CREW	 (If manual SI not previously performed) Recognize and respond to conditions requiring a Safety Injection in accordance with 1BwEP-0 "REACTOR TRIP OR SAFETY INJECTION", Step 4: PZR pressure cannot be maintained > 1829 psig PZR level cannot be maintained > 4% Manually actuate SI
	CREW	 Check SI Status SI First OUT annunciator - LIT SI ACTUATED Permissive Light - LIT SI Equipment – AUTOMATICALLY ACTUATED Either SI pumps - RUNNING Either CV pump to cold leg isolation valve OPEN – 1SI8801A/B
	BOP	 Verify FW isolated FW pumps - TRIPPED Isolation monitor lights - LIT FW pumps discharge valves - CLOSED (or going closed) 1FW002A-C

Scenario	No: NRC	Event No. 5 & 7	
Event Description:		1A SGTR (450 gpm), Faulted ruptured 1A SG	
Time Position Applicant's Actions or Behavior			
RO/ BOP [CT] E-0I• Verify ECCS pumps running • CV pumps - NONE RUNNING • Manually start the 1B CV pump prior to completion step 6 of 1BwEP-0.• Both RH pumps - RUNNING • Both SI pumps - RUNNING			
	BOP	 Verify RCFCs running in Accident Mode Group 2 RCFC Accident Mode lights - LIT Verify Phase A isolation Group 3 Cnmt Isol monitor lights - LIT Verify Cnmt Vent isolation Group 6 Cnmt Vent Isol monitor lights - LIT Verify AF system: AF pumps – BOTH RUNNING AF isolation valves – OPEN 1AF13A-H AF flow control valves - THROTTLED 1AF005A-H Verify CC pumps – BOTH RUNNING Verify SX pumps - 1A SX pump RUNNING 	
	RO/ BOP	 Check Main Steamline Isolation not required Check pressures SG pressures > 640 psig – continue on in 1BwEP-0 SG pressures < 640 psig - verify MSIVs and MSIV bypass valves closed CNMT pressure < 8.2 psig 	
	BOP	 Check CS not required CNMT pressure remained < 20 psig 	

Scenario	No: NRC	06-1 Event No. 5 & 7	
Event Description:		1A SGTR (450 gpm), Faulted ruptured 1A SG	
Time	Position	Applicant's Actions or Behavior	
	BOP/ RO	 Verify Total AF flow: AF flow > 500 gpm SG levels maintained between 10% and 50% Check status of S/G NR levels 1A S/G level rising in an uncontrolled manner Close 1AF013A & E 	
	RO/ BOP	 Verify ECCS valve alignment Group 2 Cold Leg Injection monitor lights required for injection – LIT Verify ECCS flow High Head SI flow >100 gpm (1FI-917) RCS pressure < 1700 psig SI pump discharge flow > 200 gpm 	
	RO	 Check at least ONE PZR PORV relief path available: PORV isolation valves – ENERGIZED PORV relief paths – PORVs in AUTO, PORV isolation valves OPEN 	
	BOP	 Verify Generator Trip OCB 1-8 and 7-8 open PMG output breaker open 	
	BOP	 Verify DGs running Both DGs RUNNING 1SX169A/B OPEN Dispatch operator locally to check operation 	

Scenario No: N	EVENT NO. 5 & 7		
Event Description	1A SGTR (450 gpm), Faulted ruptured 1A SG		
Time Positio	Applicant's Actions or Behavior		
	Examiners note: US and RO will likely continue in 1BwEP-0 while BOP is performing the next 3 ventilation steps:		
BOP	 Verify Control Room ventilation aligned for emergency operations: VC Rad Monitors – LESS THAN HIGH ALARM SETPOINT Operating VC train equipment - RUNNING 0B Supply fan 0B Return fan 0B M/U fan 0B Chilled water pump 0B Chiller Operating VC train dampers - ALIGNED M/U fan outlet damper – 0VC08Y NOT FULLY CLOSED 0B VC train M/U filter light - LIT 0VC09Y OPEN 0VC313Y CLOSED Operating VC train Charcoal Absorber aligned for train B 0VC05Y OPEN 0VC05Y OPEN 0VC05Y OPEN 0VC06Y OPEN 0VC06Y OPEN 0VC05Y OPEN 0VC06Y OPEN 0VC05Y OPEN 0VC05Y OPEN 0VC05Y OPEN 0VC06Y OPEN 0VC06Y OPEN 0VC06Y OPEN 0VC06Y OPEN 0VC06Y OPEN 		
BOP	 Verify Auxiliary Building ventilation aligned Two inaccessible filter plenums aligned Plenum A 0VA03CB - RUNNING 0VA023Y - OPEN 0VA436Y - CLOSED Plenum C 0VA03CF RUNNING 0VA072Y - OPEN Damper 0VA438Y - CLOSED 		

Scenario	No: NRC	Event No. 5 & 7
Event Description:		1A SGTR (450 gpm), Faulted ruptured 1A SG.
Time Position		Applicant's Actions or Behavior
	BOP	 Verify FHB ventilation aligned 0VA04CB - RUNNING 0VA055Y - OPEN 0VA062Y - OPEN 0VA435Y - CLOSED
	RO	 Check PZR sprays & PORVs Normal spray valves - CLOSED PORVs - CLOSED
	RO	 Maintain RCS temperature control Check RCPs - RUNNING Verify RCS average temperature stable at or trending to 557°F Throttle AF flow
	RO	 Check status of RCPs All RCPs - RUNNING Check RCP trip criteria RCS pressure > 1425 psig – continue on in 1BwEP-0 RCS pressure < 1425 psig Verify high head injection flow (1FI-917) > 100 gpm Trip all RCPs
	BOP/ RO	 Check if SG secondary pressure boundaries are intact: Check pressure in all SGs: 1A SG pressure decreasing in an uncontrolled manner
	CREW	Transition to 1BwEP-2, 'FAULTED STEAM GENERATOR ISOLATION'

Scenario	No: NRC	06-1 Event No. 5 & 7
Event De	scription:	1A SGTR (450 gpm), Faulted ruptured 1A SG
Time	Position	Applicant's Actions or Behavior
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Request STA evaluation of status trees Enter/Implement 1BwEP-2 and direct operator actions of 1BwEP-2 to establish the following conditions
	BOP	 Check MS isolation All MSIVs and bypass valves - CLOSED
	BOP	 Check if any SG secondary pressure boundary is intact 1B, 1C, & 1D SG pressures stable
	CREW	 Identify faulted SG 1A SG pressure decreasing in an uncontrolled manner 1A SG indicates steam flow with MSIVs and MSIV bypass valve closed
	RO/ BOP [CT] E-2A	 Isolate 1A Steam Generator prior to completing step 4 of 1BwEP-2. Close 1AF013A & D – may have already be closed at step 15 of 1BwEP-0 Top row of FW isolation monitor lights – lit 1MS018A closed 1SD002A & B closed 1SD005A closed
	BOP	 Monitor AF pump suction pressure Annunciator AF PUMP SX SUCTION VLVS ARMED (1-3-E7) – NOT LIT
	CREW	 Determine 1A S/G tubes are NOT intact: RM-11 or HMI Rad Monitor ALERT/HI RAD Alarms 1PR08J SG Blowdown 1PR27J SJAE/GS 1AR 22/23A 1A Main steam Line
	CREW	Transition to 1BwEP-3, 'STEAM GENERATOR TUBE RUPTURE'

Scenario	No: NRC	06-1 Event No. 5 & 7		
Event Description:		1A SGTR (450 gpm), Faulted ruptured 1A SG		
Time	Position	on Applicant's Actions or Behavior		
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Request STA evaluation of status trees Enter/Implement 1BwEP-3 and direct operator actions of 1BwEP-3 to establish the following conditions 		
	RO	 Check Status of RCPs: RCPs – NONE running – should have been tripped earlier when RCP trip criteria met 		
	BOP	 Identify ruptured SG 1A 1A Main steam line rad monitor ABNORMAL for plant conditions Isolate ruptured SG 1MS018A inoperable due to hydraulic leak Verify 1SD002A & B CLOSED Verify MSIVs and MSIV bypass valves for 1A SG Check PORVs on intact (1B, 1C, & 1D) SGs available for RCS cool down Check ruptured SG level - Narrow Range < 10% Do not feed 1A SG per caution prior to step Verify/close 1AF013A & E - should have already be closed in 1BwEP-0 OR 1BwEP-2 		
	CREW	Determine ruptured SG pressure < 320 psig Transition to 1BwCA-3.1, 'SGTR WITH LOSS OF REACTOR COOLANT, - SUBCOOLED RECOVERY DESIRED'		
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Request STA evaluation of status trees Enter/Implement 1BwCA-3.1 and direct operator actions of 1BwCA-3.1EP-3 to establish the following conditions 		

Scenario	No: NRC	06-1 Event No. 5 & 7			
Event Description:		1A SGTR (450 gpm), Faulted ruptured 1A SG			
Time	Position	Applicant's Actions or Behavior			
RO/BOP • Reset SI • Depress both SI reset pushbuttons • Verify SI actuated permissive light – NOT LIT • Verify auto SI blocked permissive light – LIT • Reset CNMT isolations • Reset phase A isolation • Check SAC – one running • Open 1IA065 and 1IA066 • Verify all AC buses energized • All 4 KV ESF buses energized • All 4 KV con-ESF buses energized • All 6.9 KV buses energized • Check is CS should be stopped • Check ruptured SG level • 1A SG NR level < 10% - do not feed 1A SG per caution prior to step		 Reset SI Depress both SI reset pushbuttons Verify SI actuated permissive light – NOT LIT Verify auto SI blocked permissive light – LIT Reset CNMT isolations Reset phase A isolation Check SAC – one running Open 1IA065 and 1IA066 Verify all AC buses energized All 4 KV ESF buses energized All 4 KV non-ESF buses energized All 6.9 KV buses energized Check is CS should be stopped CS pumps – NONE running Check ruptured SG level 1A SG NR level < 10% - do not feed 1A SG per caution prior to step Check if RH pumps should be stopped Stop both RH pumps and place in standby 			
	Note: At this point the scenario may be terminated				
	US	 US to determine EAL at conclusion of scenario: Site Area Emergency FS1 – Loss of 2 Fission Product Barriers Loss of Containment (1.g). Primary to secondary leakage > 10 gpm AND unisolable release of secondary coolant form affected SG to environment Loss of RCS (3.e). Entry into 1BwEP-3 AND unisolable secondary line break resulting in radioactive release to environment from affected SG 			

Simulation F	Facility	Braidwood		Scenario No.: NRC 06-2	Operating Test No.	2006301
Examiners:				Applicant:		SRO
				_		<u>RO</u>
				_		BOP
Initial Condi	tions:	IC-21				
Turnover: U is d	Unit 1 is a SOOS for emin is se	t 100% power, stor r an alignment an cheduled to be pla	teady state, equilibrind vibration problem taken on line for 30 problem	um xenon, MOL. . Expected back ninutes later in tl	. Online risk is green in service in one wee he shift.	. 1C CD/CB pump k. The CV Cation

Event	Malf. No.	Event	Event
No.		Type*	Description
Preload	IMF RH01B		RHR pump 1B trip
	IOR ZDI1CD05PC PTL		1C CD/CB pump OOS
	IOR ZDI1CD05PCB PTL		1C CD/CB AOP OOS
	IOR ZDI1CB113C CLS		1CB113C OOS
1	None	N-BOP, US	1PR11J filter change (Tech Spec)
2	None	R-RO, US	Power descension
		N-BOP	
3	IMF CV03	C-RO, US	Boric acid transfer pump trip
4	IMF ED11A	C-BOP, US	Loss of instrument bus 111 (Tech Spec)
5	IMF TH17B	C-RO, US	1B RCP degraded performance/locked rotor
6	IMF TH06B 540000	M-ALL	Large break RCS LOCA (1B RCS cold leg)
7	Preload	C-BOP	1B RH pump trip
8	Preload	C-BOP	1SI8811A fail to auto open
*(N)ormal,	(R)eactivity (I)nstru	ment, (C)om	ponent, (M)ajor Transient

SCENARIO OVERVIEW

Unit 1 is at 100% power, steady state, equilibrium xenon, MOL. Online risk is green. 1C CD/CB pump is OOS for an alignment and vibration problem. Expected back in service in one week. The CV Cation demin is scheduled to be placed on line for 30 minutes later in the shift

After completing shift turnover and relief, a Radiation Protection Technician will contact the main control room and request the crew shutdown 1PR11J sample pump to support daily filter replacement. The Unit Supervisor will enter Tech Spec 3.4.15, condition B. Approximately five minutes later, the RP Technician will request restart of the 1PR11J skid. 1PR11J will be restarted. Per operations department standing order 05-006, LCO 3.4.15 will not be exited until 1.5 hours after filter change completion and monitor is operating normally for plant conditions.

After changing the 1PR11J filter, Transmission Systems Operations will request Unit 1 lower power to 850 MW at 3 MW/min due to grid demand. The crew will commence a power reduction at 3 mw/min.

After a measurable change in power, the Unit 1 Boric Acid pump motor bearing will seize while the pump is running. MCC 133X3, cubicle A4 will open, causing a trip of the Unit 1 Boric Acid Transfer Pump. The crew will stop the load reduction and align the Unit 0 Boric Acid Transfer Pump to Unit 1 per BwOP AB-23, ALIGNMENT OF UNIT 0 BORIC ACID TRANSFER PUMP FOR UNIT ONE OR UNIT TWO DEMANDS.

After the Boric Acid Transfer Pump trip is addressed, Instrument Bus 111 will be damaged. The crew will implement 1BwOA ELEC-2, LOSS OF INSTRUMENT BUS, and determine Instrument Bus 111 cannot be reenergized and enter TS 3.8.9, condition A. The crew will perform 1BwOA INST-1, NUCLEAR INSTRUMENTATION MALFUNCTION, due to the loss of nuclear instrumentation.

After the instrument bus failure has been addressed, the 1B RCP rotor will degrade. LPMS alarms come in. Rotor degradation will cause RCS flow in the 1B loop to slowly lower until a reactor trip is required due to low RCS loop flow. RCP degradation will continue and the 1B RCP will dislodge components into the RCS, followed shortly by a large break LOCA in RCS loop 1B due to the dislodged RCP components. The crew will take actions per 1BwEP-0, RECTOR TRIP OR SAFETY INJECTION. Train A ESF equipment must be manually aligned due to the failure of Instrument Bus 111. 1B RH pump will trip when starting. The crew must manually start 1A RH pump to establish low head ECCS flow. The crew will transition to 1BwEP-1 after determining that the RCS is not intact. SR NI N32 will fail low due to the HELB inside containment. PANMs will be utilized to monitor SR level.

When the RWST level reaches the low-2 setpoint the crew will transition to 1BwEP ES-1.3, TRANSFER TO COLD LEG RECIRCULATION. Upon transition to 1BwEP ES-1.3, 1SI8811A will not automatically open due to the loss of Instrument Bus 111. The crew will align the 1A RH pump for cold leg recirculation per attachment A of 1BwEP ES-1.3 to ensure long term core cooling.

Completion criteria is performance of 1BwEP ES-1.3, step 8.

Critical Tasks

- Manually start 1A RH pump prior to completion of step 6 of 1BwEP-0. (ERG Critical Task number - E-0--H) (K/A number - 000011EA1.13 importance - 4.1/4.2)
- 2. Align 1A RH Pump suction to the containment sump prior to completion of step 3 of 1BwEP ES-1.3. (ERG Critical Task number ES-1.3--A) (K/A 011000EA1.11 Importance 4.2/4.2)

SIMULATOR SETUP GUIDE:

- Verify/perform TQ-BR-201-0113, BRAIDWOOD TRAINING DEPARTMENT SIMULATOR EXAMINATION SECURITY ACTIONS CHECKLIST.
- Establish the conditions of IC 21, 100% power, BOL, steady state, equilibrium xenon.
- Complete items on Simulator Ready for Training Checklist.
- Verify/remove any Equipment Status Tags and Danger Tags not applicable to the scenario.
- Place simulator in RUN (allow simulator to run during board walk down and turnover).
- Place 1C CD/CB pump and 1C CD/CB pump aux oil pump C/S's in PTL.
- Place 1CB113C C/S in closed.
- Place CD/CB Pump Standby Selector C/S to OFF.
- Run caep NRC 06-2 SETUP from disk and verify the following actuate:
 - IMF RH01B
 - IOR ZDI1CD05PC PTL
 - IOR ZDI1CD05PCB PTL
 - IOR ZDI1CB113C CLS
- Place danger tags on 1C CD/CB pump, 1C CD/CD pump aux oil pump, and 1CB113C C/S's.
- Update PARAGON to reflect 1C CD/CB pump OOS.
- Set Δ I Target Curve slopes to -0.015 (-1.5%)
- Provide students with turnover sheets, 1BwOS NR-1, and critical parameter sheet.

Event 1: 1PR11J filter change

As rad protection, contact the MCR by phone (X-2209) shortly after completion of shift turnover and request shutdown of 1PR11J to obtain sample (change of particulate and iodine filter cartridges). The rad protection procedure governing the filter change is RP-BR-911.

Three minutes after 1PR11J is shutdown, contact the MCR by phone and request startup of 1PR11J. If asked, report the bypass/normal switch on 1PS36J CASP panel is in bypass. Following start of 1PR11J, provide MCR feedback that 1PR11J is operating properly.

Acknowledge as SM LCO 3.4.15, condition B entry for 1PR11J.

Event 2: Power descension

As Transmission Systems Operations, contact the MCR by phone (TSO phone) and request Unit 1 lower power 200 MW at 3 MW/min due to grid demand.

Acknowledge as chemistry/rad protection requests for RCS samples (if required).

Acknowledge as Transmission Systems Operations initiation of ramp.

Event 3: Boric acid transfer pump trip

Note: Ensure a boration is in progress prior to inserting the next malfunction.

Insert IMF CV03

If dispatched as NLO, report Unit 1 AB pump breaker 133X3 is tripped and does not appear to be damaged. If breaker reclosure is requested, report breaker is closed. DO NOT DELETE MALFUNCTION. If pump restart is attempted, report the breaker is open.

If dispatched as NLO, report the Unit 1 AB pump bearing is hot and appears to be damaged.

If contacted as Unit 2, report Unit 0 AB pump is NOT supplying Unit 2 demands and is NOT electrically aligned to Unit 2.

If dispatched as NLO, align the Unit 0 AB pump to Unit 1 demands per BwOP AB-23 as follows:

- Verify w/MCR U-1 makeup c/s is in STOP (BwOP AB-23, step F.1.b)
- Verify w/MCR AB pump 1 + 0 c/s is in PTL (BwOP AB-23, step F.1.c)
- Insert IOR ZLO0AB03P ON
- Wait approximately two minutes then perform the following:
 - Delete malfunction **DMF CV03**
- Report Unit 0 AB pump aligned for Unit 1 demands (BwOP AB-23 is complete up to step F.1.k)

As SM, acknowledge the failure and requests for on line risk assessment, maintenance support, and IR initiation.

Event 4: Loss of instrument bus 111

Insert IMF ED11A for loss of instrument bus 111.

When dispatched as NLO to instrument inverter 111, wait two minutes and report inverter appears normal, inverter output volts are 121 and amps at 0, and inverter output breaker open.

When dispatched as NSO to instrument bus 111, wait one minute and report instrument bus 111 has signs of arcing on cabinet. (X-2209)

When dispatched as NLO to fail air 1AF005A-D, wait approximately 5 minutes and perform the following:

- Perform first check at 1AF005A-D (364' P-10 Aux Bdg)
- IMF FW45A 100
- IMF FW45B 100
- IMF FW45C 100
- IMF FW45D 100

If lead examiner desires the N41 bistables tripped, participate in brief and perform the following:

- As assist NSO contact Unit 1 (X-2209)
- Insert the following:
 - MRF RP20 OPEN
 - MRF RX013 TRIP
 - MRF RX135 TRIP
 - MRF RP20 CLOSE

As SM, acknowledge the failure, LCO 3.3.1 condition A, D, & E entry and LCO 3.8.9 condition B entry, and requests for on line risk assessment (**COLOR**), maintenance support, and IR initiation.

AT THE CONCLUSION OF THE SCENARIO, ENSURE THE FOLLOWING COMPUTER POINTS ARE TAKEN OUT OF TEST AND RETURNED TO SCAN: N0041, N0042, U1144, N0049A

Events 5: 1B RCP degraded performance/locked rotor

Run caep NRC 06-2 EVENTS 5_6 from disk and verify the following actuate:

- IMF TH17B
- IMF PN1760 ON
- TRGSET 1 "ZLO52BRKA(2) = = 1"
- IMF TH16B (1 0)
- IMF TH06B (1 10) 540000 10

If dispatched as NSO to LPMS panel 1PA44J, report LPMS high alarms on 1VE-LM008, cold side SG B channel head (first out) and 1VE-LM003, reactor bottom H-13. Report metallic impact noises heard on both channels. Report tapes will be allowed to run per BwOP LM-6.

Event 6: Large break LOCA (1A RCS cold leg)

Acknowledge as SM procedure changes, E Plan evaluations, and STA request.

After STA requested, as STA report CSF status:

If dispatched as NLO to throttle/close 1AF005A-D, perform the following

- Modify malfunction FW45A (severity as directed by MCR request)
- Modify malfunction FW45B (severity as directed by MCR request)
- Modify malfunction FW45C (severity as directed by MCR request)
- Modify malfunction FW45D (severity as directed by MCR request)

Event 7: 1B RH pump trip

If dispatched as NLO to investigate 1B RH pump, report ground overcurrent flag at breaker cubicle.

Event 8: 1SI8811A fail to auto open

Acknowledge as SM procedure changes, E Plan evaluations, and STA request.

After STA requested, as STA report CSF status:

AT THE CONCLUSION OF THE SCENARIO, ENSURE THE FOLLOWING COMPUTER POINTS ARE TAKEN OUT OF TEST AND RETURNED TO SCAN: N0041, N0042, U1144, N0049A

Scenario	No: NRC	06-2 Event No. 1
Event Description:		1PR11J filter change
Time Position		Applicant's Actions or Behavior
	CUE	Request from RP to shutdown 1PR11J for filter change
	BOP	 Refer to BwOP AR/PR-19, ROUTINE SKID MOUNTED PROCESS RADIATION MONITOR OPERATIONS Notify US of 1PR11J filter change request Secure 1PR11J Select Grid 2 on RM-11 Select 1PR11J Depress flow button to secure 1PR11J.
	US	 Recognize entry conditions for TS LCO 3.4.15, condition B. Inform SM of TS 3.4.15 entry
	CUE	• Request from RP to startup 1PR11J following filter change
	BOP	 Refer to BwOP AR/PR-19 Start 1PR11J Select Grid 2 on RM-11 Select 1PR11J Depress flow button to start 1PR11J Verify flow indicated on 1PR11J Notify US of completion of 1PR11J filter change
		NOTE: LCO 3.4.15 should NOT be exited following completion of 1PR11J filter change. Per operations department standing order 05-006, LCO 3.4.15 will not be exited until 1.5 hours after filter change completion and monitor is operating normally for plant conditions.

Scenario	No: NRC	E 06-2 Event No. 2
Event Description:		200 MW power reduction at 3 Mw/min
Time Position		Applicant's Actions or Behavior
	CUE	• Call from Transmission System Operations to lower power 200 MW at 3 Mw/min.
	US	 Acknowledge request to lower power 200 MW at 3 Mw/min. Implement actions of 1BwGP 100-4
	US	 Direct load reduction of 200 MW at 3 Mw/min. Initiate load swing instruction sheet, 1BwGP 100-4T2 Perform pre-job brief per HU-AA-1211 "PRE-JOB, HEIGHTENED LEVEL OF AWARENESS, INFREQUENT PLANT ACTIVITY, AND POST JOB BRIEFINGS" for load ramp.
	CREW	Review applicable Precautions, Limitations and Actions of 1BwGP 100-4
	RO	 Verify rod position and boron concentration Initiate boration, if required. (BwOP CV-6) (approximate band: 500 gal – 750 gal) Determine required boric acid volume. Perform boration boundary calculation per 1BwGP 100-4T2 Refer to operator aid for ramp Determine desired boric acid flow rate Set 1FK-110 BA Flow Control to desired boration rate Set 1FY-0110 BA Blender Predet Counter to desired volume. Place MAKE-UP MODE CONT SWITCH to STOP position Place MAKE-UP MODE CONT SWITCH to START Verify proper operation of valves and BA transfer pump (1CV110B open, Boric Acid Transfer Pump running, 1CV110A throttles open, proper BA flow indicated on recorder). Turn on PZR backup heaters
		OR

Sechario No. INK	, 00-2 Event No. 2			
Event Description:	200 MW power reduction at 3 Mw/min			
Time Position	Applicant's Actions or Behavior			
RO	 Batch addition of Boric Acid: Open 1CV110B Open 1CV110A Start the BA Transfer pump When desired amount of BA has been added, stop the BA Transfer Pump Close 1CV110A Close 1CV110B 			
BOP	 Initiate turbine load reduction: Depress LOAD RATE MW/MIN Enter desired load rate (3 MW/min) Depress REF Enter desired MW on REFERENCE DEMAND Window (850 MW) When ready to begin load reduction, depress GO Verify load reduction occurring 			
RO/ BOP	 Monitor reactor power and load reduction Monitor NI's, Tave, ΔI, Pzr press/level Monitor MWe, Turb loading, EHC 			
RO	 Perform Boration: Monitor VCT Level and pressure Verify RCS boron concentration increasing Monitor BA blender counter Verify boration stops at preset value Verify boration auto stops at preset value. Return Reactor Makeup System to automatic at current boron concentration. 			

Scenario	Scenario No: NRC 06-2 Event No. 3		
Event De	scription:	Boric acid transfer pump trip	
Time	Position	Applicant's Actions or Behavior	
	CUE	 Annunciator BA XFER PUMP TRIP (1-9-A4) Trip/yellow disagreement light on Boric Acid Transfer pump 1 + 0 C/S 	
	RO	 Identify/report trip of Unit 1 Boric Acid Transfer pump Refer to BwAR 1-9-A4 Dispatch operator to Unit 1 Boric Acid Transfer pump and breaker 	
	US	 Notify SM of Unit 1 Boric Acid Transfer pump trip. Direct operators to align the Unit 0 Boric Acid Transfer pump for Unit 1 demand Direct BOP to stop load ramp 	
	ВОР	 Stop turbine load ramp Depress DEHC HOLD pushbutton Assist US & RO Refer to BwARs Dispatch operators Refer to BwOP AB-23 	
	RO	 Determine Unit 1 Boric Acid Transfer pump bearing is damaged Report from NLO Align 0AB03P, Boric Acid Transfer pump 0 for Unit 1 demands per BwOP AB-23 Verify 0AB03P NOT supplying Unit 2 boric acid demands Verify 0AB03P NOT connected to Unit 2 power supply MAKE-UP MODE CONT SWITCH to STOP Place Boric Acid Transfer pump 1 + 0 C/S in PULL OUT Dispatch operator to align 0AB03P to Unit 1 per BwOP AB-23 Verify 1CV110A in AUTO Place Boric Acid Transfer pump 1 + 0 C/S in AFTER TRIP Return Unit 1 RMCS to AUTO 	
	US	Contact SM to perform risk assessment, initiate IR, and contact maintenance to investigate/correct component.	
		NOTE: After the actions for boric acid pump trip are complete and with lead examiners concurrence, enter next event	

Scenario	No: NRC	06-2 Event No. 4
Event De	scription:	Loss of instrument bus 111
Time	Position	Applicant's Actions or Behavior
	CUE	 Annunciator BUS 111 INVERTER TROUBLE (1-4-A5) Annunciator PROCESS I & C CAB PWR SUP FAILURE (1-4-A3) Annunciator SOLID STATE PROT CAB GENERAL WARNING (1-4-B3) Annunciator SEQUENCING CAB PWR FAILURE (1-4-C2) Annunciator RCP BUS UNDERVOLTAGE (1-13-A2) Loss of control and instrument power to: N31 Source Range Instrument N35 Intermediate Range Instrument N41 Power Range Instrument
	RO/ BOP	 Determine instrument bus 111 deenergized Reference BwARs
	CREW	 Identify entry conditions for 1BwOA ELEC-2, "LOSS OF INSTRUMENT BUS" Dispatch operators to investigate status of inverter and instrument bus
		Examiners note: Loss of instrument bus 111 will require the crew to implement 1BwOA INST-1, NUCLEAR INSTRUMENTATION MALFUNCTION. See page 12 for 1BwOA INST-1 actions.
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwOA ELEC-2 "LOSS OF INSTRUMENT BUS" and direct operator actions of 1BwOA ELEC-2 to establish the following conditions. Direct BOP/RO to stop load ramp/boration
	RO/ BOP	 Stop turbine load ramp Depress DEHC HOLD pushbutton Check control channels PZR pressure/level T_{AVE}/Delta T P_{IMP} SG level, steam flow & feed flow

Comments: _____

Scenario No: NRC 06-2 Event No. 4		
Event Description: Loss of instrument bus 111		
Time	Position	Applicant's Actions or Behavior
	BOP	 Dispatch operator to locally energize affected instrument bus Determine Instrument Bus 111 DAMAGED Determine Instrument Bus 111 DEAD Do NOT attempt to energize Instrument Bus 111 from the CVT
	BOP	Verify RH train 1A NOT operating in shutdown cooling mode
	CREW	• Dispatch operator to locally fail open 1AF005A – D
	US	 Refer to Table A for expected equipment failures Identify entry conditions for 1BwOA INST-1, "NUCLEAR INSTRUMENTATION MALFUNCTION" Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwOA ELEC-2 "LOSS OF INSTRUMENT BUS" and direct operator actions of 1BwOA ELEC-2 to establish the following conditions.
	RO	 Place rod control in manual Check for PR flux high rod stop
	BOP	Place rod stop bypass switch for N41 in bypass
	RO	 Check Tave – Tref stable and within 1°F Restore Tave – Tref within 1°F using control rods, turbine load, or RCS boron adjustment
	RO/ BOP	Check SG levels normal and stable
	BOP	 Bypass associated functions for PR N41 Upper current comparator Lower current comparator Power mismatch Rod stop Channel current comparator

Scenario	No: NRC	206-2 Event No. 5
Event Description: 1B RCP degraded performance/locked rotor		
Time	Position	Applicant's Actions or Behavior
	RO/ BOP	 Place computer points in test N0041 N0042 U1144 Place computer point N0049A in removed from scan
	RO/ BOP	 Trip bistables for N41 by removing PR N41 control power fuses. NC41P NC41R NC41U
	US	 Perform pre-job brief per HU-AA-1211 for bistable tripping Complete 1BwOL 3.3.1, Attachment A, "INSTRUMENT CONDITION TRACKING LOG"
	Extra NSO/ RO	 Locally trip bistables for 1D Loop by placing in TEST/ RO verifies correct bistable operation TB441C C4-124 BS-3 TB441D C4-124 BS-4
	RO	 Select channel 1B, 1C or 1D to ΔT recorder Check if rod control can be placed in automatic C5 NOT lit Tave – Tref stable within 1°F Place rod bank select switch in auto
	US	 Determine TS 3.3.1 conditions A, D, and E are applicable Determine Tech Spec 3.8.9, condition B applies Contact SM to perform risk assessment, initiate IR, and contact maintenance to investigate/correct component failure
		The next event is to be inserted following the above actions by the US and Lead Examiner concurrence

Scenario	Scenario No: NRC 06-2 Event No. 5		
Event De	scription:	1B RCP degraded performance/locked rotor	
Time	Position	Applicant's Actions or Behavior	
	CUE	 Annunciator LOOSE PARTS MONITORING SYSTEM TROUBLE (1-13-E9) RCP 1B amps rising RCS loop 1B flow lowering 	
	RO	 Refer to BwAR 1-9-A4 Dispatch operator to 1PA44J Identify/report degraded performance of 1B RCP 	
	US	 Notify SM of plant status Direct operator to monitor 1B RCP performance Determine 1B RCP degraded flow requires reactor trip 	
	CREW	• Initiate a manual reactor trip and transition to 1BwEP-0	
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwEP-0 and direct operator actions of 1BwEP-0 	
	RO	 Perform immediate operator actions of 1BwEP-0: Verify reactor trip Rod bottom lights - ALL LIT Reactor trip & Bypass breakers - OPEN Neutron flux - DROPPING 	
	BOP	 Perform immediate operator actions of 1BwEP-0: Verify Turbine Trip All Turbine throttle valves - CLOSED All Turbine governor valves - CLOSED 	
	BOP	 Perform immediate operator actions of 1BwEP-0: Verify power to 4KV busses ESF Buses – BOTH ENERGIZED (141 & 142) 	

Scenario No: NRC 06-2 Event No. 6 & 7		
Event Description:		Large break RCS LOCA/1B RH pump trip
Time	Position	Applicant's Actions or Behavior
	CREW	 (If manual SI not previously performed) Recognize and respond to conditions requiring a Safety Injection in accordance with 1BwEP-0 "REACTOR TRIP OR SAFETY INJECTION", Step 4: PZR pressure cannot be maintained > 1829 psig PZR level cannot be maintained > 4% Manually actuate SI
	CREW	 Check SI Status SI First OUT annunciator - LIT SI ACTUATED Permissive Light - LIT SI Equipment – AUTOMATICALLY ACTUATED Either SI pumps - RUNNING Either CV pump to cold leg isolation valve OPEN – 1SI8801A/B
	RO	 Determine RCP trip required CNMT phase B actuated RCS pressure < 1425 psig High head SI flow (1FI-917) > 100 gpm Trip ALL RCPs
	BOP	 Verify FW isolated FW pumps - TRIPPED Isolation monitor lights - LIT FW pumps discharge valves - CLOSED (or going closed) 1FW002A-C
	RO/ BOP [CT] E-0H	 Verify ECCS pumps running Both CV pumps – RUNNING NEITHER RH pump – RUNNING Manually start 1A RH pump prior to completion of step 6 of 1BwEP-0. Place 1B RH pump in pull out 1B SI pump – RUNNING Manually start 1A SI pump

Scenario No: NRC	06-2 Event No. 6 & 7
Event Description:	Large break RCS LOCA/1B RH pump trip
Time Position	Applicant's Actions or Behavior
BOP	 Verify RCFCs running in Accident Mode 1B & 1D RCFC Accident Mode lights - LIT 1A & 1C RCFC Accident Mode lights - NOT LIT Stop 1A & 1C high speed RCFCs Close 1SX112A and 1SX114A Verify/open 1SX147A Verify/open 1SX016A and 1SX027A Start 1A & 1C low speed RCFCs
RO/ BOP	 Verify Phase A isolation Group 3 Cnmt Isol monitor lights – NOT ALL LIT Manually actuate Cnmt isol phase A Manually close Cnmt isol phase A valves 1CV8100 & 1CV8152 1W0006A, 1W0020A, & 1W0056B 1PR001A & 1PR066 1PS228A & 1PS228B 1IA065 Verify Cnmt Vent isolation Group 6 Cnmt Vent Isol monitor lights – ALL LIT Verify AF system: AF pumps – 1B AF pump RUNNING Manually start 1A AF pump AF isolation valves – OPEN 1AF13A-H AF flow control valves – THROTTLED 1AF005A-D failed open – dispatch operator to locally control 1AF005A-D 1AF005E-H throttled Verify SX pumps - BOTH RUNNING Main Steamline Isolation - required All S/G pressure > 640 psig CNMT pressure > 8.2 psig

Scenario No:NRC 06-2Event No.6 & 7		
Event Description:		Large break RCS LOCA/1B RH pump trip
Time	Position	Applicant's Actions or Behavior
	BOP	 Check if CS is required CNMT pressure has risen > 20 psig (CNMT pressure recorder in not available) Stop ALL RCPs Group 6 CS monitor lights – NOT ALL LIT Manually actuate CS and phase B Group 6 CS monitor lights – NOT ALL LIT Go to 1BwEP-0, Attachment B, step 1 1CS001A/B – BOTH OPEN 1CS007B – OPEN Manually open 1CS007A 1CS019B – OPEN Place 1A CS pump test switch in TEST Manually open 1CS019A 1CS010A/B - BOTH OPEN 1B CS pump running Return to 1BwEP-0, step 14.d Group 6 phase B lights – NOT ALL LIT Manually close 1CC9413A, 1CC9416, & 1CC9438 CS eductor suction flow - > 15 gpm on 1FI-CS014 CS eductor additive flow - > 5 gpm on 1FI-CS016
	BOP/ RO	 Verify Total AF flow: AF flow > 500 gpm SG levels maintained between 10% (31%) and 50% S/G NR levels – NOT rising in an uncontrolled manner
	RO	 Verify ECCS valve alignment Determine Group 2 Cold Leg Injection monitor lights required for injection - NOT lit Manually open 1CV112D 1SI8801A Manually close 1CV112B 1CV8106

Comments: _

Scenario	No: NRC	06-2 Event No. 6 & 7
Event Description:		Large break RCS LOCA/1B RH pump trip
Time	Position	Applicant's Actions or Behavior
	RO/ BOP	 Verify ECCS flow High Head SI flow >100 gpm (1FI-917) RCS pressure < 1700 psig SI pumps discharge flow > 200 gpm RCS pressure < 325 psig 1A RH pump discharge flow > 1000 gpm
	RO	 Check at least ONE PZR PORV relief path available: PORV isol valves – BOTH ENERGIZED PORV relief path – BOTH PORVs in AUTO, 1RY8000A & B - OPEN
	BOP	 Verify Generator Trip OCB 1-8 and 7-8 open PMG output breaker open
	BOP	 Verify DGs running 1B DG RUNNING Manually start 1A DG 1SX169A/B OPEN Dispatch operator locally to check operation
		Examiners note: US and RO will likely continue in 1BwEP-0 while BOP is performing the next 3 ventilation steps:

Scenario No: NRC 06-2 Event No. 6 & 7		
Event Description:		Large break RCS LOCA/1B RH pump trip
Time	Position	Applicant's Actions or Behavior
	BOP	 Verify Control Room ventilation aligned for emergency operations: VC Rad Monitors – LESS THAN HIGH ALARM SETPOINT Operating VC train equipment - RUNNING 0B Supply fan 0B Return fan 0B M/U fan 0B Chilled water pump 0B Chiller Operating VC train dampers - ALIGNED M/U fan outlet damper – 0VC08Y NOT FULLY CLOSED 0B VC train M/U filter light - LIT 0VC09Y - OPEN 0VC313Y - CLOSED Operating VC train Charcoal Absorber aligned for train B 0VC05Y - OPEN 0VC06Y - OPEN
	BOP	 Verify Auxiliary Building ventilation aligned Two inaccessible filter plenums aligned Plenum A 0VA03CB - RUNNING 0VA023Y - OPEN 0VA436Y - CLOSED Plenum C 0VA03CE RUNNING 0VA067Y - OPEN Damper 0VA052Y - CLOSED
	BOP	 Verify FHB ventilation aligned 0VA04CB - RUNNING 0VA055Y - OPEN 0VA062Y - OPEN 0VA435Y - CLOSED

Comments: _

Scenario	Scenario No: NRC 06-2 Event No. 6 & 7		
Event De	scription:	Large break RCS LOCA/1B RH pump trip	
Time	Position	Applicant's Actions or Behavior	
	RO	 Check PZR sprays & PORVs Normal spray valves 1RY455B and 1RY455C - CLOSED PORVs - CLOSED 	
	RO	 Maintain RCS temperature control Check RCP's – NONE RUNNING Verify RCS average temperature stable at or trending to 557°F MSIVs closed 	
	RO	 Check status of RCP's All RCP's – NONE RUNNING 	
	BOP/ RO	 Check if SG secondary pressure boundaries are intact: Check pressure in all SGs: None decreasing in an uncontrolled manner None completely depressurized 	
	BOP/ RO	 Check S/G tubes are intact: 1PR08J SG Blowdown 1PR27J SJAE/GS 1AR 22/23A-D Main steam Lines 	
	CREW	 Determine RCS in NOT intact CNMT area rad monitors > alert alarm setpoint CNMT pressure > 3.4 psig (1PI-CS934-937) CNMT floor water level > 5 inches (1LI-PC006/007) 	
	CREW	Transition to 1BwEP-1, 'LOSS OF REACTOR OR SECONDARY COOLANT'	
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Request STA evaluation of status trees Enter/Implement 1BwEP-1 and direct operator actions of 1BwEP-1 to establish the following conditions: 	
		Examiners note: When RWST level reaches the low-2 setpoint, the crew will transition to	

Scenario	No: NRC	Event No. 6 & 7
Event De	scription:	Large break RCS LOCA/1B RH pump trip
Time	Position	Applicant's Actions or Behavior
		1BwEP ES-1.3 to align ECCS for cold leg recirc. 1BwEP ES-1.3 actions begin on page 22.
	RO	Check Status of RCPs:
		RCPs – NONE RUNNING
	RO/	Check if SG secondary pressure boundaries are intact:
	BOP	• Check pressure in all SGs:
		None decreasing in an uncontrolled manner
		None completely depressurized
		Check intact SG levels
		• SG levels maintained between 10% (31%) and 50%
		• SG NR levels – NOT rising in an uncontrolled manner
		• Check secondary radiation normal – RM-11 or HMI:
		1PR08J SG Blowdown
		• 1PR27J SJAE/GS
		1AR 22/23A-D Main steam lines
	RO	• Check at least ONE PZR PORV relief path available:
		 PORV isol valves – BOTH ENERGIZED
		 PORV relief path – BOTH PORVs in AUTO, 1RY8000A & B - OPEN
	CREW	Check if ECCS flow should be reduced
		• RCS subcooling – NOT acceptable
		Check if CS should be stopped
		• 1B CS pump – RUNNING
		• Reset CS
		• Spray add tank lo-2 level light – NOT LIT
		CS termination requirements
		• CNMT pressure < 15 psig
		• Spray operating time < 2 hours
		Check if RH pumps should be stopped
		• Reset SI
		RH pumps suction aligned to RWST
		• 1SI8812A & B – OPEN
		• RCS pressure < 325 psig – go to 1BwEP-1, step 10.

Scenario N	o: NRC	06-2 Event No. 8
Event Description:		1SI8811A fail to auto open.
Time	Position	Applicant's Actions or Behavior
	CUE	 Annunciator RWST LEVEL LO-2 (1-6-B7) RWST level <46%.
	CREW	Transition to 1BwEP ES-1.3, 'TRANSFER TO COLD LEG RECIRCULATION'
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Request STA monitor status trees – BwFRs should not be implemented Enter/Implement 1BwEP ES-1.3 and direct operator actions of 1BwEP ES-1.3 to establish the following conditions:
	RO/ BOP	 Establish CC flow to RH HXs 1CC9473A & B – OPEN CC pumps – TWO RUNNING Open 1CC 9412A & B CC to RH HX flows – 1FI-0689 & 1FI-0688 > 5000 gpm Check CNMT floor level – 1LI-PC006 & 1LI-PC007 > 8 inches (13 inches) Align RH pumps suction to CNMT sumps Place SVAG valve C/Ss to close Check RH pumps 1A RH pump – RUNNING 1B RH pump cannot be started Check CNMT sump isolation valves 1SI8811B – OPEN 1SI8811A – CLOSED – go to attachment A, step 1.

Scenario	No: NRC	E 06-2 Event No. 8
Event Description:		1SI8811A fail to auto open
Time	Position	Applicant's Actions or Behavior
	BOP/ RO [CT] ES-1.3 A	 Check if 1A RH pump needs to be aligned to CNMT sump 1SI8811A – CLOSED Check train A recirc flowpath from CNMT sump available 1A RH pump – RUNNING 1SI8811A – energized Manually align 1A RH Pump suction to the containment sump prior to completion of step 3 of 1BwEP ES-1.3. Place 1A RH pump in PULL OUT Close 1SI8812A Place 1A CS pump in PULL OUT Close 1SI8811A Start 1A RH pump Open 1SI8811A Start 1A RH pump (due to loss of Instrument Bus 111) Manually actuate CS Check if 1B RH pump needs to be aligned to CNMT sump 1SI8811B – OPEN Check at least one CNMT sump recirc flowpath established 1A RH pump – NOT RUNNING Return to 1BwEP ES-1.3, step 3.d

Scenario	No: NRC	206-2 Event No. 8
Event Description: 1		1SI8811A fail to auto open
Time	Position	Applicant's Actions or Behavior
	RO/ BOP	 Verify/close 1SI8812A & B SI pumps – BOTH RUNNING Align SI and CV pumps for cold leg recirc Verify/close 1CV8110, 1CV8111, 1CV8114, & 1CV8116 Close 1SI8814, 1SI8813, & 1SI8920 Close 1RH8716A & B Open 1SI8807A, 1SI8807B, & 1SI8924 1A RH pump – RUNNING Open 1CV8804A 1B RH pump – NOT RUNNING
	RO/ BOP	 CV pumps – BOTH RUNNING SI pumps – BOTH RUNNING Reset SI if necessary Isolate RWST from SI and CV pumps 1CV8804A – OPEN Close 1SI8806 Close 1CV112 D & E Dispatch operator to deenergize 1CV112D & E Note: At this point the scenario may be terminated
	US	 US to determine EAL at conclusion of scenario: Alert FA1 Potential loss of RCS (3.d). Unisolable RCS leak > capacity of ONE centrifugal charging pump in the normal charging alignment.

Comments: ____

Simulation	n Facility <u>Braidwood</u>		Scenario No.: Operating Test No.: 2006301
Examiner	s:		Applicant: <u>SRO</u>
			<u>RO</u>
			BOP
Initial Co	nditions: IC-18		
Turnover	Unit 1 is at 76% power stea	dy state equili	brium venon MOL Online risk is green 1C RCFC is OOS
Turnover.	for the past 20 hours for run	time meter rep	lacement. LCOAR 3.6.6, Condition C has been initiated.
	Expected back in service in	12 hours. 1B C	GC pump is OOS for motor bearing replacement for past 12
	hours. Expected back in ser	vice in 5 days. Surveillance (B	OBWOSR 3.7.10.1-2, Unit Common Control Room Train) is scheduled for later in the shift
	ventilation (ve) i huation s	Sui veinanee (B	fram) is selectice for face in the shift.
Event	Malf. No.	Event	Event
No.		Type*	Description
Preload	IOR ZDI1VP01CCL PIL		IC REFE OUS
	ZDI1GC01PB PTL		1B GC pump OOS
	IMF RP02A		Reactor trip breaker A fails to open
	IMF RP02B		Reactor trip breaker B fails to open
	IMF FW48A		1A AF pump fails to start
	IMF FW 13C 25 0		IFW009C fails 25% open
	IOR ZLO1FW5302 ON		11 w 550 rans partially open
	IOR ZLO1SLFW530 OFF		
	IOR ZLOMLB6315 OFF		
	IOR ZDI1FW002B OPEN		1FW002B failed open
1	None	R-RO, US	Power ascension
		N-BOP	
2	IOR ZDI1AF01PB PTL	N-BOP, US	1B AF pump clearance order (Tech Spec)
	IOR ZLOAUXOIL OFF		
	IOR ZLO1AF01PBC OFF		
3	IMF RX 21A 1700 30	I-RO, US	Pressurizer pressure channel 1PT-455 fails low (Tech Spec)
4	IMF RX04E 0 120	I-BOP, US	Feed flow channel 1FT-530 fails low
5	IOR ZDI1FW009C CLS	M-ALL	ATWS
6	IMF RD09 0	C-RO	Auto rod speed failed
7	IMF FW19C 3.5 30	M-ALL	1C FW line break inside containment
8	Preload	C-BOP	1A AF pump fails to auto start
9	Preload	C-BOP	FW isolation failure
*())		(C)	Learner Abrier Transient

SCENARIO OVERVIEW

Unit 1 is at 76% power, steady state, equilibrium xenon, MOL. Online risk is green. 1C RCFC is OOS for the past 20 hours for run time meter replacement. LCOAR 3.6.6, Condition C has been initiated. Expected back in service in 12 hours. 1B GC pump is OOS for motor bearing replacement for past 12 hours. Expected back in service in 5 days. 0BwOSR 3.7.10.1-2, Unit Common Control Room Ventilation (VC) Filtration Surveillance (B Train) is scheduled for later in the shift.

After completing shift turnover and relief, Transmission System Operations (TSO) will request Unit 1 raise power to full power at 0.6 MW/min. The crew will commence a power increase at 0.6 mw/min.

After a measurable change in power, the Work Execution Supervisor will bring a clearance order for the 1B AF pump to the Main Control Room. The crew will execute the MCR portion of the clearance order and enter Tech Spec 3.7.5, Condition A for the 1B AF pump. The 1B AF pump will remain unavailable for the remainder of the scenario.

After performing the clearance order for the 1B AF pump, the controlling PZR pressure channel 1PT-455 will fail low, the RO will identify the failure and take manual control of the PZR pressure master controller and restore pressurizer pressure. The US will enter 1BwOA INST 2, OPERATION WITH A FAILED INSTRUMENT CHANNEL-Attachment B. Tech Specs 3.3.1 conditions A, E, and K, 3.3.2 conditions A and D, and 3.3.4 condition A will be entered.

After the pressurizer pressure channel is addressed, Feed Flow channel 1FT-530A will fail low, resulting in indications of increased steam flow and opening of 1FW530, 1C S/G Feed Reg Valve to attempt to match feed flow with steam flow. The BOP will diagnose the failure and take manual control of 1FW530 to restore 1C SG level. The US will enter 1BwOA INST-2, OPERATION WITH A FAILED INSTRUMENT CHANNEL-Attachment G.

After the Feed Flow channel has been addressed, a hydraulic leak will develop on 1FW009C, 1C SG FW Isolation Valve. The leak will continue and 1FW009C will fail to mid position and bind. A reactor trip will be required due to lowering 1C SG level. When a reactor trip signal is generated, the reactor will not trip. The resultant transient will cause a feed water line to break inside containment downstream of 1FW009C. When FW isolation actuates, 1FW530, 1C SG Feed Reg Valve, will not fully close and 1FW002B, 1B FW Pump Discharge Valve, will remain open, resulting in FW flow to the 1C SG when SG pressure lowers below the Condensate Booster pumps shutoff head. The 1B AF pump will not automatically start. The crew will take actions per 1BwFR-S.1, RESPONSE TO NUCLEAR GENERATION/ATWS. Automatic rod control will fail, and the RO will manually insert the control rods to add negative reactivity. The crew will manually start the 1A AF pump. The crew will close 1FW006C to isolate feedwater flow to the 1C SG. After completing actions of 1BwFR-S.1, the crew will transition to 1BwEP-0, REACTOR TRIP OR SAFETY INJECTION.

Completion criteria is completion of step 27 of 1BwEP-0

Critical Tasks

- Insert negative reactivity into the core by initiating RCCA insertion at greater than or equal to 48 steps per minute prior to completion of step 1 of 1BwFR-S.1.
 (ERG Critical Task number - FR-S.1--C) (K/A number - 000029EA1.09 importance - 4.0/3.6)
- 2. Manually start the 1A AF pump prior to completion of step 3 of 1BwFR-S.1 (ERG Critical Task number FR-S.1--B) (K/A number 000029EA1.15 importance 4.1/3.9)
- 3. Isolate the 1C Steam Generator prior to completion of step 14 of 1BwFR-S.1. (ERG Critical Task number - E-2--A) (K/A number - 000040AA1.10 importance - 4.1/4.1)

SIMULATOR SETUP GUIDE:

- Verify/perform TQ-BR-201-0113, BRAIDWOOD TRAINING DEPARTMENT SIMULATOR EXAMINATION SECURITY ACTIONS CHECKLIST.
- Establish the conditions of IC 18, 75% power, steady state, equilibrium xenon.
- Complete items on Simulator Ready for Training Checklist.
- Verify/remove any Equipment Status Tags and Danger Tags not applicable to the scenario.
- Place simulator in RUN (allow simulator to run during board walk down and turnover).
- Run caep NRC 06-3 SETUP from disk and verify the following actuate:
 - IOR ZDI1VP01CCL PTL
 - IOR ZDI1VP01CCH PTL
 - IOR ZDI1GC01PB PTL
 - IMF RP02A
 - IMF RP02B
 - IMF FW48A
 - IMF FW13C 25 0
 - IMF FW26C 2000 0
 - IOR ZLO1FW5302 ON
 - IOR ZLO1SLFW530 OFF
 - IOR ZLOMLB6315 OFF
 - IOR ZDI1FW002B OPEN
- Place 1C RCFC high and low speed fans and 1B GC pump C/S's in PTL.
- Place danger tags on 1C RCFC high and low speed fans and 1B GC pump C/S's.
- Set Δ I Target Curve slopes to 0.06 (6%)
- Provide students with turnover sheets, 1BwOS NR-1, critical parameter sheet, load swing instruction sheets, and ReMa form.

Event 1: Power ascension

As Transmission System Operations, contact the MCR by phone (TSO phone) and request Unit 1 raise power to full power at 0.6 MW/min due to grid demand.

Acknowledge as chemistry/rad protection requests for RCS samples (if required).

Acknowledge as Transmission System Operations initiation of ramp.

Event 2: 1B AF pump clearance order

As SM acknowledge the failure, LCO 3.7.5, condition A entry, and request for on line risk assessment.

As SM, inform US on line risk is yellow.

After operator places 1B AF pump C/S in PTL, insert the following to disable the 1B AF pump

- IOR ZDI1AF01PB PTL
- IOR ZLOAUXOIL OFF
- IOR ZLO1AF01PBC OFF

Event 3: Pressurizer pressure channel 1PT-455 fails low

Insert IMF RX 21A 1700 30

As SM, acknowledge the failure, LCO 3.3.1 conditions A, E, & K entry, LCO 3.3.2, condition A & D entry, and LCO 3.3.4 condition A entry, requests for on line risk assessment (**COLOR**), maintenance support, and IR initiation.

If lead examiner desires the bistables tripped, participate in brief and perform the following:

- As assist NSO contact Unit 1 (X-2209)
- Insert the following:
 - MRF RP20 OPEN
 - MRF RX032 TRIP
 - MRF RX034 TRIP
 - MRF RX035 TRIP
 - MRF RX033 TRIP
 - MRF RX013 TRIP
 - MRF RX135 TRIP
 - MRF RP20 CLOSE

Event 4: Feed flow channel 1FT-530 fails low

Insert IMF RX04E 0 120

As SM, acknowledge the failure, requests for on line risk assessment, maintenance support, and IR initiation.

Event 5: ATWS

Run caep NRC 06-3 EVENTS 5_6 from disk and verify the following actuate:

- IOR ZDI1FW009C CLS
- IMF FW19C 3.5 30
- IMF RD09 0

If dispatched as NLO to locally trip Unit 1 reactor, wait until 1BwFR-S.1 step 6 (VERIFY REACTOR SUBCRITICAL) is complete, then delete the following malfunctions to locally open Unit 1 reactor trip breakers:

- DMF RP02A
- DMF RP02B

If reactor trip breakers do not open when above malfunctions deleted, insert the following remote functions to open the reactor trip breakers:

- IRF RP01 TRIP
- IRF RP02 TRIP

If dispatched as NLO/FS to verify dilution paths isolated, wait 15 minutes and report the following: 1CV8441, 1CV8435, & 1CV8453 are locked closed. 1AB8629A is closed.

Event 6: 1C FW line break inside containment

Acknowledge as SM procedure changes, E Plan evaluations, and STA request.

After STA requested, as STA report CSF status:

Event 7: 1A AF pump fails to auto start (preload)

Event 8: FW isolation failure (preload)

If dispatched as NLO to locally close 1FW002B, wait 5 minutes and report 1FW002B is mechanically bound open.

Scenario No: NR	C 06-3 Event No. 1
Event Description: Raise power at 0.6 MW/min	
Time Position	Applicant's Actions or Behavior
CUE	• Call from Transmission System Operations to raise power to full power at 0.6 MW/min.
US	 Acknowledge request to raise power Implement actions of 1BwGP 100-3 Perform pre-job brief per HU-AA-1211 "PRE-JOB, HEIGHTENED LEVEL OF AWARENESS, INFREQUENT PLANT ACTIVITY, AND POST JOB BRIEFINGS" for load ramp.
US	 Direct raising load to full power at 0.6 MW/min. Initiate load swing instruction sheet, 1BwGP 100-4T2.
CREW	Review applicable Precautions, and Limitations and Actions
RO	 Verify rod position and boron concentration. Perform dilution boundary calculation per 1BwGP 100-4T2 Initiate dilution, if required (BwOP CV-5) Determine required PW volume: (approximate band: 3000 gal – 4500 gal) Braidwood Boration Dilution Tables Determine required PW flow rate. Set 1FK-111 PW Flow Cont to desired PW flow rate. Set 1FY-0111 PW/Total Predet Counter to desired PW volume. Place MAKE-UP CONT SWITCH to STOP position. Set MODE SELECT to DIL/ALT DIL position. Place MAKE-UP CONT Switch to START Verify proper operation of valves and PW makeup pump (1CV111B open, 1CV111A throttled, 1CV110B open (ALT DIL only), PW pump running, PW flow on recorder) Turn on PZR backup heaters

Event Description: Raise power at 0.6 MW/min Time Position Applicant's Actions or Behavior Batch addition of PW: • Open CV110B. • Open CV111A. When desired amount of primary water added: Batch addition of PW: • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV111A. • Open CV111A. • When desired amount of primary water added: Close CV111A. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B.	Scenario No: NR	C 06-3 Event No. 1
Time Position Applicant's Actions or Behavior Batch addition of PW: • Open CV110B. • Open CV111A. When desired amount of primary water added: Batch addition of PW: • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV110B. • Open CV111A. • When desired amount of primary water added: Close CV111A. • Close CV110B. • Close CV110B. • Initiate turbing load increase:	Event Description:	Raise power at 0.6 MW/min
Batch addition of PW: • Open CV110B. • Open CV111A. When desired amount of primary water added: Batch addition of PW: • Open CV110B. • Open CV110B. • Open CV111A. • When desired amount of primary water added: Close CV111A. • When desired amount of primary water added: Close CV111A. • Close CV110B. • Initiate turbing load ingroses;	Time Position	Applicant's Actions or Behavior
BOP • Initiata turbina load increase:		 Batch addition of PW: Open CV110B. Open CV111A. When desired amount of primary water added: Batch addition of PW: Open CV110B. Open CV111A. When desired amount of primary water added: Close CV111A. Close CV110B.
 Depress LOAD RATE MW/MIN Enter desired load rate (0.6 MW/min) Depress REF Enter desired MW on REFERENCE DEMAND Window (1120 MW) When ready to begin load increase, depress GO Verify load increase occurring 	BOP	 Initiate turbine load increase: Depress LOAD RATE MW/MIN Enter desired load rate (0.6 MW/min) Depress REF Enter desired MW on REFERENCE DEMAND Window (1120 MW) When ready to begin load increase, depress GO Verify load increase occurring
 RO/ BOP Monitor reactor power and load increase: Monitor NI's, Tave, ΔI, Pzr press/level Monitor MWe, Turb loading, EHC During dilution: Monitor VCT level Verify RCS boron concentration lowering Monitor PW/Total flow predet counter Verify dilution auto stops at preset value. Return Reactor Makeup System to automatic at current boron concentration. 	RO/ BOP	 Monitor reactor power and load increase: Monitor NI's, Tave, ΔI, Pzr press/level Monitor MWe, Turb loading, EHC During dilution: Monitor VCT level Verify RCS boron concentration lowering Monitor PW/Total flow predet counter Verify dilution auto stops at preset value. Return Reactor Makeup System to automatic at current boron concentration.

Scenario No: NRC 06-3 Event No. 2		
Event Description: 1B AF pump clearance order		1B AF pump clearance order
Time	Position	Applicant's Actions or Behavior
	CUE	• Request from Work Control supervisor to place emergent C/O on 1B AF pump
	US	• Recognize entry conditions for TS LCO 3.7.5, condition A.
		• Inform SM of TS LCO 3.7.5 condition A entry and request risk assessment.
		• Direct RO & BOP to place C/O on 1B AF pump
	RO/	• Place 1B AF pump C/S in pull out
	BOP	• Place danger tag on 1B AF pump C/S
		• Close 1AF17B
		• Place danger tag on 1AF017B C/S
		• Close 1AF013E, G, & H
		• Place danger tags on 1AF013E, G, & H C/Ss
		Notify US of completion of C/O placement
		NOTE: 1B AF pump will remain unavailable for remainder of scenario.

Scenario No: NRC 06-3 Event No. 3		
Event Description:		Pressurizer pressure channel 1PT-455 fails low
Time	Position	Applicant's Actions or Behavior
	CUE	 Annunciator PZR PRESS LOW RX TRIP STPT ALERT (1-12-A1) Annunciator PZR PRESS LOW (1-12-B1) Annunciator PZR PRESS CONT DEV LOW HTRS ON (1-12-C1) Annunciator OTAT HIGH ROD STOP C-3 (1-10-C5) Annunciator OTAT HIGH RX TRIP ALERT (1-14-B1) PZR pressure indicators 1PRY456/457/458 rising PZR spray valve demand lowering Master PZR pressure controller demand lowering
	RO	 Identify/report failure of 1PT-455 Take manual control to restore PZR pressure Place 1PK-455A in manual and raise demand prior to PZR PORVs automatically opening Refer to BwARs
	CREW	Identify entry conditions for 1BwOA INST-2, "OPERATION WITH A FAILED INSTRUMENT CHANNEL"
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwOA INST-2, "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment B "PRESSURIZER PRESSURE CHANNEL FAILURE" and direct operator actions of 1BwOA INST -2 to establish the following conditions. Direct BOP/RO to stop load ramp/dilution
	RO	 Control PZR pressure in manual Select operable PZR pressure channel Place pressure control channel select switch to 457/458 position Check PZR PORVs - CLOSED Check PZR spray valves – NORMAL Check PZR heaters – NORMAL

Comments: _____

Scenario	No: NRC	06-3 Event No. 3
Event Description:		Pressurizer pressure channel 1PT-455 fails low
Time	Position	Applicant's Actions or Behavior
	RO	Check PZR pressure control in auto
		• PZR PORVs in auto
		 PZK spray valves in auto Place Mester PZP pressure controller in cuto
		Place Master PZR pressure controller in auto Salaat aparable abaptals to recorders
		 Select operable channels to recorders P7P pressure recorder selected to CH456, CH457, or CH458
		 FZK pressure recorder selected to CH450, CH457, or CH458 Loop AT recorder selected to 1B, 1C, or 1D
		• Loop AT recorder selected to TB, TC, of TD
	BOP	• Stop turbine load ramp
		 Depress DEHC HOLD pushbutton
		• Assist US & RO
		• Refer to BwARs
		• Monitor plant instrumentation
		• Refer to Tech Specs
	US	Perform pre-iob brief per HU-AA-1211 for bistable tripping
		• Complete 1BwOL 3.3.1, Attachment A, "INSTRUMENT CONDITION TRACKING LOG"
	Extra	Locally trip bistables for 1PT-455/BOP verifies correct bistable operation
	NSO/	• PB455A C1-153 BS-1
	BOP	• PB455C C1-153 BS-4
		• PB455D C1-153 BS-3
		• PB455B C1-153 BS-2
		• TB411C C1-124 BS-3
		• TB411D C1-124 BS-4
		Check P11 interlock
		• RCS pressure > 1930 psig – P11 NOT lit
	US	• Determine TS 3.3.1 conditions A, E, & K are applicable.
		• Determine TS 3.3.2 conditions A & D are applicable
		• Determine TS 3.3.4 condition A is applicable
		• Contact SM to perform risk assessment, initiate IR, and contact maintenance to
		investigate/correct instrument failure.
		The next event is to be inserted following the above actions by the US and Lead Examiner
		concurrence.

Scenario	No: NRC	06-3 Event No. 4
Event De	scription:	Feed flow channel 1FT-530 fails low
Time	Position	Applicant's Actions or Behavior
	CUE	 Annunciator SG 1C FLOW MISMATCH STM FLOW LOW (1-15-C3) Annunciator SG 1C FLOW MISMATCH FW FLOW LOW (1-15-C4) Annunciator SG 1C LEVEL DEVIATION HIGH/LOW (1-15-C9) 1C SG NR levels rising FW flow rising on 1FI-531
	BOP	 Identify/report failure of 1FT-530 Take manual control to restore SG level Place 1FK-530 in manual and lower demand prior to receiving P14 turbine trip/FW isolation. Refer to BwARs
	CREW	• Identify entry conditions for 1BwOA INST-2, "OPERATION WITH A FAILED INSTRUMENT CHANNEL"
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwOA INST-2, "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment G "FEEDWATER FLOW CHANNEL FAILURE" and direct operator actions of 1BwOA INST-2 to establish the following conditions. Direct BOP/RO to stop load ramp/dilution
	BOP	 Stop turbine load ramp Depress DEHC HOLD pushbutton Restore 1C SG level to 60% Control 1FW530 in manual Select operable FW flow channel Place FW flow select switch to F-531 position Establish automatic level control Place 1FK-530 in auto when SG level restored to normal Check HD system operation 1HD046A & B position normal

Comments: _____

Scenario	No: NRC	06-3 Event No. 4
Event De	scription:	Feed flow channel 1FT-530 fails low
Time	Position	Applicant's Actions or Behavior
	RO	 Monitor reactor power Ensure correct response of rod control system Assist US & BOP Refer to BwARs Monitor plant instrumentation
	US	• Contact SM to perform risk assessment, initiate IR, and contact maintenance to investigate/correct instrument failure.
		• The next event is to be inserted following the above actions by the US and Lead Examiner concurrence

Scenario	No: NRC	06-3 Event No. 5 & 6
Event Description:		ATWS/1C FW line break inside containment
Time	Position	Applicant's Actions or Behavior
	CUE	 Annunciator FWIV NOT FULL OPEN (1-1-A4) (1-15-E7) Annunciator FWIV HYD/PNEU PRESS LOW (1-1-B4) SG 1C FLOW MISMATCH FW FLOW LOW (1-15-C4) Annunciator SG 1C FLOW MISMATCH STM FLOW LOW (1-15-C3) 1C SG NR levels lowering
	RO/ BOP	 Identify/report 1FW009C partial closure Refer to BwARs
	US	 Notify SM of plant status Direct operator to trip reactor
	CREW	• Initiate a manual reactor trip and transition to 1BwEP-0
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwEP-0 and direct operator actions of 1BwEP-0
	RO	 Perform immediate operator actions of 1BwEP-0: Verify reactor trip Rod bottom lights - NONE LIT Reactor trip & Bypass breakers - CLOSED Neutron flux - NOT DROPPING Manually trip the reactor 1PM05J 1PM06J PR channels > 5% GO TO 1BwFR-S.1, RESPONSE TO NUCLEAR POWER GENERATION/ATWS
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwFR-S.1 and direct operator actions of 1BwFR-S.1

Scenario No: NRC 06-3 Event No. 5, 6, & 7

Event Description:		ATWS/1C FW line break inside containment/1B AF pump fails to auto start
Time	Position	Applicant's Actions or Behavior
	RO [CT] FR-S.1 C	 Perform immediate operator actions of 1BwFR-S.1: Verify reactor trip Rod bottom lights - NONE LIT Reactor trip & Bypass breakers - CLOSED Neutron flux – NOT DECREASING Manually trip the reactor 1PM05J 1PM06J Determine control rods NOT inserting automatically Manually insert control rods at greater than or equal to 48 steps per minute prior to completion of step 1 of 1BwFR-S.1.
	BOP	 Perform immediate operator actions of 1BwFR-S.1: Verify Turbine Trip All Turbine throttle valves - CLOSED All Turbine governor valves - CLOSED
	BOP [CT] FR-S.1 B	 Perform immediate operator actions of 1BwFR-S.1: Check AF pumps running AF pump run lights – NONE LIT Manually start the 1A AF pump prior to completion of step 3 of 1BwFR-S.1
	RO/ BOP	 Initiate emergency boration of the RCS CV pumps – BOTH RUNNING Open 1CV8104 Start boric acid transfer pump Emergency boration flow > 30 gpm (1FI-183A) Charging flow > 30 gpm (1FI-121A) or (1FI-917) PZR pressure < 2335 psig Dispatch operator to locally trip reactor
	BOP	 Verify CNMT vent isolation Group 6 CNMT vent isolation monitor lights – LIT

Scenario No: NRC 06-3 Event No. 5 & 6		
Event Description:		ATWS/1C FW line break inside containment
Time	Position	Applicant's Actions or Behavior
	RO BOP	 Verify reactor subcritical PR channels > 5% IR channels startup rate - NOT NEGATIVE Isolate steam dumps Place steam dump bypass interlock switches in - OFF RESET
	RO/ BOP	 Check if the following trips have occurred Reactor trip Turbine trip Check SG levels At least one SG level > 10% (31%) SG levels maintained between 10% (31%) and 50% 1SD002A-H - CLOSED Verify dilution paths isolated 1CV111A & B - CLOSED BTRS mode selector switch - OFF Dispatch operator to locally verify dilution paths isolated Stop reactivity insertion from RCS cooldown RCS temperature - DECREASING IN AN UNCONTROLLED MANNER 1C SG pressure - DECREASING IN AN UNCONTROLLED MANNER Check MS isolation MSIVs and MSIV bypass valves - CLOSED Identify faulted SG 1C SG pressure - DECREASING IN AN UNCONTROLLED MANNER CSG pressure - DECREASING IN AN UNCONTROLLED MANNER

Scenario No: NRC 06-3 Event No. 5, 6, & 8		
Event Description:		ATWS/1C FW line break inside containment/FW isolation failure
Time	Position	Applicant's Actions or Behavior
	RO/ BOP [CT] E-2A	 Isolate the 1C Steam Generator prior to completion of step 14 of 1BwFR-S.1. 1FW009C and 1FW530 FW isol monitor lights – NOT LIT 1FW009C – NOT FULLY CLOSED 1FW530 – NOT FULLY CLOSED 1FW530 – NOT FULLY CLOSED Close 1FW006C 1FW510 – CLOSED Close 1AF013C & G 1MS018C – CLOSED 1SD002G & H – CLOSED 1SD005D – CLOSED
	RO/ BOP	 Check CETCs < 1200°F Verify reactor subcritical PR channels < 5% IR channels - NEGATIVE SUR Return to 1BwEP-0
	US	 Notify SM of plant status and procedure entry Request evaluation of Emergency Plan conditions Enter/Implement 1BwEP-0 and direct operator actions of 1BwEP-0
	RO	 Perform immediate operator actions of 1BwEP-0: Verify reactor trip Rod bottom lights - ALL LIT Reactor trip & Bypass breakers - OPEN Neutron flux - DROPPING
	ВОР	 Perform immediate operator actions of 1BwEP-0: Verify Turbine Trip All Turbine throttle valves - CLOSED All Turbine governor valves - CLOSED

Scenario No: NRC 06-3 Event No. 5 & 6		
Event Description:		ATWS/1C FW line break inside containment
Time	Position	Applicant's Actions or Behavior
	ВОР	 Perform immediate operator actions of 1BwEP-0: Verify power to 4KV busses ESF Buses – BOTH ENERGIZED (141 & 142)
	CREW	 Check SI Status SI First OUT annunciator - LIT SI ACTUATED Permissive Light - LIT SI Equipment – AUTOMATICALLY ACTUATED Both SI pumps - RUNNING Both CV pump to cold leg isolation valves OPEN – 1SI8801A/B Manually actuate SI
	BOP	 Verify FW isolated FW pumps - TRIPPED Isolation monitor lights – NOT ALL LIT 1FW006C - closed FW pumps discharge valves – 1FW002B NOT CLOSED Dispatch operators to locally close 1FW002B
	RO/ BOP	 Verify ECCS pumps running Both CV pumps - RUNNING Both RH pumps - RUNNING Both SI pumps - RUNNING
	BOP	 Verify RCFCs running in Accident Mode Group 2 RCFC Accident Mode lights – LIT for 1A, 1B, & 1D RCFCs (1C RCFC OOS) Verify Phase A isolation Group 3 Cnmt Isol monitor lights - LIT Verify Cnmt Vent isolation Group 6 Cnmt Vent Isol monitor lights - LIT

Scenario	No: NRC	06-3 Event No. 5 & 6
Event Description:		ATWS/1C FW line break inside containment
Time	Position	Applicant's Actions or Behavior
	BOP	 Verify AF system: 1B AF pump – RUNNING AF isolation valves 1AF13 A, B, D, E, F, & H – OPEN 1AF013C & G - CLOSED AF flow control valves - THROTTLED 1AF005A-H
	BOP	 Verify CC pumps – BOTH RUNNING Verify SX pumpsBOTH RUNNING
	RO/ BOP	 Check Main Steamline Isolation not required 1Cl S/G pressure < 640 psig CNMT pressure > 8.2 psig
	BOP	 Check CS not required CNMT pressure remained < 20 psig CNMT pressure rose > 20 psig Stop all RCPs Group 6 CS monitor lights – LIT Group 6 phase B lights – LIT CS eductor suction flow > 15 gpm (1FI-CS013/14) CS eductor additive flow > 5 gpm (1FI-CS015/16)
	BOP/ RO	 Verify Total AF flow: AF flow > 500 gpm SG levels maintained between 10% (31%) and 50% Check status of S/G NR levels None rising in an uncontrolled manner

Scenario	No: NRC	06-3 Event No. 5 & 6
Event Description:		ATWS/1C FW line break inside containment
Time	Position	Applicant's Actions or Behavior
	RO/ BOP	 Verify ECCS valve alignment Group 2 Cold Leg Injection monitor lights required for injection – LIT Verify ECCS flow High Head SI flow >100 gpm (1FI-917) RCS pressure < 1700 psig SI pump discharge flow > 200 gpm
	RO	 Check at least ONE PZR PORV relief path available: PORV isolation valves – ENERGIZED PORV relief paths – PORVs in AUTO, PORV isolation valves OPEN
	ВОР	 Verify Generator Trip OCB 1-8 and 7-8 open PMG output breaker open
	ВОР	 Verify DGs running Both DGs RUNNING 1SX169A/B OPEN Dispatch operator locally to check operation
		Examiners note: US and RO will likely continue in 1BwEP-0 while BOP is performing the next 3 ventilation steps:

Scenario	No: NRC	06-3 Event No. 5 & 6
Event De	scription:	ATWS/1C FW line break inside containment
Time	Position	Applicant's Actions or Behavior
	BOP	 Verify Control Room ventilation aligned for emergency operations: VC Rad Monitors – LESS THAN HIGH ALARM SETPOINT Operating VC train equipment - RUNNING 0B Supply fan 0B Return fan 0B M/U fan 0B Chilled water pump 0B Chiller Operating VC train dampers - ALIGNED M/U fan outlet damper – 0VC08Y NOT FULLY CLOSED 0B VC train M/U filter light - LIT 0VC09Y OPEN 0VC313Y CLOSED Operating VC train Charcoal Absorber aligned for train B 0VC05Y OPEN 0VC05Y OPEN 0VC05Y OPEN 0VC06Y OPEN 0VC06Y OPEN 0VC06Y OPEN 0VC05Y OPEN 0VC06Y OPEN OVC05Y OPEN 0VC05Y OPEN 0VC06Y OPEN OVC06Y OPEN 0VC06Y OPEN 0VC06Y OPEN 0VC06Y OPEN 0VC06Y OPEN 0VC06Y OPEN
	BOP	 Verify Auxiliary Building ventilation aligned Two inaccessible filter plenums aligned Plenum A 0VA03CB - RUNNING 0VA023Y - OPEN 0VA436Y - CLOSED Plenum C 0VA03CF RUNNING 0VA072Y - OPEN Damper 0VA438Y - CLOSED

Scenario	No: NRC	06-3 Event No. 5 & 6
Event Description: ATWS/1C FW line break inside containment		ATWS/1C FW line break inside containment
Time	Position	Applicant's Actions or Behavior
	BOP	 Verify FHB ventilation aligned 0VA04CB - RUNNING 0VA055Y - OPEN 0VA062Y - OPEN 0VA435Y - CLOSED
	RO	 Check PZR sprays & PORVs Normal spray valves - CLOSED PORVs - CLOSED
	RO	 Maintain RCS temperature control RCPs - RUNNING Verify RCS average temperature stable at or trending to 557°F RCPs - NONE RUNNING Verify RCS cold leg temperature stable at or trending to 557°F Throttle AF flow
	RO	 Check status of RCPs All RCPs - RUNNING RCP trip criteria NOT met

Scenario	Scenario No: NRC 06-3 Event No. 5 & 6		
Event Description: ATWS/1C FW line break inside containment		ATWS/1C FW line break inside containment	
Time	Position	Applicant's Actions or Behavior	
	BOP/ RO	 Check if SG secondary pressure boundaries are intact: Check pressure in all SGs: 1C SG pressure decreasing in an uncontrolled manner 	
	CREW	Transition to 1BwEP-2, 'FAULTED STEAM GENERATOR ISOLATION'	
		Note: At this point the scenario may be terminated	
	US	 US to determine EAL at conclusion of scenario: Site Area Emergency MS3 – Auto and manual reactor trip not successful Failure of RPS to initiate AND complete an automatic reactor trip AND Failure of manual reactor trip 	