

Five Year PM History for P-40-1A, DIESEL DRIVEN FIRE PUMP

| Work Order # | Year | WO DESC (EWO) | WO Status |
|---------------|------|---|-----------|
| 00-000429-000 | 2000 | ANNUAL ELECTRICAL CHECK OF THE DIESEL FIRE PUMP GENERATOR | Closed |
| 00-000436-000 | 2000 | VERIFY JW AND LO HEATERS TURN OFF WHEN ENGINE IS RUNNING | Closed |
| 00-000437-000 | 2000 | DIESEL FIRE PUMP/ENGINE P-40-1A OVERHAUL - CANCEL SEE NOTES | Closed |
| 00-000438-000 | 2000 | DIESEL FIRE PUMP P-40-1A ANNUAL PM | Closed |
| 00-007068-000 | 2000 | ANNUAL ELECTRICAL CHECK OF THE DIESEL FIRE PUMP GENERATOR | Closed |
| 00-007071-000 | 2000 | VERIFY JW AND LO HEATERS TURN OFF WHEN ENGINE IS RUNNING | Closed |
| 00-007089-000 | 2000 | DIESEL FIRE PUMP P-40-1A ANNUAL PM | Closed |
| 01-002853-000 | 2001 | DIESEL FIRE PUMP/ENGINE P-40-1A MAJOR MAINT | Closed |
| 01-006298-000 | 2001 | ANNUAL ELECTRICAL CHECK OF THE DIESEL FIRE PUMP GENERATOR - CANCEL SEE NOTES | Closed |
| 01-006421-000 | 2001 | DIESEL FIRE PUMP P-40-1A ANNUAL PM | Closed |
| 01-006440-000 | 2001 | VERIFY JW AND LO HEATERS TURN OFF WHEN ENGINE IS RUNNING. CANCELLED SEE NOTES | Closed |
| 02-001109-000 | 2002 | ANNUAL ELECTRICAL CHECK OF THE DIESEL FIRE PUMP GENERATOR. DUPLICATE WO SEE NOTES. | Closed |
| 02-001110-000 | 2002 | DIESEL FIRE PUMP P-40-1A ANNUAL PM - CANCEL SEE NOTES | Closed |
| 02-001119-000 | 2002 | VERIFY JW AND LO HEATERS TURN OFF WHEN ENGINE IS RUNNING | Closed |
| 03-001076-000 | 2003 | ANNUAL ELECTRICAL CHECK OF THE DIESEL FIRE PUMP GENERATOR | Closed |
| 03-001093-000 | 2003 | VERIFY JW AND LO HEATERS TURN OFF WHEN ENGINE IS RUNNING | Closed |
| 03-001112-000 | 2003 | DIESEL FIRE PUMP P-40-1A ANNUAL PM | Closed |
| 04-000854-000 | 2004 | VERIFY JW AND LO HEATERS TURN OFF WHEN ENGINE IS RUNNING | Closed |
| 04-000855-000 | 2004 | ANNUAL ELECTRICAL CHECK OF THE DIESEL FIRE PUMP GENERATOR | Closed |
| 04-000879-000 | 2004 | DIESEL FIRE PUMP P-40-1A ANNUAL PM | Closed |
| 04-001101-000 | 2004 | REPLACE PUMP | Closed |
| 04-005833-000 | 2004 | DIESEL FIRE PUMP/ANGLE DRIVE P-40-1A 10 YEAR PM | Closed |
| 05-000882-000 | 2005 | DIESEL FIRE PUMP P-40-1A ANNUAL PM | Closed |
| 05-000882-001 | 2005 | PERFORM DIESEL FIRE PUMP RPM ADJUSTMENT IAW AP 0049 MINOR MAINT. & OP 4105. | Closed |
| 05-000886-000 | 2005 | VERIFY JW AND LO HEATERS TURN OFF WHEN ENGINE IS RUNNING | Closed |
| 05-000887-000 | 2005 | ANNUAL ELECTRICAL CHECK OF THE DIESEL FIRE PUMP | Closed |