

From: D. Ashley
To: John Hufnagel
Date: 06/05/2006 2:37:15 PM
Subject: supplemental information RAI 4.3-4

John-

In reviewing your RAI response to question RAI 4.3-4, the reviewer needs clarification on the following...

In the May 1, 2006, submittal, the response to RAI 4.3-4 lists the environmental multiplier, Fen, for the feedwater nozzle as 2.19.

This multiplier does not appear to be correct for the LAS nozzle.

Do we need to arrange a followup call to discuss this issue? or is this a typo?

thanks

=====
regards,

Donnie Ashley
NRR/DLR/RLRA
Oyster Creek
License Renewal Project Manger
301-415-3191
dja1@nrc.gov

10
11
12
13
14
15
16
17
18
19
20

Mail Envelope Properties (448479DB.737 : 9 : 10848)

Subject: supplemental information RAI 4.3-4
Creation Date 06/05/2006 2:37:15 PM
From: D. Ashley

Created By: DJA1@nrc.gov

Recipients	Action	Date & Time
exeloncorp.com	Transferred	05 June, 2006 2:38:19
PM		
john.hufnagel (John Hufnagel)		

Post Office	Delivered	Route
		exeloncorp.com

Files	Size	Date & Time
MESSAGE	1339	05 June, 2006 2:37:15 PM
D. Ashley.vcf	232	05 June, 2006 2:37:15 PM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened