

From: "Timothy Rice" <tbrice@gw.dec.state.ny.us>
To: "William Axelson" <WAxelso@entergy.com>, "James Noggle" <JDN@nrc.gov>
Date: 4/17/06 1:01PM
Subject: Latest State Data

Bill and Jim,
Attached is an Excel file with the latest summary of State final analytical results.
Tim

B-22

Summary of NYS Results

05/09/2006

Sampling Date	Sample ID	Sample Location	Tritium pCi/l	Sr-90 pCi/l	Gamma Spec	GB pCi/l	GA pCi/l
10/21/2005	200520855628	U2 CST	<110	NA	NA		
10/21/2005	200520855629	U3-T2	1420 +/- 160	NA	NA		
10/21/2005	200520855630	U3-2	510 +/- 130	NA	NA		
10/21/2005	200520855631	MW-111	267000 +/- 8000	3 +/- 2	ND		
10/21/2006	200520855631	MW-111 Sr90 recount & GA/GB *		1.9 +/- 0.7		9.0 +/- 6.0	5.0 +/- 2.0
10/21/2005	200520855632	U3-4	340 +/- 120	NA	NA		
10/21/2005	200520855633	U3-1	<110	NA	NA		
10/21/2005	200520855634	U3-3	<110	NA	NA		
10/21/2005	200520855635	U3-T1	<110	NA	NA		
11/30/2005	200520855645	Trap Rock Quarry	90 +/- 60	<0.4	ND		
11/30/2005	200520855646	Algonquin Creek	<60	0.7 +/- 0.4	RDP		
11/30/2005	200520855647	5th Street Well	<60	0.8 +/- 0.7	RDP		
11/30/2005	200520855648	Gypsum Plant Outfall	<60	0.8 +/- 0.4	RDP		
12/06/2005	200520855658	LaFarge Gypsum Well #1	<50	NA	NA		
12/06/2005	200520855659	LaFarge Gypsum Well #3	<50	NA	NA		
12/08/2005	200520855654	MW38	700 +/- 120	NA	NA		
12/08/2005	200520855655	MW101	<50	NA	NA		
12/08/2005	200520855656	MW105	100 +/- 90	NA	NA		
12/08/2005	200520855657	MW107	<50	NA	NA		
02/07/2006	200620865001	MW-30 72'	3.76E5 +/- 0.11E5	<0.5	ND		
02/07/2006	200620865002	MW-31	3.38E4 +/- 0.12E4	<0.5	ND		
02/07/2006	200620865003	MW-32	1.92E4 +/- 0.07E4	<0.6	ND		
02/07/2006	200620865004	MW-33	2.02E5 +/- 0.06E5	<0.5	ND		
02/07/2006	200620865005	MW-34	1.74E5 +/- 0.05E5	<0.6	ND		
02/07/2006	200620865006	MW-35	8.9E4 +/- 0.3E4	<0.5	ND		
02/07/2006	200620865007	MW-36	2.1E4 +/- 0.08E4	1.1 +/- 0.6	ND		
02/08/2006	200620865008	MW-38	<110	<0.5	ND		
02/08/2006	200620865009	MW-48	250 +/- 110	<0.5	ND		
02/07/2006	200620865010	MW-111	1.96E5 +/- 0.06E5	1.6 +/- 0.05	ND	9.9 +/- 1.7	2.6 +/- 0.9
01/30/2006	200620865011	Doodletown Bight @ PIP Maint.	<90	<0.5	ND		
02/08/2006	200620865012	Algonquin Creek	<90	<0.6	ND		
02/08/2006	200620865013	Trap Rock Quarry	<90	0.9 +/- 0.6	ND		
01/30/2006	200620865014	Lake Kanawake	<90	<0.4	ND		
01/30/2006	200620865015	Ramapo River @ Arden Rd	<90	<0.4	ND		
02/08/2006	200620865016	Hudson River Middle of waterfront	<90	<0.4	ND		
02/08/2006	200620865017	Hudson River Unit 2 Outfall	<90	<0.4	ND		
02/08/2006	200620865018	Hudson River Off Manhole 1	<90	<0.4	ND		
02/08/2006	200620865019	Gypsum Plant Outfall	<90	<0.4	ND		
02/08/2006	200620865020	Hudson River North of IPEC	<90	<1.0	ND		
03/10/2006	200620865028	MW-37 22'	2.20E4 +/- 0.08E4	8.3 +/- 0.7	ND	26 +/- 4	<1.7
03/10/2006	200620865029	MW-37 32'	2.79E4 +/- 0.10E4	23.9 +/- 1.1	ND	56 +/- 4	3.8 +/- 1.7
03/10/2006	200620865030	MW-37 40' **	1.63E4 +/- 0.06E4	22.3 +/- 1.2	ND	73 +/- 7	67 +/- 4
03/10/2006	200620865031	MW-37 57'	1.54E4 +/- 0.06E4	27.3 +/- 1.2	ND	62 +/- 4	2.9 +/- 1.8
03/22/2006		MW-49 25.5'					
03/22/2006		MW-49 42'					
03/22/2006		MW-49 65.5'					
03/22/2006		MW-50 42'					
03/22/2006		MW-50 67'					
03/23/2006		MW-42 49'					
03/24/2006		MW-42 78'					
03/23/2006		MW-36 26'					
03/24/2006		MW-36 41'					
03/23/2006		MW-36 52'					
NA - Not Applicable (This analysis was not performed)							
ND - Non Detect (No readings at or above detection limits)							
RDP - Dissolved Radon Decay Products							
Sr-90 Bkg Ran 0.8 - 1.3 pCi/l NYSDOH Data, 1987 - 1990.							
* Analysis for Sr-90 repeated with 600ml of sample for better counting statistics							
** Review of GA Result requested							