

Part 70; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

A. Maximum Power Level

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 2568 megawatts thermal.

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 353 are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

C. This license is subject to the following antitrust conditions:

Applicant makes the commitments contained herein, recognizing that bulk power supply arrangements between neighboring entities normally tend to serve the public interest. In addition, where there are net benefits to all participants, such arrangements also serve the best interests of each of the participants. Among the benefits of such transactions are increased electric system reliability, a reduction in the cost of electric power, and minimization of the environmental effects of the production and sale of electricity.

Any particular bulk power supply transaction may afford greater benefits to one participant than to another. The benefits realized by a small system may be proportionately greater than those realized by a larger system. The relative benefits to be derived by the parties from a proposed transaction, however, should not be controlling upon a decision with respect to the desirability of participating in the transaction. Accordingly, applicant will enter into proposed bulk power transactions of the types hereinafter described which, on balance, provide net benefits to applicant. There are net benefits in a transaction if applicant recovers the cost of the transaction (as defined in ¶1 (d) hereof) and there is no demonstrable net detriment to applicant arising from that transaction.

1. As used herein:

- (a) "Bulk Power" means electric power and any attendant energy, supplied or made available at transmission or sub-transmission voltage by one electric system to another.
- (b) "Neighboring Entity" means a private or public corporation, a governmental agency or authority, a municipality, a cooperative, or a lawful association of any of the foregoing owning or operating, or

December 27, 1984; December 5, 1988; and August 21, 1989 subject to the following provision:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

E. Physical Protection

Duke Power Company LLC shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contains safeguards information protected under 10 CFR 73.21, is entitled: "Duke Energy Physical Security Plan" submitted by letter dated September 8, 2004, and supplemented on September 30, 2004, October 15, 2004, October 21, 2004, and October 27, 2004.

F. In the update to the UFSAR required pursuant to 10 CFR 50.71(e)(4) scheduled for July, 2001, the licensee shall update the UFSAR to include the UFSAR supplement submitted pursuant to 10 CFR 54.21(d) as revised on March 27, 2000. Until the UFSAR update is complete, the licensee may make changes to the programs described in its UFSAR supplement without prior Commission approval, provided that the licensee evaluates each such change pursuant to the criteria set forth in 10 CFR 50.59 and otherwise complies with the requirements in that section.

G. The licensee's UFSAR supplement submitted pursuant to 10 CFR 54.21(d), as revised on March 27, 2000, describes certain future inspection activities to be completed before the period of extended operation. The licensee shall complete these activities no later than February 6, 2013.

4. This renewed license is effective as of the date of issuance and shall expire at midnight on February 6, 2033.

Part 70; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

A. Maximum Power Level

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 2568 megawatts thermal.

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 355 are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

C. This license is subject to the following antitrust conditions:

Applicant makes the commitments contained herein, recognizing that bulk power supply arrangements between neighboring entities normally tend to serve the public interest. In addition, where there are net benefits to all participants, such arrangements also serve the best interests of each of the participants. Among the benefits of such transactions are increased electric system reliability, a reduction in the cost of electric power, and minimization of the environmental effects of the production and sale of electricity.

Any particular bulk power supply transaction may afford greater benefits to one participant than to another. The benefits realized by a small system may be proportionately greater than those realized by a larger system. The relative benefits to be derived by the parties from a proposed transaction, however, should not be controlling upon a decision with respect to the desirability of participating in the transaction. Accordingly, applicant will enter into proposed bulk power transactions of the types hereinafter described which, on balance, provide net benefits to applicant. There are net benefits in a transaction if applicant recovers the cost of the transaction (as defined in ¶1(d) hereof) and there is no demonstrable net detriment to applicant arising from that transaction.

1. As used herein:

- (a) "Bulk Power" means electric power and any attendant energy, supplied or made available at transmission or sub-transmission voltage by one electric system to another.
- (b) "Neighboring Entity" means a private or public corporation, a governmental agency or authority, a municipality, a cooperative, or a lawful association of any of the foregoing owning or operating, or

December 27, 1984; December 5, 1988; and August 21, 1989 subject to the following provision:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

E. Physical Protection

Duke Power Company LLC shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contains safeguards information protected under 10 CFR 73.21, is entitled: "Duke Energy Physical Security Plan" submitted by letter dated September 8, 2004, and supplemented on September 30, 2004, October 15, 2004, October 21, 2004, and October 27, 2004.

- F. In the update to the UFSAR required pursuant to 10 CFR 50.71(e)(4) scheduled for July, 2001, the licensee shall update the UFSAR to include the UFSAR supplement submitted pursuant to 10 CFR 54.21(d) as revised on March 27, 2000. Until the UFSAR update is complete, the licensee may make changes to the programs described in its UFSAR supplement without prior Commission approval, provided that the licensee evaluates each such change pursuant to the criteria set forth in 10 CFR 50.59 and otherwise complies with the requirements in that section.
- G. The licensee's UFSAR supplement submitted pursuant to 10 CFR 54.21(d), as revised on March 27, 2000, describes certain future inspection activities to be completed before the period of extended operation. The licensee shall complete these activities no later than February 6, 2013.
4. This renewed license is effective as of the date of issuance and shall expire at midnight on October 6, 2033.

Part 70; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

A. Maximum Power Level

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 2568 megawatts thermal.

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 354 are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

C. This license is subject to the following antitrust conditions:

Applicant makes the commitments contained herein, recognizing that bulk power supply arrangements between neighboring entities normally tend to serve the public interest. In addition, where there are net benefits to all participants, such arrangements also serve the best interests of each of the participants. Among the benefits of such transactions are increased electric system reliability, a reduction in the cost of electric power, and minimization of the environmental effects of the production and sale of electricity.

Any particular bulk power supply transaction may afford greater benefits to one participant than to another. The benefits realized by a small system may be proportionately greater than those realized by a larger system. The relative benefits to be derived by the parties from a proposed transaction, however, should not be controlling upon a decision with respect to the desirability of participating in the transaction. Accordingly, applicant will enter into proposed bulk power transactions of the types hereinafter described which, on balance, provide net benefits to applicant. There are net benefits in a transaction if applicant recovers the cost of the transaction (as defined in ¶1(d) hereof) and there is no demonstrable net detriment to applicant arising from that transaction.

1. As used herein:

- (a) "Bulk Power" means electric power and any attendant energy, supplied or made available at transmission or sub-transmission voltage by one electric system to another.
- (b) "Neighboring Entity" means a private or public corporation, a governmental agency or authority, a municipality, a cooperative, or a lawful association of any of the foregoing owning or operating, or

December 27, 1984; December 5, 1988; and August 21, 1989 subject to the following provision:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

E. Physical Protection

Duke Power Company LLC shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contains safeguards information protected under 10 CFR 73.21, is entitled: "Duke Energy Physical Security Plan" submitted by letter dated September 8, 2004, and supplemented on September 30, 2004, October 15, 2004, October 21, 2004, and October 27, 2004.

F. In the update to the UFSAR required pursuant to 10 CFR 50.71(e)(4) scheduled for July, 2001, the licensee shall update the UFSAR to include the UFSAR supplement submitted pursuant to 10 CFR 54.21(d) as revised on March 27, 2000. Until the UFSAR update is complete, the licensee may make changes to the programs described in its UFSAR supplement without prior Commission approval, provided that the licensee evaluates each such change pursuant to the criteria set forth in 10 CFR 50.59 and otherwise complies with the requirements in that section.

G. The licensee's UFSAR supplement submitted pursuant to 10 CFR 54.21(d), as revised on March 27, 2000, describes certain future inspection activities to be completed before the period of extended operation. The licensee shall complete these activities no later than February 6, 2013.

4. This renewed license is effective as of the date of issuance and shall expire at midnight on July 19, 2034.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	<p>C.2.2.3 Verify by administrative means that the remaining KHU and its required underground emergency power path and both required offsite sources are OPERABLE and the requirements of LCO 3.8.3, "DC Sources-Operating," LCO 3.8.6, "Vital Inverters-Operating," LCO 3.8.8, "Distribution Systems-Operating," LCO 3.3.17, "EPSL Automatic Transfer Function," LCO 3.3.18, "EPSL Voltage Sensing Circuits," LCO 3.3.19, "EPSL 230 kV Switchyard DGVP," and LCO 3.3.21, "EPSL Keowee Emergency Start Function" are met.</p> <p><u>AND</u></p>	<p>72 hours</p> <p>(continued)</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	<p>C.2.2.4 Verify alternate power source capability by performing SR 3.8.1.16.</p> <p><u>AND</u></p>	<p>72 hours</p> <p><u>AND</u></p> <p>Every 31 days thereafter</p>
	<p>C.2.2.5 Restore KHU and its required overhead emergency power path to OPERABLE status.</p>	<p>28 days when Condition due to an inoperable Keowee main step-up transformer</p> <p><u>AND</u></p> <p>45 days from discovery of initial inoperability when Condition due to an inoperable KHU if not used for that KHU in the previous 3 years</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. KHU or its required underground power path inoperable.</p>	<p>D.1 Perform SR 3.8.1.4 for OPERABLE KHU.</p>	<p>1 hour if not performed in previous 12 hours</p>
	<p><u>AND</u></p> <p>D.2 Energize either standby bus from LCT via isolated power path.</p>	<p>24 hours</p> <p><u>AND</u></p> <p>1 hour from subsequent discovery of deenergized required standby bus</p>
	<p><u>AND</u></p> <p>D.3 Restore KHU and its required underground emergency power path to OPERABLE status.</p>	<p>72 hours</p> <p><u>AND</u></p> <p>72 hours from discovery of inoperable KHU</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>E. Required Action and associated Completion Time not met for Required Action D.2.</p>	<p>E.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>E.2 Be in MODE 5.</p>	<p>12 hours for one unit</p> <p><u>AND</u></p> <p>24 hours for other unit(s)</p> <p>84 hours</p>
<p>F. Zone overlap protection circuitry inoperable when overhead electrical disconnects for KHU associated with the underground power path are closed.</p>	<p>F.1 Restore zone overlap protection circuitry to OPERABLE status.</p> <p><u>OR</u></p> <p>F.2 Open overhead electrical disconnects for KHU associated with the underground power path.</p>	<p>72 hours</p> <p>72 hours</p>
<p>G. Both emergency power paths inoperable due to one inoperable E breaker and one inoperable S breaker on the same main feeder bus.</p>	<p>G.1 Restore one breaker to OPERABLE status.</p>	<p>24 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>H. -----NOTE----- Condition may be entered only when both required offsite sources are verified by administrative means to be OPERABLE and the requirements of LCO 3.8.3, "DC Sources-Operating;" LCO 3.8.6, "Vital Inverters-Operating;" LCO 3.8.8, "Distribution Systems-Operating;" LCO 3.3.17, "EPSL Automatic Transfer Function;" LCO 3.3.18, "EPSL Voltage Sensing Circuits;" LCO 3.3.19, "EPSL 230 kV Switchyard DGVP," are verified by administrative means to be met.</p> <p>-----</p> <p>Both KHUs or their required emergency power paths inoperable for planned maintenance or test with both standby buses energized from LCT via isolated power path.</p>	<p>H.1 Energize both standby buses from LCT via isolated power path.</p> <p><u>AND</u></p> <p>H.2 Restore one KHU and its required emergency power path to OPERABLE status.</p>	<p>1 hour from discovery of deenergized standby bus</p> <p>60 hours</p>

(continued)