

1.0 USE AND APPLICATION

1.1 Definitions

- NOTE -

The defined terms of this section appear in capitalized type and are applicable throughout these Technical Specifications and Bases.

<u>Term</u>	<u>Definition</u>
ACTIONS	ACTIONS shall be that part of a Specification that prescribes Required Actions to be taken under designated Conditions within specified Completion Times.
ACTUATION LOGIC TEST	An ACTUATION LOGIC TEST shall be the application of various simulated or actual input combinations in conjunction with each possible interlock logic state and the verification of the required logic output. The ACTUATION LOGIC TEST, as a minimum, shall include a continuity check of output devices.
AXIAL FLUX DIFFERENCE (AFD)	AFD shall be the difference in normalized flux signals between the top and bottom halves of a two section excore neutron detector.
CHANNEL CALIBRATION	<p>A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel so that it responds within the required range and accuracy to known input. The CHANNEL CALIBRATION shall encompass the entire channel, including the required sensor, alarm, interlock, display, and trip functions. Calibration of instrument channels with resistance temperature detector (RTD) or thermocouple sensors may consist of an inplace qualitative assessment of sensor behavior and normal calibration of the remaining adjustable devices in the channel.</p> <p>The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping calibrations or total channel steps so that the entire channel is calibrated.</p>
CHANNEL CHECK	A CHANNEL CHECK shall be the qualitative assessment, by observation, of channel behavior during operation. This determination shall include, where possible, comparison of the channel indication and status to other indications or status derived from independent instrument channels measuring the same parameter.

**CHANNEL OPERATIONAL TEST (COT)** A COT shall be the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify the OPERABILITY of required alarm, interlock, display, and trip functions. The COT shall include adjustments, as necessary, of the required alarm, interlock, and trip setpoints so that the setpoints are within the required range and accuracy.

**CORE ALTERATIONS** CORE ALTERATIONS shall be the movement of any fuel, sources, or reactivity control components, within the reactor vessel with the vessel head removed and fuel in the vessel. Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to a safe position.

**CORE OPERATING LIMITS REPORT (COLR)** The COLR is the plant specific document that provides cycle specific parameter limits for the current reload cycle. These cycle specific parameter limits shall be determined for each reload cycle in accordance with Specification 5.6.5. Plant operation within these limits is addressed in individual Specifications.

**DOSE EQUIVALENT I-131** DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microcuries/gram) that alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in ICRP 30, Supplement to Part 1, pages 192-212, table entitled, "Committed Dose Equivalent in Target Organs or Tissues per Intake of Unit Activity."

**$\bar{E}$  - AVERAGE DISINTEGRATION ENERGY**  $\bar{E}$  shall be the average (weighted in proportion to the concentration of each radionuclide in the reactor coolant at the time of sampling) of the sum of the average beta and gamma energies (in MeV) per disintegration for non-iodine isotopes, with half lives > 15 minutes, making up at least 95% of the total non-iodine activity in the coolant.

LEAKAGE

LEAKAGE from the RCS shall be:

a. Identified LEAKAGE

1. LEAKAGE, such as that from pump seals or valve packing (except reactor coolant pump (RCP) seal water injection or return), that is captured and conducted to collection systems or a sump or collecting tank;
2. LEAKAGE into the containment atmosphere from sources that are both specifically located and known either not to interfere with the operation of leakage detection systems or not to be pressure boundary LEAKAGE; or
3. Reactor Coolant System (RCS) LEAKAGE through a steam generator (SG) to the Secondary System;

b. Unidentified LEAKAGE

All LEAKAGE (except RCP seal water injection or return) that is not identified LEAKAGE;

c. Pressure Boundary LEAKAGE

LEAKAGE (except SG LEAKAGE) through a nonisolable fault in an RCS component body, pipe wall, or vessel wall.

MODE  
- MODES

A MODE shall correspond to any one inclusive combination of core reactivity condition, power level, average reactor coolant temperature, and reactor vessel head closure bolt tensioning specified in Table 1.1-1 with fuel in the reactor vessel.

OPERABLE  
- OPERABILITY

A system, subsystem, train, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s) and when all necessary attendant instrumentation, controls, normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, train, component, or device to perform its specified safety function(s) are also capable of performing their related support function(s).

PHYSICS TESTS	<p>PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation. These tests are:</p> <ol style="list-style-type: none"> <li>a. Described in Chapter 14, Initial Test Program of the UFSAR;</li> <li>b. Authorized under the provisions of 10 CFR 50.59; or</li> <li>c. Otherwise approved by the Nuclear Regulatory Commission (NRC).</li> </ol>
PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)	<p>The PTLR is the plant specific document that provides the reactor vessel pressure and temperature limits, including heatup and cooldown rates, and the power operated relief valve lift settings and enable temperature associated with the Low Temperature Overpressurization Protection System for the current reactor vessel fluence period. These pressure and temperature limits shall be determined for each fluence period in accordance with Specification 5.6.6. Plant operation within these limits is addressed in individual specifications.</p>
QUADRANT POWER TILT RATIO (QPTR)	<p>QPTR shall be the ratio of the highest average nuclear power in any quadrant to the average nuclear power in the four quadrants.</p>
RATED THERMAL POWER (RTP)	<p>RTP shall be a total reactor core heat transfer rate to the reactor coolant of 1775 MWt.</p>
SHUTDOWN MARGIN (SDM)	<p>SDM shall be the instantaneous amount of reactivity by which the reactor is subcritical or would be subcritical from its present condition assuming:</p> <ol style="list-style-type: none"> <li>a. All rod cluster control assemblies (RCCAs) are fully inserted except for the single RCCA of highest reactivity worth, which is assumed to be fully withdrawn. With any RCCAs not capable of being fully inserted, the reactivity worth of the RCCAs must be accounted for in the determination of SDM; and</li> <li>b. In MODES 1 and 2, the fuel and moderator temperatures are changed to the nominal hot zero power temperature.</li> </ol>
STAGGERED TEST BASIS	<p>A STAGGERED TEST BASIS shall consist of the testing of one of the systems, subsystems, channels, or other designated components during the interval specified by the Surveillance Frequency, so that all systems, subsystems, channels, or other designated components are tested during <i>n</i> Surveillance Frequency intervals, where <i>n</i> is the total number of systems, subsystems, channels, or other designated components in the associated function.</p>

THERMAL POWER	THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.
TRIP ACTUATING DEVICE OPERATIONAL TEST (TADOT)	A TADOT shall consist of operating the trip actuating device and verifying the OPERABILITY of required alarm, interlock, display, and trip functions. The TADOT shall include adjustment, as necessary, of the trip actuating device so that it actuates at the required setpoint within the required accuracy.

---

---

Table 1.1-1  
MODES

MODE	TITLE	REACTIVITY CONDITION ( $k_{eff}$ )	% RATED THERMAL POWER <sup>(a)</sup>	AVERAGE REACTOR COOLANT TEMPERATURE (°F)
1	Power Operation	$\geq 0.99$	$> 5$	NA
2	Startup	$\geq 0.99$	$\leq 5$	NA
3	Hot Shutdown	$< 0.99$	NA	$\geq 350$
4	Hot Standby <sup>(b)</sup>	$< 0.99$	NA	$350 > T_{avg} > 200$
5	Cold Shutdown <sup>(b)</sup>	$< 0.99$	NA	$\leq 200$
6	Refueling <sup>(c)</sup>	NA	NA	NA

(a) Excluding decay heat.

(b) All reactor vessel head closure bolts fully tensioned.

(c) One or more reactor vessel head closure bolts less than fully tensioned.

3.3 INSTRUMENTATION

3.3.1 Reactor Trip System (RTS) Instrumentation

LCO 3.3.1 The RTS instrumentation for each Function in Table 3.3.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1-1.

ACTIONS

- NOTE -

Separate Condition entry is allowed for each Function.

CONDITION		REQUIRED ACTION	COMPLETION TIME
A.	One or more Functions with one channel inoperable.  <u>OR</u>  Two source range channels inoperable.	A.1 Enter the Condition referenced in Table 3.3.1-1 for the channel(s).	Immediately
B.	As required by Required Action A.1 and referenced by Table 3.3.1-1.	B.1 Restore channel to OPERABLE status.	48 hours
C.	Required Action and associated Completion Time of Condition B not met.	C.1 Be in MODE 3.  <u>AND</u>  C.2 Initiate action to fully insert all rods.  <u>AND</u>  C.3 Place Control Rod Drive System in a condition incapable of rod withdrawal.	6 hours  6 hours  7 hours

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. As required by Required Action A.1 and referenced by Table 3.3.1-1.	D.1 ----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels. -----  Place channel in trip.	6 hours
E. As required by Required Action A.1 and referenced by Table 3.3.1-1.	E.1 Reduce THERMAL POWER to < 5E-11 amps.  <u>OR</u>  E.2 ----- - NOTE - Required Action E.2 is not applicable when:  a. Two channels are inoperable, or  b. THERMAL POWER is < 5E-11 amps. -----  Increase THERMAL POWER to ≥ 8% RTP.	2 hours           2 hours
F. As required by Required Action A.1 and referenced by Table 3.3.1-1.	F.1 Open RTBs and RTBBs upon discovery of two inoperable channels.  <u>AND</u>  F.2 Suspend operations involving positive reactivity additions.  <u>AND</u>  F.3 Restore channel to OPERABLE status.	Immediately upon discovery of two inoperable channels           Immediately           48 hours



CONDITION	REQUIRED ACTION	COMPLETION TIME
G. Required Action and associated Completion Time of Condition D, E, or F is not met.	G.1 Be in MODE 3.	6 hours
H. As required by Required Action A.1 and referenced by Table 3.3.1-1.	H.1 Restore at least one channel to OPERABLE status upon discovery of two inoperable channels.	1 hour from discovery of two inoperable channels
	<u>AND</u>	
	H.2 Suspend operations involving positive reactivity additions.	Immediately
	<u>AND</u>	
	H.3 Restore channel to OPERABLE status.	48 hours
I. Required Action and associated Completion Time of Condition H not met.	I.1 Initiate action to fully insert all rods.	Immediately
	<u>AND</u>	
	I.2 Place the Control Rod Drive System in a condition incapable of rod withdrawal.	1 hour
J. As required by Required Action A.1 and referenced by Table 3.3.1-1.	J.1 Suspend operations involving positive reactivity additions.	Immediately
	<u>AND</u>	
	J.2 Perform SR 3.1.1.1.	12 hours
	<u>AND</u>	
		Once per 12 hours thereafter

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>K. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>K.1</p> <p>----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels. -----</p> <p>Place channel in trip.</p>	<p>6 hours</p>
<p>L. Required Action and associated Completion Time of Condition K not met.</p>	<p>L.1 Reduce THERMAL POWER to &lt; 8.5% RTP.</p>	<p>6 hours</p>
<p>M. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>M.1</p> <p>----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels. -----</p> <p>Place channel in trip.</p>	<p>6 hours</p>
<p>N. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>N.1 Restore channel to OPERABLE status.</p>	<p>6 hours</p>
<p>O. Required Action and associated Completion Time of Condition M or N not met.</p>	<p>O.1 Reduce THERMAL POWER to &lt; 30% RTP.</p>	<p>6 hours</p>
<p>P. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>P.1</p> <p>----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels. -----</p> <p>Place channel in trip.</p>	<p>6 hours</p>

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>Q. Required Action and Associated Completion Time of Condition P not met.</p>	<p>Q.1 Reduce THERMAL POWER to &lt; 50% RTP.</p> <p><u>AND</u></p> <p>Q.2.1 Verify Steam Dump System is OPERABLE.</p> <p><u>OR</u></p> <p>Q.2.2 Reduce THERMAL POWER to &lt; 8% RTP.</p>	<p>6 hours</p> <p>7 hours</p> <p>7 hours</p>
<p>R. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>R.1</p> <p>----- - NOTE - One train may be bypassed for up to 4 hours for surveillance testing provided the other train is OPERABLE. -----</p> <p>Restore train to OPERABLE status.</p>	<p>6 hours</p>
<p>S. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>S.1 Verify interlock is in required state for existing plant conditions.</p> <p><u>OR</u></p> <p>S.2 Declare associated RTS Function channel(s) inoperable.</p>	<p>1 hour</p> <p>1 hour</p>

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>T. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>T.1</p> <p>----- - NOTE - -----</p> <p>1. One train may be bypassed for up to 2 hours for surveillance testing, provided the other train is OPERABLE.</p> <p>2. One RTB may be bypassed for up to 6 hours for maintenance on undervoltage or shunt trip mechanisms, provided the other train is OPERABLE.</p> <p>-----</p> <p>Restore train to OPERABLE status.</p>	<p>1 hour</p>
<p>U. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>U.1 Restore at least one trip mechanism to OPERABLE status upon discovery of two RTBs with inoperable trip mechanisms.</p> <p><u>AND</u></p> <p>U.2 Restore trip mechanism to OPERABLE status.</p>	<p>1 hour from discovery of two inoperable trip mechanisms</p> <p>48 hours</p>
<p>V. Required Action and associated Completion Time of Condition R, S, T, or U not met.</p>	<p>V.1 Be in MODE 3.</p>	<p>6 hours</p>
<p>W. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>W.1 Restore at least one trip mechanism to OPERABLE status upon discovery of two RTBs with inoperable trip mechanisms.</p> <p><u>AND</u></p>	<p>1 hour from discovery of two inoperable trip mechanisms</p>

CONDITION	REQUIRED ACTION	COMPLETION TIME
	W.2 Restore trip mechanism or train to OPERABLE status.	48 hours
X. Required Action and associated Completion Time of Condition W not met.	X.1 Initiate action to fully insert all rods.	Immediately
	<u>AND</u> X.2 Place the Control Rod Drive System in a Condition incapable of rod withdrawal.	1 hour

SURVEILLANCE REQUIREMENTS

- NOTE -

Refer to Table 3.3.1-1 to determine which SRs apply for each RTS Function.

SURVEILLANCE	FREQUENCY
SR 3.3.1.1 Perform CHANNEL CHECK.	12 hours
SR 3.3.1.2 ----- - NOTE - Required to be performed within 12 hours after THERMAL POWER is $\geq$ 50% RTP. ----- Compare results of calorimetric heat balance calculation to Nuclear Instrumentation System (NIS) channel output and adjust if calorimetric power is > 2% higher than indicated NIS power.	24 hours
SR 3.3.1.3 ----- - NOTE - 1. Required to be performed within 7 days after THERMAL POWER is $\geq$ 50% RTP but prior to exceeding 90% RTP following each refueling and if the Surveillance has not been performed within the last 31 EFPD.  2. Performance of SR 3.3.1.6 satisfies this SR. ----- Compare results of the incore detector measurements to NIS AFD and adjust if absolute difference is $\geq$ 3%.	31 effective full power days (EFPD)

SURVEILLANCE		FREQUENCY
SR 3.3.1.4	Perform TADOT.	31 days on a STAGGERED TEST BASIS
SR 3.3.1.5	Perform ACTUATION LOGIC TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.1.6	<p>-----            - NOTE -            Not required to be performed until 7 days after THERMAL POWER is <math>\geq</math> 50% RTP, but prior to exceeding 90% RTP following each refueling.            -----</p> <p>Calibrate excore channels to agree with incore detector measurements.</p>	92 EFPD
SR 3.3.1.7	<p>-----            - NOTE -            Not required to be performed for source range instrumentation prior to entering MODE 3 from MODE 2 until 4 hours after entering MODE 3.            -----</p> <p>Perform COT.</p>	92 days
SR 3.3.1.8	<p>-----            - NOTE -            1. Not required for power range and intermediate range instrumentation until 4 hours after reducing power &lt; 6% RTP.            2. Not required for source range instrumentation until 4 hours after reducing power &lt; 5E-11 amps.            -----</p> <p>Perform COT.</p>	92 days
SR 3.3.1.9	<p>-----            - NOTE -            Setpoint verification is not required.            -----</p> <p>Perform TADOT.</p>	92 days

SURVEILLANCE		FREQUENCY
SR 3.3.1.10	<p>-----                      - NOTE -                      Neutron detectors are excluded.                      -----</p> <p>Perform CHANNEL CALIBRATION.</p>	24 months
SR 3.3.1.11	Perform TADOT.	24 months
SR 3.3.1.12	<p>-----                      - NOTE -                      Setpoint verification is not required.                      -----</p> <p>Perform TADOT.</p>	Prior to reactor startup if not performed within previous 31 days
SR 3.3.1.13	Perform COT.	24 months

Table 3.3.1-1  
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
1. Manual Reactor Trip	1, 2, 3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	2	B,C	SR 3.3.1.11	NA
2. Power Range Neutron Flux					
a. High	1, 2	4	D,G	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.10	≤ 109.27% RTP
b. Low	1 <sup>(c)</sup> , 2	4	D,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.10	≤ 29.28% RTP
3. Intermediate Range Neutron Flux	1 <sup>(c)</sup> , 2	2	E,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.10	(d)
4. Source Range Neutron Flux	2 <sup>(e)</sup>	2	F,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.10	(d)
	3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	2	H,I	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	(d)
	3 <sup>(f)</sup> , 4 <sup>(f)</sup> , 5 <sup>(f)</sup>	1	J	SR 3.3.1.1 SR 3.3.1.10	NA
5. Overtemperature ΔT	1, 2	4	D,G	SR 3.3.1.1 SR 3.3.1.3 SR 3.3.1.6 SR 3.3.1.7 SR 3.3.1.10	Refer to Note 1
6. Overpower ΔT	1, 2	4	D,G	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	Refer to Note 2



Table 3.3.1-1  
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
7. Pressurizer Pressure					
a. Low	1(g)	4	K,L	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥ 1791.3 psig
b. High	1, 2	3	D,G	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≤ 2396.2 psig
8. Pressurizer Water Level-High	1, 2	3	D,G	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≤ 96.47%
9. Reactor Coolant Flow-Low					
a. Single Loop	1(h)	3 per loop	M,O	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥ 89.86%
b. Two Loops	1(i)	3 per loop	K,L	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥ 89.86%
10. Reactor Coolant Pump (RCP) Breaker Position					
a. Single Loop	1(h)	1 per RCP	N,O	SR 3.3.1.11	NA
b. Two Loops	1(i)	1 per RCP	K,L	SR 3.3.1.11	NA
11. Undervoltage-Bus 11A and 11B	1(g)	2 per bus	K,L	SR 3.3.1.9 SR 3.3.1.10	(d)
12. Underfrequency-Bus 11A and 11B	1(g)	2 per bus	K,L	SR 3.3.1.9 SR 3.3.1.10	≥ 57.5 HZ

Table 3.3.1-1  
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
13. Steam Generator (SG) Water Level- Low Low	1, 2	3 per SG	D,G	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥ 13.88%
14. Turbine Trip					
a. Low Autostop Oil Pressure	1 <sup>(k)(l)</sup>	3	P,Q	SR 3.3.1.10 SR 3.3.1.12	(d)
b. Turbine Stop Valve Closure	1 <sup>(k)(l)</sup>	2	P,Q	SR 3.3.1.12	NA
15. Safety Injection (SI) Input from Engineered Safety Feature Actuation System (ESFAS)	1, 2	2	R,V	SR 3.3.1.11	NA

Table 3.3.1-1  
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
16. Reactor Trip System Interlocks					
a. Intermediate Range Neutron Flux, P-6	2 <sup>(e)</sup>	2	S,V	SR 3.3.1.10 SR 3.3.1.13	≥ 5E-11 amp
b. Low Power Reactor Trips Block, P-7	1 <sup>(g)</sup>	4 (power range only)	S,V	SR 3.3.1.10 SR 3.3.1.13	≤ 8.0% RTP
c. Power Range Neutron Flux, P-8	1 <sup>(h)</sup>	4	S,V	SR 3.3.1.10 SR 3.3.1.13	≤ 29.0% RTP
d. Power Range Neutron Flux, P-9	1 <sup>(l)</sup>	4	S,V	SR 3.3.1.10 SR 3.3.1.13	≤ 50.0% RTP
	1 <sup>(k)</sup>	4	S,V	SR 3.3.1.10 SR 3.3.1.13	≤ 8.0% RTP
e. Power Range Neutron Flux, P-10	1 <sup>(c)</sup> , 2	4	S,V	SR 3.3.1.10 SR 3.3.1.13	≥ 6.0% RTP
17. Reactor Trip Breakers <sup>(m)</sup>	1, 2 3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	2 trains 2 trains	T,V W,X	SR 3.3.1.4 SR 3.3.1.4	NA NA
18. Reactor Trip Breaker Undervoltage and Shunt Trip Mechanisms	1, 2 3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	1 each per RTB 1 each per RTB	U,V W,X	SR 3.3.1.4 SR 3.3.1.4	NA NA
19. Automatic Trip Logic	1, 2 3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	2 trains 2 trains	R,V W,X	SR 3.3.1.5 SR 3.3.1.5	NA NA

(a)

A channel is OPERABLE when both of the following conditions are met:

1. The absolute difference between the as-found Trip Setpoint (TSP) and the previous as-left TSP is within the COT Acceptance Criteria. The COT Acceptance Criteria is defined as:

$$|\text{as-found TSP} - \text{previous as-left TSP}| \leq \text{COT uncertainty}$$

The COT uncertainty shall not include the calibration tolerance.

2. The as-left TSP is within the established calibration tolerance band about the nominal TSP. The nominal TSP is the desired setting and shall not exceed the Limiting Safety System Setting (LSSS). The LSSS and the established calibration tolerance band are defined in accordance with the Ginna Instrument Setpoint Methodology. The channel is considered operable even if the as-left TSP is non-conservative with respect to the LSSS provided that the as-left TSP is within the established calibration tolerance band.
- (b) With Control Rod Drive (CRD) System capable of rod withdrawal or all rods not fully inserted.
- (c) THERMAL POWER < 6% RTP.
- (d) UFSAR Table 7.2-3.
- (e) Both Intermediate Range channels < 5E-11 amps.
- (f) With CRD System incapable of withdrawal and all rods fully inserted. In this condition, the Source Range Neutron Flux function does not provide a reactor trip, only indication.
- (g) THERMAL POWER  $\geq$  8.5% RTP.
- (h) THERMAL POWER  $\geq$  30% RTP.
- (i) THERMAL POWER  $\geq$  8.5% RTP and Reactor Coolant Flow-Low (Single Loop) trip Function blocked.
- (j) THERMAL POWER  $\geq$  8.5% RTP and RCP Breaker Position (Single Loop) trip Function blocked.
- (k) THERMAL POWER > 8% RTP, and either no circulating water pump breakers closed, or condenser vacuum  $\leq$  20".
- (l) THERMAL POWER  $\geq$  50% RTP, 1 of 2 circulating water pump breakers closed, and condenser vacuum > 20".
- (m) Including any reactor trip bypass breakers that are racked in and closed for bypassing an RTB.

Table 3.3.1-1 (Note 1)  
Overtemperature  $\Delta T$

- NOTE -

The Overtemperature  $\Delta T$  Function Limiting Safety System Setting is defined by:

$$\text{Overtemperature } \Delta T \leq \Delta T_0 \{K_1 + K_2 (P-P') - K_3 (T-T') [(1+\tau_1 s) / (1+\tau_2 s)] - f_1(\Delta I)\}$$

Where:

$\Delta T$  is measured RCS  $\Delta T$ , °F.

$\Delta T_0$  is the indicated  $\Delta T$  at RTP, °F.

$s$  is the Laplace transform operator,  $\text{sec}^{-1}$ .

$T$  is the measured RCS average temperature, °F.

$T'$  is the nominal  $T_{\text{avg}}$  at RTP, °F.

$P$  is the measured pressurizer pressure, psig.

$P'$  is the nominal RCS operating pressure, psig.

$K_1$  is the Overtemperature  $\Delta T$  reactor trip setpoint, [\*].

$K_2$  is the Overtemperature  $\Delta T$  reactor trip depressurization setpoint penalty coefficient, [\*]/psi.

$K_3$  is the Overtemperature  $\Delta T$  reactor trip heatup setpoint penalty coefficient, [\*]/°F.

$\tau_1$  is the measured lead time constant, [\*] seconds.

$\tau_2$  is the measured lag time constant, [\*] seconds.

$f_1(\Delta I)$  is a function of the indicated difference between the top and bottom detectors of the Power Range Neutron Flux channels where  $q_t$  and  $q_b$  are the percent power in the top and bottom halves of the core, respectively, and  $q_t + q_b$  is the total THERMAL POWER in percent RTP.

$$f_1(\Delta I) = [*] \{[*] - (q_t - q_b)\} \quad \text{when } q_t - q_b \leq [*]\% \text{ RTP}$$

$$f_1(\Delta I) = 0\% \text{ of RTP} \quad \text{when } [*]\% \text{ RTP} < q_t - q_b \leq [*]\% \text{ RTP}$$

$$f_1(\Delta I) = [*] \{(q_t - q_b) - [*]\} \quad \text{when } q_t - q_b > [*]\% \text{ RTP}$$

\* These values denoted with [\*] are specified in the COLR.

Table 3.3.1-1 (Note 2)  
Overpower  $\Delta T$

- NOTE -

The Overpower  $\Delta T$  Function Limiting Safety System Setting is defined by:

$$\text{Overpower } \Delta T \leq \Delta T_0 \{K_4 - K_5 (T-T') - K_6 [(\tau_3 s T) / (\tau_3 s + 1)] - f_2(\Delta I)\}$$

Where:

$\Delta T$  is measured RCS  $\Delta T$ , °F.

$\Delta T_0$  is the indicated  $\Delta T$  at RTP, °F.

$s$  is the Laplace transform operator,  $\text{sec}^{-1}$ .

$T$  is the measured RCS average temperature, °F.

$T'$  is the nominal  $T_{\text{avg}}$  at RTP, °F.

$K_4$  is the Overpower  $\Delta T$  reactor trip setpoint, [\*].

$K_5$  is the Overpower  $\Delta T$  reactor trip heatup setpoint penalty coefficient which is:

[\*]/°F for  $T < T'$  and;

[\*]/°F for  $T \geq T'$ .

$K_6$  is the Overpower  $\Delta T$  reactor trip thermal time delay setpoint penalty which is:

[\*]/°F for increasing  $T$  and;

[\*]/°F for decreasing  $T$ .

$\tau_3$  is the measured impulse/lag time constant, [\*] seconds.

$$f_2(\Delta I) = [*]$$

\* These values denoted with [\*] are specified in the COLR.

3.3 INSTRUMENTATION

3.3.2 Engineered Safety Feature Actuation System (ESFAS) Instrumentation

LCO 3.3.2 The ESFAS instrumentation for each Function in Table 3.3.2-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.2-1.

ACTIONS

- NOTE -

Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more Functions with one channel or train inoperable.	A.1 Enter the Condition referenced in Table 3.3.2-1 for the channel or train.	Immediately
B. As required by Required Action A.1 and referenced by Table 3.3.2-1.	B.1 Restore channel to OPERABLE status.	48 hours
C. Required Action and associated Completion Time of Condition B not met.	C.1 Be in MODE 2.	6 hours
D. As required by Required Action A.1 and referenced by Table 3.3.2-1.	D.1 Restore channel to OPERABLE status.	48 hours
E. As required by Required Action A.1 and referenced by Table 3.3.2-1.	E.1 Restore train to OPERABLE status.	6 hours

CONDITION		REQUIRED ACTION	COMPLETION TIME
F.	As required by Required Action A.1 and referenced by Table 3.3.2-1.	F.1 ----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of the other channels. -----  Place channel in trip.	6 hours
G.	Required Action and associated Completion Time of Condition D, E, or F not met.	G.1 Be in MODE 3. <u>AND</u> G.2 Be in MODE 4.	6 hours  12 hours
H.	As required by Required Action A.1 and referenced by Table 3.3.2-1.	H.1 Restore channel to OPERABLE status.	48 hours
I.	As required by Required Action A.1 and referenced by Table 3.3.2-1.	I.1 Restore train to OPERABLE status.	6 hours
J.	As required by Required Action A.1 and referenced by Table 3.3.2-1.	J.1 ----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of the other channels. -----  Place channel in trip.	6 hours
K.	Required Action and associated Completion Time of Condition H, I, or J not met.	K.1 Be in MODE 3. <u>AND</u> K.2 Be in MODE 5.	6 hours  36 hours



CONDITION	REQUIRED ACTION	COMPLETION TIME
L. As required by Required Action A.1 and referenced by Table 3.3.2-1.	L.1 ----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of the other channels. -----  Place channel in trip.	6 hours
M. Required Action and associated Completion Time of Condition L not met.	M.1 Be in MODE 3.  <u>AND</u>  M.2 Reduce pressurizer pressure to < 2000 psig.	6 hours   12 hours
N. As required by Required Action A.1 and referenced by Table 3.3.2-1.	N.1 Declare associated Auxiliary Feedwater pump inoperable and enter applicable condition(s) of LCO 3.7.5, "Auxiliary Feedwater (AFW) System."	Immediately

SURVEILLANCE REQUIREMENTS

-----  
- NOTE -  
-----

Refer to Table 3.3.2-1 to determine which SRs apply for each ESFAS Function.

SURVEILLANCE	FREQUENCY
SR 3.3.2.1 Perform CHANNEL CHECK.	12 hours
SR 3.3.2.2 Perform COT.	92 days
SR 3.3.2.3 ----- - NOTE - Verification of relay setpoints not required. ----- Perform TADOT.	92 days

SURVEILLANCE	FREQUENCY
SR 3.3.2.4      - NOTE - Verification of relay setpoints not required. Perform TADOT.	24 months
SR 3.3.2.5      Perform CHANNEL CALIBRATION.	24 months
SR 3.3.2.6      Verify the Pressurizer Pressure-Low and Steam Line Pressure-Low Functions are not bypassed when pressurizer pressure > 2000 psig.	24 months
SR 3.3.2.7      Perform ACTUATION LOGIC TEST.	24 months

Table 3.3.2-1  
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
1. Safety Injection					
a. Manual Initiation	1,2,3,4	2	D,G	SR 3.3.2.4	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	I,K	SR 3.3.2.7	NA
c. Containment Pressure-High	1,2,3,4	3	J,K	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≤ 4.61 psig
d. Pressurizer Pressure-Low	1,2,3 <sup>(b)</sup>	3	L,M	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5 SR 3.3.2.6	≥ 1729.8 psig
e. Steam Line Pressure-Low	1,2,3 <sup>(b)</sup>	3 per steam line	L,M	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5 SR 3.3.2.6	≥ 393.8 psig

Table 3.3.2-1  
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
<b>2. Containment Spray</b>					
a. Manual Initiation					
Left pushbutton	1,2,3,4	1	H,K	SR 3.3.2.4	NA
Right pushbutton	1,2,3,4	1	H,K	SR 3.3.2.4	NA
b. Automatic Actuation Logic and Actuation Relays					
	1,2,3,4	2 trains	I,K	SR 3.3.2.7	NA
c. Containment Pressure-High High					
	1,2,3,4	3 per set	J,K	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≤ 32.11 psig (narrow range) ≤ 29.6 psig (wide range)
<b>3. Containment Isolation</b>					
a. Manual Initiation					
	1,2,3,4, <sup>(c)</sup>	2	H,K	SR 3.3.2.4	NA
b. Automatic Actuation Logic and Actuation Relays					
	1,2,3,4	2 trains	I,K	SR 3.3.2.7	NA
c. Safety Injection					
	Refer to Function 1 (Safety Injection) for all automatic initiation functions and requirements.				

Table 3.3.2-1  
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
4. Steam Line Isolation					
a. Manual Initiation	1,2 <sup>(d)</sup> ,3 <sup>(d)</sup>	1 per loop	D,G	SR 3.3.2.4	NA
b. Automatic Actuation Logic and Actuation Relays	1,2 <sup>(d)</sup> ,3 <sup>(d)</sup>	2 trains	E,G	SR 3.3.2.7	NA
c. Containment Pressure-High High	1,2 <sup>(d)</sup> ,3 <sup>(d)</sup>	3	F,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≤ 18.0 psig
d. High Steam Flow	1,2 <sup>(d)</sup> ,3 <sup>(d)</sup>	2 per steam line	F,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≤ 1.30E6 lbm/hr @ 1005 psig
Coincident with Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				
and					
Coincident with T <sub>avg</sub> -Low	1,2 <sup>(d)</sup> ,3 <sup>(d)</sup>	2 per loop	F,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≥ 544.0°F
e. High-High Steam Flow	1,2 <sup>(d)</sup> ,3 <sup>(d)</sup>	2 per steam line	F,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≤ 4.53E6 lbm/hr @ 785 psig
Coincident with Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				

Table 3.3.2-1  
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
5. Feedwater Isolation					
a. Automatic Actuation Logic and Actuation Relays	1,2 <sup>(e)</sup> ,3 <sup>(e)</sup>	2 trains	E,G	SR 3.3.2.7	NA
b. SG Water Level-High	1,2 <sup>(e)</sup> ,3 <sup>(e)</sup>	3 per SG	F,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≤ 91.15%
c. Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				

Table 3.3.2-1  
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
6. Auxiliary Feedwater (AFW)					
a. Manual Initiation					
AFW	1,2,3	1 per pump	N	SR 3.3.2.4	NA
Standby AFW	1,2,3	1 per pump	N	SR 3.3.2.4	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3	2 trains	E,G	SR 3.3.2.7	NA
c. SG Water Level-Low Low	1,2,3	3 per SG	F,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≥ 13.88%
d. Safety Injection (Motor driven pumps only)	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				
e. Undervoltage - Bus 11A and 11B (Turbine driven pump only)	1,2,3	2 per bus	D,G	SR 3.3.2.3 SR 3.3.2.5	≥ 2597 V with ≤ 3.6 sec time delay
f. Trip of Both Main Feedwater Pumps (Motor driven pumps only)	1	2 per MFW pump	B,C	SR 3.3.2.4	NA

(a)

A channel is OPERABLE ~~when~~ both of the following conditions are met:

1. The absolute difference ~~between~~ the as-found Trip Setpoint (TSP) and the previous as-left TSP is within the COT Acceptance Criteria. The COT Acceptance Criteria is defined as:

$$|\text{as-found TSP} - \text{previous as-left TSP}| \leq \text{COT uncertainty}$$

The COT uncertainty shall not include the calibration tolerance.

2. The as-left TSP is within ~~the~~ established calibration tolerance band about the nominal TSP. The nominal TSP ~~is~~ the desired setting and shall not exceed the Limiting Safety System Setting (LSSS). The LSSS and the established calibration tolerance band are defined in accordance ~~with~~ the Ginna Instrument Setpoint Methodology. The channel is considered operable ~~even~~ if the as-left TSP is non-conservative with respect to the LSSS ~~provided that the~~ as-left TSP is within the established calibration tolerance band.

- (b) Pressurizer Pressure  $\geq$  2000 psig.
- (c) During CORE ALTERATIONS and movement of irradiated fuel assemblies within containment.
- (d) Except when both MSIVs are closed and de-activated.
- (e) Except when all Main Feedwater Regulating and associated bypass valves are closed and de-activated or isolated by a closed manual valve.



3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.10 Pressurizer Safety Valves

LCO 3.4.10 Two pressurizer safety valves shall be OPERABLE with lift settings  $\geq 2410$  psig and  $\leq 2542$  psig.

APPLICABILITY: MODES 1, 2, and 3,  
MODE 4 with all RCS cold leg temperatures greater than the LTOP enable temperature specified in the PTLR.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One pressurizer safety valve inoperable.	A.1 Restore valve to OPERABLE status.	15 minutes
B. Required Action and associated Completion Time not met.  <u>OR</u>  Both pressurizer safety valves inoperable.	B.1 Be in MODE 3.  <u>AND</u>  B.2 Be in MODE 4 with any RCS cold leg temperature less than or equal to the LTOP enable temperature specified in the PTLR.	6 hours   12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.10.1</p> <p style="text-align: center;">----- - NOTE - -----</p> <p>Required to be performed within 36 hours of entering MODE 4 from MODE 5 with all RCS cold leg temperatures greater than the LTOP enable temperature specified in the PTLR for the purpose of setting the pressurizer safety valves under ambient (hot) conditions only provided a preliminary cold setting was made prior to heatup.</p> <p>-----</p> <p>Verify each pressurizer safety valve is OPERABLE in accordance with the Inservice Testing Program. Following testing, lift settings shall be within <math>\pm 1\%</math>.</p>	<p>In accordance with the Inservice Testing Program</p>

3.7 PLANT SYSTEMS

3.7.6 Condensate Storage Tanks (CSTs)

LCO 3.7.6 The CSTs shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. CST water volume not within limit.	A.1 Verify by administrative means OPERABILITY of backup water supply.	4 hours
	<u>AND</u> A.2 Restore CST water volume to within limit.	7 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u> B.2 Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.6.1 Verify the CST water volume is $\geq 24,350$ gal.	12 hours