

Component to be Worked:

SW -STNR -B
SERVICE WATER ZURN STRAINER B
IS-SWP RM



RH-5A30

Description:

DISASSEMBLE & CLEAN & REPAIR.
ADMIN OOS LIMIT OF 10 DAYS.

Special Instructions

MANUAL DRAIN (SW-V-15) NO-TAGGED TO ALLOW DRAINING AS NEEDED BEFORE OR DURING MAINTENANCE.
DRAIN FOR ~10 MINUTES, THEN CLOSE DURING INITIAL TAGGING.

Worker Notes

LCO ACTIONS REQUIRED FOR THIS WORK. REMOVE STRAINER FROM SERVICE PER 2.2.71 PRIOR TO HANGING TAGOUT. Temporary Air is to be applied to SW-858AV keep it closed.

Release Notes

ENSURE TEMPORARY AIR SUPPLY HAS BEEN REMOVED.
RELEASE TAGS AND RESTART STRAINER IAW 2.2.71.

Section Attributes:

Attribute Description	Attribute Value
MRRS	Yes
LCO ACTION REQUIRED	Yes
FIRE IMPAIRMENT REQUIRED	Yes
CONTAINMENT AFFECTED	No
REQUIRED PLANT CONDITIONS	B ZURN STRAINER BYPASSED

Work Order List:

Number / Equipment ID	Description
4324147	EXAMINE STRAINER SW-STNR-B

Section Verification:

Status	Description	Name	Verification Date
	Section Prepared	Reed, Daniel W.	12/17/2003 09:28
	Section Verified	Weiss, Jamie R.	01/04/2004 22:23
	Section Authorized	Gilbert, William T.	01/21/2004 02:36
	Equip. Ready for Maintenance	Cable, Brian E.	01/21/2004 05:54
	Release Prepared	Cable, Brian E.	01/21/2004 05:59
	Release Verified	Weiss, Jamie R.	01/21/2004 09:10
	Release Authorized	Beger, Nathan L.	01/21/2004 15:53
	Section Complete	Weiss, Jamie R.	01/21/2004 16:58

Temporary Safety Devices List:

J-29

Section Tag List

Tagout: CLEARANCE ORDER

Section: SWB -1-4324147 SW-STNR-B -

03/10/2004 13:0

Tag Serial No.	Tag Type	Equipment ----- * Equipment Description * Equipment Location	Pla Seq	Placement Configuration ----- * Notes	Place: 1st Verif Date/Time	Place: 2nd Verif Date/Time	Rest Seq	Restoration Configuration ----- * Notes	As Left Configuration	Rest: 1st Verif Date/Time	Rest: 2nd Verif Date/Time
35256	Danger	SW -SW -S192(PB1) ----- * START SWITCH FOR B&D SW STRAINER * B SW ZURN STRAINER AREA	1	DO NOT OPERATE -----	Hung - Unruh, Michael J.; 01/21/2004 05:46	Hung - Knowles, Timothy A.; 01/21/2004 05:48	7	PULL TAG ----- * Restore per 2.2.71	PULL TAG	- Carpenter, Christopher M.; 01/21/2004 16:36	- Hayes, Martin "Marty" F.; 01/21/2004 16:36
35257	Danger	EE -MCC -TX(1DL) ----- * SW-STNR-B SW STRAINER B CONTROL PANEL FEEDER * MCC-TX AUX RELAY ROOM	2	OFF -----	Hung - Unruh, Michael J.; 01/21/2004 05:46	Hung - Knowles, Timothy A.; 01/21/2004 05:48	6	ON -----	ON	- Carpenter, Christopher M.; 01/21/2004 16:36	- Hayes, Martin "Marty" F.; 01/21/2004 16:36
35258	Danger	SW -V -194 ----- * SW STRAINER B BYPASS * B & D SW PUMP AREA	3	OPEN -----	Hung - Unruh, Michael J.; 01/21/2004 05:46	Hung - Knowles, Timothy A.; 01/21/2004 05:48	5	CLOSED -----	CLOSED	- Carpenter, Christopher M.; 01/21/2004 16:36	- Hayes, Martin "Marty" F.; 01/21/2004 16:36
35259	Danger	SW -V -17 ----- * SW STRAINER B OUTLET * B & D SW PUMP AREA	4	CLOSED -----	Hung - Unruh, Michael J.; 01/21/2004 05:46	Hung - Knowles, Timothy A.; 01/21/2004 05:48	4	SEALED OPEN -----	SEALED OPEN	- Carpenter, Christopher M.; 01/21/2004 16:36	- Hayes, Martin "Marty" F.; 01/21/2004 16:36
35260	Danger	SW -V -192 ----- * SW STRAINER B INLET * B & D SW PUMP AREA	5	CLOSED -----	Hung - Unruh, Michael J.; 01/21/2004 05:46	Hung - Knowles, Timothy A.; 01/21/2004 05:48	3	SEALED OPEN -----	SEALED OPEN	- Carpenter, Christopher M.; 01/21/2004 16:36	- Hayes, Martin "Marty" F.; 01/21/2004 16:36
35261	No Tag	SW -V -15 ----- * SW STRAINER B BACKWASH * B & D SW PUMP AREA	6	----- * VALVE SILTS IN, THROTTLE CLOSED TILL FULL CLOSED			2	CLOSED -----	CLOSED	- Carpenter, Christopher M.; 01/21/2004 16:36	- Hayes, Martin "Marty" F.; 01/21/2004 16:36
35262	No Tag	SW -V -1378 ----- * SW-858AV ISOLATION * A & C SW PUMP AREA	7	-----			1	OPEN -----	OPEN	- Carpenter, Christopher M.; 01/21/2004 16:36	- Hayes, Martin "Marty" F.; 01/21/2004 16:36

Section Tag List

Tagout: CLEARANCE ORDER

Section: SWB -1-4324147 SW-STNR-B -

03/10/2004-13:0

Component	Note No.	Note Text
SW -SW -S192(PB1)	3	MRRS
EE -MCC -TX(1DL)	3	MRRS
SW -V -194	3	MRRS
SW -V -17	3	MRRS
SW -V -192	3	MRRS
SW -V -15	3	MRRS
SW -V -1378	3	MRRS

Component	Print Number
EE -MCC -TX(1DL)	B5700*3006
EE -MCC -TX(1DL)	B5700*3253
EE -MCC -TX(1DL)	I2020*85B-70008
SW -V -194	B5700*2006 SHT1
SW -V -194	P3400*B-99
SW -V -17	B5700*2006 SHT1
SW -V -17	P3400*B-102
SW -V -192	B5700*2006 SHT1
SW -V -192	P3400*B-102
SW -V -15	A3950*856-3
SW -V -15	B5700*2006 SHT1
SW -V -1378	B5700*2006 SHT1

Section Holder List

Tagout: CLEARANCE ORDER

Section: SWB -1-4324147 SW-STNR-B

03/10/2004 13:0

Accepted By	Accepted At	Signed On By	Released By	Released At
Peters, Marvin E.	01/21/2004 06:00	Peters, Marvin E.	Peters, Marvin E.	01/21/2004 15:46
Mason, Eric D.	01/21/2004 06:24	Mason, Eric D.	Mason, Eric D.	01/21/2004 15:04

Work Order Holder List

Tagout: CLEARANCE ORDER

Section: SWB -1-4324147 SW-STNR-B -

03/10/2004 13:0

Number: 4324147

Status:

Percent Complete:

EXAMINE STRAINER SW-STNR-B

Holder	Signed On By	Sign On Date	Signed Off By	Sign Off Date
Lewis, Dave	Lewis, Dave	01/21/2004 06:26	Lewis, Dave	01/21/2004 14:57
Sullwold, Kim D.	Sullwold, Kim D.	01/21/2004 06:03	Sullwold, Kim D.	01/21/2004 12:31