

July 19, 2006

Mr. Karl W. Singer  
Chief Nuclear Officer and  
Executive Vice President  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNITS 2 AND 3 — REQUEST FOR  
ADDITIONAL INFORMATION FOR EXTENDED POWER UPRATE - ROUND 7  
(TS-431) (TAC NOS. MC3743 AND MC3744)

Dear Mr. Singer:

By letter dated June 28, 2004, as supplemented by letters dated August 23, 2004, February 23, April 25, June 6, and December 19, 2005, February 1 and 28, March 7, 9, 23, and 31, April 13, May 5 and 11, and June 12, 15 and 23, 2006, Tennessee Valley Authority submitted to the U.S. Nuclear Regulatory Commission (NRC) an amendment request for Browns Ferry Nuclear Plant, Units 2 and 3. The proposed amendments would change the Units 2 and 3 operating licenses to increase the maximum authorized power level from 3458 to 3952 megawatts thermal. This change represents an increase of approximately 15 percent above the current maximum authorized power level. The proposed amendments would also change the Units 2 and 3 licensing bases to revise the credit for overpressure from 3 pounds for short-term and 1 pound for long-term, to 3 pounds for the duration of a loss-of-coolant accident, and revise the maximum ultimate heat sink temperature.

The request for additional information was informally provided to your staff on June 15, 2006. A response to the enclosed request for additional information is needed before the NRC staff can complete the review. If you have any questions, please contact me at (301) 415-2315.

Sincerely,

*/RA/*

Eva A. Brown, Project Manager  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-260 and 50-296

Enclosures:

1. Redacted Request for Additional Information
2. Proprietary Request for Additional Information

cc w/Enclosure 1 only: See next page

July 19, 2006

Mr. Karl W. Singer  
Chief Nuclear Officer and  
Executive Vice President  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNITS 2 AND 3 — REQUEST FOR  
ADDITIONAL INFORMATION FOR EXTENDED POWER UPRATE - ROUND 7  
(TS-431) (TAC NOS. MC3743 AND MC3744)

Dear Mr. Singer:

By letter dated June 28, 2004, as supplemented by letters dated August 23, 2004, February 23, April 25, June 6, and December 19, 2005, February 1 and 28, March 7, 9, 23, and 31, April 13, May 5 and 11, and June 12, 15 and 23, 2006, Tennessee Valley Authority submitted to the U.S. Nuclear Regulatory Commission (NRC) an amendment request for Browns Ferry Nuclear Plant, Units 2 and 3. The proposed amendments would change the Units 2 and 3 operating licenses to increase the maximum authorized power level from 3458 to 3952 megawatts thermal. This change represents an increase of approximately 15 percent above the current maximum authorized power level. The proposed amendments would also change the Units 2 and 3 licensing bases to revise the credit for overpressure from 3 pounds for short-term and 1 pound for long-term, to 3 pounds for the duration of a loss-of-coolant accident, and revise the maximum ultimate heat sink temperature.

The request for additional information was informally provided to your staff on June 15, 2006. A response to the enclosed request for additional information is needed before the NRC staff can complete the review. If you have any questions, please contact me at (301) 415-2315.

Sincerely,  
*/RA/*

Eva A. Brown, Project Manager  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-260 and 50-296

Enclosures:

1. Redacted Request for Additional Information
2. Proprietary Request for Additional Information

cc w/Enclosure 1 only: See next page

DISTRIBUTION: see next page

Package No.: ML061980163

Enclosure 2: ML061980313

ADAMS Accession No.: ML061980144

NRR-106

OFFICE	LPL2-2/PM	LPL2-2/LA	EEEE/BC	EEMB/BC
NAME	EBrown	RSola for BClayton	GWilson by memo	KManoly by memo
DATE	07/18/06	07/18/06	06/21/06	06/8/06

OFFICE	LPL2-2/BC
NAME	MMarshall
DATE	07/18/06

**OFFICIAL RECORD COPY**

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNITS 2 AND 3 — REQUEST FOR  
ADDITIONAL INFORMATION FOR EXTENDED POWER UPRATE - ROUND 7  
(TS-431) (TAC NOS. MC3743 AND MC3744)

Document Date:

DISTRIBUTION:

PUBLIC

RidsNrrDorlLpl2-2

RidsNrrLABClayton

RidsNrrPMMChernoff

RidsNrrPMEBrown

RidsAcrsAcnwMailCenter

RidsRgn2MailCenter

J. Moore, OGC

RidsNrrDorl

RidsNrrDorlDpr

LPL2-2 R/F

RidsNrrDeEeeb

T. Alexion, NRR

O. Chopra, NRR

RidsNrrDeEemb

RidsOgcRp

C. Wu, NRR

T. Scarbrough, NRR



and their frequency content. Include a discussion of why, when and how 1/6th scale models are used for modeling the safety relief valves (S/RVs).

17. [redacted] because they cannot be accurately modeled at 1/17 scale. Discuss what, if any, flow-induced vibration (FIV) excitation mechanisms are precluded by this distortion.
18. As mentioned on pages 71, 74, and 114 of the SMT Report, [redacted]. Explain how the waterline is modeled, changes that are planned, and the effects of potential distortions on pressures and acoustic mode shapes. The response should take into account that acoustic circuit analysis (ACA) has shown that this water-steam interface's damping significantly affects pressure predictions.
19. As mentioned on pages 70 and 75 of the SMT Report, [redacted], which the report states will attenuate fluid flow oscillations. Elaborate on how this distortion will affect SMT pressures and what changes could be made to model more prototypic conditions. The reply should take into account that ACA analysis has shown that the steam dome and MSL steam damping significantly affects pressure predictions.
20. As mentioned on pages 70, 71, and 74 of the SMT Report, the array of steam separators in the reactor are described to act like a muffler and the vane bundles which provide some attenuation to acoustic waves. [redacted]. Explain how these boundary conditions are represented in the SMT. Also, explain how the differences between the actual boundary conditions and those modeled in the SMT affect the pressures and acoustic mode shapes.
21. As mentioned on pages 72, 73, 75, and 104 of the SMT Report, [redacted]. Also, the piping layouts between the S/RVs and the main steam isolation valves (MSIVs) are not prototypic. [redacted]. Elaborate on the sensitivity of the turbulence noise excitation mechanism created by these model distortions. Include in the response similar considerations for the turbine control valves (TCVs) and turbine stop valves (TSVs). Discuss the adequacy of the modeling of these components.
22. In reference to the discussion on page 46 of the SMT Report, discuss potential periodicities created in the flow resulting from the multiple jets emanating from the top of the dryer into the steam dome.
23. In reference to the discussion on page 49 and in Appendix A of the SMT Report, explain the potential excitation mechanisms within the steam dome and their significance in term of the need to understand their source and impact. Address the dependence of these mechanisms on Reynolds number (Re) and their possible distortion in the SMT.
24. In reference to the discussion on page 138 of the SMT Report, address how the time shifts are formulated in the stress analyses using an SMT load definition [redacted].



and P3 are on one side of the steam dryer and sensors P9, P10, and P11 are in a similar location on the other side of the dryer, discuss why the trends in Table 11 are not similar for the groups. Discuss why there are not similar pressure trends for sensors in symmetric locations.

32. Discuss the potential effects on the S/RVs from possible resonant frequencies that could occur, leading to valve failures. Effects due to vortex shedding were examined for the steam dryer; discuss whether this anomaly would exist in the valves.
33. Regarding uncertainty analysis, discuss whether the uncertainties in the venturi calculation from the manufacturer taken into account (accuracy, resolution, and propagated errors). For the exponential pressure/velocity relationship, discuss the basis for the exponent [\_\_\_\_\_].
34. The SMT Report indicates that the SMT [\_\_\_\_\_]. In some cases, the SMT data trended in the opposite direction from the QC2 plant data. See Table 11 (75 percent underprediction from 150-162 Hz) and Figures 75 to 98, 109, 112, 117, and 120. Discuss the basis for reliance on the SMT in predicting steam dryer loading in Browns Ferry Nuclear Plant (BFN) in light of these [\_\_\_\_\_].
35. On page 175, the SMT Report states that the SMT amplitude measurements associated with S/RV resonances [\_\_\_\_\_]. Discuss the reliability of this effort based on the significant underprediction of the QC2 plant data by the SMT and the nonlinearity of the data.
36. On page 175 of the SMT Report, the vendor recommends power ascension monitoring in light of the error in the SMT load prediction. Discuss the plans to address this recommendation.
37. Page 19 of the SMT Report states that additional work is on-going to improve the accuracy of the load predictions. Discuss the status and success of this additional work.
38. In reference to Table 3-6 and Section 3.3.4, Reactors Internal Structural Evaluation of the PUSAR, the reactor internal components such as shroud, shroud support, core plate, top guide, orificed fuel support, fuel channel, jet pump, core spray line and sparger, incore housing and guide tube, vessel head cooling spray nozzle, jet pump instrument penetration, core differential pressure and standby liquid control line and CRD were evaluated qualitatively for the EPU condition. Provide a quantitative evaluation by comparing the key parameters and design transients, loads and load combinations that are used in the design basis analysis report for stresses and cumulative usage factors in each component, against the EAU condition. Confirm whether and how the design basis parameters envelop those of the EAU condition.
39. Section 3.3.5, Flow Induced Vibration, of the PUSAR, states that analyses performed to evaluate the effects of FIV on the reactor internals at EAU conditions were based on vibration data obtained during startup testing of a prototype plant (Browns Ferry Unit 1) or of similar boiling water reactor (BWR) plants. The expected vibration levels for EAU were estimated by extrapolating the vibration data recorded in the prototype plant or

similar plants and on GE BWR operating experience. These expected vibration levels were then compared with the established vibration acceptance limits. For the proposed EAU operation at BFN Units 2 and 3, the components in the upper zone of the reactor, such as the moisture separators and dryer, are mostly affected by the increased steam flow. The adverse effects of increased steam flow on the steam dryer is evaluated in a separate analysis. Provide a summary of the quantitative evaluation for the effects of flow induced vibration on steam separators for the proposed EAU condition at Units 2 and 3.

40. Section 3.5, Reactor Coolant Pressure Boundary (RCPB) Piping, of the PUSAR indicates that the effects of the EAU have been evaluated for the RCPB piping systems and their supports. Other than the main steam (MS) and Feedwater system, the RCPB piping systems are not significantly affected by the proposed constant operating pressure power uprate (CPPU) at Units 2 and 3. Provide the maximum calculated stress and fatigue usage factors at the current rated and the CPPU conditions in comparison with the Code allowable limits for the feedwater piping and the main steam and the branch piping connected to the MS headers.
41. Section 3.5 of the PUSAR states that the supporting structure for the MS piping system is currently being evaluated for increased loading associated with the limiting transient at EAU conditions. Any supporting structure modifications deemed necessary due to EAU increased transient loads will be completed prior to EAU implementation. Provide the results of the evaluation and identify the supports that are added or modified for the proposed power uprate condition for the RCPB piping systems.
42. In Section 3.4 of the PUSAR states that the reactor recirculation system (RRS) components (e.g., pumps and valves) will be evaluated at EAU conditions to ensure that safety and design objectives are met. Provide a summary of the evaluation for the reactor recirculation pumps and valves at the EAU condition. Discuss the effects of EAU on vibration due to the vane-passing frequency of the RRS pump to accommodate the increase in thermal power. Confirm whether a modification is required for the RRS piping and supports after the EAU and identify the modification if any.
43. Section 3.11, Balance-of-Plant Piping (BOP) Evaluation, of the PUSAR indicates that for EAU conditions, the loss-of-coolant accident (LOCA) torus shell response loads were reevaluated using a more realistic reactor pressure vessel (RPV) depressurization to within the capability of the available number of main steam relief valves. These loads were found to be acceptable and there are no adverse effects on the torus shell attached structures. Discuss the EAU LOCA loads using the more realistic RPV depressurization in comparison with the LOCA loads originally defined for Units 2 and 3.
44. Section 3.11 of the PUSAR indicates that, for those BOP piping analyzed, the maximum stress levels and fatigue analysis results were reviewed for the increases in temperature, pressure and flow rate. Provide the maximum calculated stresses and fatigue usage factors for the evaluated BOP piping systems, including those attached to the torus shell.
45. Section 3.11 and Table 3-7c of the PUSAR indicates that no results were provided associated with the percentage increase in the MS piping stress because the TSV



transient was not considered previously for Browns Ferry. Provide the maximum stresses and fatigue usage factors resulting from the EAU evaluation for the BOP main steam piping outside the containment in comparison with the code allowable limits. Confirm whether any modifications are required for the BOP piping and supports following the EAU at BFN. Identify these modifications if any.

Mr. Karl W. Singer  
Tennessee Valley Authority  
cc:

**BROWNS FERRY NUCLEAR PLANT**

Mr. Ashok S. Bhatnagar, Senior Vice President  
Nuclear Operations  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Robert G. Jones, General Manager  
Browns Ferry Site Operations  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609

Mr. Larry S. Bryant, Vice President  
Nuclear Engineering & Technical Services  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Glenn W. Morris, Manager  
Corporate Nuclear Licensing  
and Industry Affairs  
Tennessee Valley Authority  
4X Blue Ridge  
1101 Market Street  
Chattanooga, TN 37402-2801

Brian O'Grady, Site Vice President  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609

Mr. William D. Crouch, Manager  
Licensing and Industry Affairs  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609

Mr. Robert J. Beecken, Vice President  
Nuclear Support  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Browns Ferry Nuclear Plant  
10833 Shaw Road  
Athens, AL 35611-6970

General Counsel  
Tennessee Valley Authority  
ET 11A  
400 West Summit Hill Drive  
Knoxville, TN 37902

State Health Officer  
Alabama Dept. of Public Health  
RSA Tower - Administration  
Suite 1552  
P.O. Box 303017  
Montgomery, AL 36130-3017

Mr. John C. Fornicola, Manager  
Nuclear Assurance and Licensing  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Chairman  
Limestone County Commission  
310 West Washington Street  
Athens, AL 35611

Mr. Bruce Aukland, Plant Manager  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609