



R2-B86

Westinghouse
Electric Company

Nuclear Fuel

Drawer R
Columbia SC 29250
(803) 647-1000

ISE-REF-2002-013

August 6, 2002

U.S. Nuclear Regulatory Commission
ATTN: Mr. ~~William J. Stover~~
Atlanta Federal Center
61 Forsyth Street
Atlanta, Georgia 30303

Dear Mr. Gloerson:


RE: NRC License SNM 1107 (70-1151)
Reporting SC-DHEC NPDES Permit # SC001848
Notice of Exceedance

Attached with this report is the discharge monitoring report sent to South Carolina Department of Health and Environmental Control documenting an exceedance of our NPDES Permit limitations for the month of June 2002. The BOD5 parameter exceeded the permit Daily Average limit for the month of June 2002. All BOD5 results since that date have met permit limitations.

If you have any questions concerning this report, please contact me at (803) 647-3671.

Sincerely,

Westinghouse Electric Company


Roger E. Fischer
Senior Engineer

FILE

70-1151/5.4

C-42