

July 24, 2006

Mr. Gary Van Middlesworth  
Vice President  
Duane Arnold Energy Center  
3277 DAEC Road  
Palo, Iowa 52324-9785

SUBJECT: DUANE ARNOLD ENERGY CENTER - REQUEST FOR ADDITIONAL  
INFORMATION RELATED TO THE PROPOSED AMENDMENT TO REVISE  
THE LIMITING CONDITION FOR OPERATION (LCO) 3.10.1  
(TAC NO. MD0293)

Dear Mr. Van Middlesworth:

Your letter of March 1, 2006, submitted a proposed amendment to revise the limiting condition for operation 3.10.1, to allow ancillary testing to occur during the evolutions associated with performing the American Society of Mechanical Engineers Code Class I leak test of the reactor pressure vessel, at the Duane Arnold Energy Center.

We are reviewing this information, and find that we need additional information as shown in the enclosed request for additional information (RAI). I discussed this RAI with Tony Browning of your organization on July 18, 2006, and he agreed to respond within 30 days of receipt of this RAI. Please contact me at (301) 415-2928 if you have questions.

Sincerely,

**/RA/**

Deirdre W. Spaulding, Project Manager  
Plant Licensing Branch III-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosure:  
RAI

cc w/encl: See next page

Mr. Gary Van Middlesworth  
Vice President  
Duane Arnold Energy Center  
3277 DAEC Road  
Palo, Iowa 52324-9785

July 24, 2006

SUBJECT: DUANE ARNOLD ENERGY CENTER - REQUEST FOR ADDITIONAL  
INFORMATION RELATED TO THE PROPOSED AMENDMENT TO REVISE  
THE LIMITING CONDITION FOR OPERATION (LCO) 3.10.1  
(TAC NO. MD0293)

Dear Mr. Van Middlesworth:

Your letter of March 1, 2006, submitted a proposed amendment to revise the limiting condition for operation 3.10.1, to allow ancillary testing to occur during the evolutions associated with performing the American Society of Mechanical Engineers Code Class I leak test of the reactor pressure vessel, at the Duane Arnold Energy Center.

We are reviewing this information, and find that we need additional information as shown in the enclosed request for additional information (RAI). I discussed this RAI with Tony Browning of your organization on July 18, 2006, and he agreed to respond within 30 days of receipt of this RAI. Please contact me at (301) 415-2928 if you have questions.

Sincerely,

**/RA/**

Deirdre W. Spaulding, Project Manager  
Plant Licensing Branch III-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosure:  
RAI

cc w/encl: See next page

DISTRIBUTION:

PUBLIC                      LPL3-1 R/F                      RidsNrrPMDSpaulding                      RidsNrrLATHarris  
RidsNrrDorlLple                      RidsOgcRp                      RidsAcrsAcnwMailCenter                      RidsRgn3MailCenter  
RidsNrrDorlDpr                      ALewin                      JGilmer                      TBoyce

ADAMS Accession Number: **ML061990634**

OFFICE	NRR/LPL3-1/PM	NRR/LPL3-1/LA	NRR/LPL3-1/BC
NAME	DSpaulding	THarris	LRaghavan
DATE	07/21/06	07/20/06	07/24/06

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION  
RELATED TO THE PROPOSED AMENDMENT TO  
REVISE THE LIMITING CONDITION FOR OPERATION (LCO) 3.10.1  
DUANE ARNOLD ENERGY CENTER  
DOCKET NO. 50-331

1. LCO 3.10.1 Rev 3.1a would allow testing in Mode 4 with average reactor coolant temperature drifting greater than 200 F as a result of decay heat. Primary containment requirements are relaxed in LCO 3.10.1 Rev 3.0 with the reasoning in the technical specification (TS) Bases that average reactor coolant temperature is greater than 200 F as a result of testing and not due to significant decay heat. Please explain why it is acceptable to be in Mode 4 (with average reactor coolant temperature greater than 200 F) vice Mode 3 with the presence of decay heat contributing to an increase in the average reactor coolant temperature.
2. LCO 3.4.7 "RCS Specific Activity," is normally not required in Mode 4 because the reactor is normally not pressurized. Please provide justification for not including LCO 3.4.7 under LCO 3.10.1 Rev 3.1a requirements when in Mode 4 with average reactor coolant temperature greater than 200 F.
3. The Bases for TS 3.10.1 Rev 3.1a discusses conducting other unnamed testing while the TS 3.10.1 Rev 3.1a specifically mentions conducting only inservice leak or hydrostatic tests and control rod scram time tests. Please elaborate on the intent of the TS and Bases as written with regards to "other testing."
4. The use of the verbiage "as a consequence of" in the LCO under TS 3.10.1 Rev 3.1a could result in steady state Mode 4 with reactor coolant temperature > 200 F even though testing is over and no longer being conducted. This seems to be the reasoning for eliminating the statement in the Bases for TS 3.10.1 Rev 3.0 which states that normal Mode 4 requirements are in effect immediately prior to and immediately after LCO 3.10.1 operations. Please elaborate on what would require returning to normal Mode 4 requirements after testing is completed.

ENCLOSURE

Duane Arnold Energy Center

cc:

Mr. J. A. Stall  
Senior Vice President, Nuclear and Chief  
Nuclear Officer  
Florida Power & Light Company  
P. O. Box 14000  
Juno Beach, FL 33408-0420

Mr. M. S. Ross  
Managing Attorney  
Florida Power & Light Company  
P. O. Box 14000  
Juno Beach, FL 33408-0420

Mr. R. E. Helfrich  
Senior Attorney  
Florida Power & Light Company  
P. O. Box 14000  
Juno Beach, FL 33408-0420

Mr. W. E. Webster  
Vice President, Nuclear Operations  
Florida Power & Light Company  
P. O. Box 14000  
Juno Beach, FL 33408-0420

John Bjorseth  
Site Director  
Duane Arnold Energy Center  
3277 DAEC Road  
Palo, IA 52324

Steven R. Catron  
Manager, Regulatory Affairs  
Duane Arnold Energy Center  
3277 DAEC Road  
Palo, IA 52324

U. S. Nuclear Regulatory Commission  
Resident Inspector's Office  
Rural Route #1  
Palo, IA 52324

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
Suite 210  
2443 Warrenville Road  
Lisle, IL 60532-4351

Mr. M. Warner  
Vice President, Nuclear Operations  
Support  
Florida Power & Light Company  
P. O. Box 14000  
Juno Beach, FL 33408-0420

Mr. D. A. Curtland  
Plant Manager  
Duane Arnold Energy Center  
3277 DAEC Rd.  
Palo, IA 52324-9785

Mr. R. S. Kundalkar  
Vice President, Nuclear Engineering  
Florida Power & Light Company  
P. O. Box 14000  
Juno Beach, FL 33408-0420

Daniel McGhee  
Utilities Division  
Iowa Department of Commerce  
Lucas Office Buildings, 5th Floor  
Des Moines, IA 50319

Chairman, Linn County  
Board of Supervisors  
930 1st Street SW  
Cedar Rapids, IA 52404