

July 24, 2006

Mr. Gary Van Middlesworth
Vice President
Duane Arnold Energy Center
3277 DAEC Road
Palo, Iowa 52324-9785

SUBJECT: DUANE ARNOLD ENERGY CENTER - REQUEST FOR ADDITIONAL
INFORMATION RELATED TO THE PROPOSED AMENDMENT TO REVISE
THE LIMITING CONDITION FOR OPERATION (LCO) 3.10.1
(TAC NO. MD0293)

Dear Mr. Van Middlesworth:

Your letter of March 1, 2006, submitted a proposed amendment to revise the limiting condition for operation 3.10.1, to allow ancillary testing to occur during the evolutions associated with performing the American Society of Mechanical Engineers Code Class I leak test of the reactor pressure vessel, at the Duane Arnold Energy Center.

We are reviewing this information, and find that we need additional information as shown in the enclosed request for additional information (RAI). I discussed this RAI with Tony Browning of your organization on July 18, 2006, and he agreed to respond within 30 days of receipt of this RAI. Please contact me at (301) 415-2928 if you have questions.

Sincerely,

/RA/

Deirdre W. Spaulding, Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosure:
RAI

cc w/encl: See next page

Mr. Gary Van Middlesworth
Vice President
Duane Arnold Energy Center
3277 DAEC Road
Palo, Iowa 52324-9785

July 24, 2006

SUBJECT: DUANE ARNOLD ENERGY CENTER - REQUEST FOR ADDITIONAL
INFORMATION RELATED TO THE PROPOSED AMENDMENT TO REVISE
THE LIMITING CONDITION FOR OPERATION (LCO) 3.10.1
(TAC NO. MD0293)

Dear Mr. Van Middlesworth:

Your letter of March 1, 2006, submitted a proposed amendment to revise the limiting condition for operation 3.10.1, to allow ancillary testing to occur during the evolutions associated with performing the American Society of Mechanical Engineers Code Class I leak test of the reactor pressure vessel, at the Duane Arnold Energy Center.

We are reviewing this information, and find that we need additional information as shown in the enclosed request for additional information (RAI). I discussed this RAI with Tony Browning of your organization on July 18, 2006, and he agreed to respond within 30 days of receipt of this RAI. Please contact me at (301) 415-2928 if you have questions.

Sincerely,

/RA/

Deirdre W. Spaulding, Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosure:
RAI

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	LPL3-1 R/F	RidsNrrPMDSpaulding	RidsNrrLATHarris
RidsNrrDorlLple	RidsOgcRp	RidsAcrcAcnwMailCenter	RidsRgn3MailCenter
RidsNrrDorlDpr	ALewin	JGilmer	TBoyce

ADAMS Accession Number: **ML061990634**

OFFICE	NRR/LPL3-1/PM	NRR/LPL3-1/LA	NRR/LPL3-1/BC
NAME	DSpaulding	THarris	LRaghavan
DATE	07/21/06	07/20/06	07/24/06

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION
RELATED TO THE PROPOSED AMENDMENT TO
REVISE THE LIMITING CONDITION FOR OPERATION (LCO) 3.10.1
DUANE ARNOLD ENERGY CENTER
DOCKET NO. 50-331

1. LCO 3.10.1 Rev 3.1a would allow testing in Mode 4 with average reactor coolant temperature drifting greater than 200 F as a result of decay heat. Primary containment requirements are relaxed in LCO 3.10.1 Rev 3.0 with the reasoning in the technical specification (TS) Bases that average reactor coolant temperature is greater than 200 F as a result of testing and not due to significant decay heat. Please explain why it is acceptable to be in Mode 4 (with average reactor coolant temperature greater than 200 F) vice Mode 3 with the presence of decay heat contributing to an increase in the average reactor coolant temperature.
2. LCO 3.4.7 "RCS Specific Activity," is normally not required in Mode 4 because the reactor is normally not pressurized. Please provide justification for not including LCO 3.4.7 under LCO 3.10.1 Rev 3.1a requirements when in Mode 4 with average reactor coolant temperature greater than 200 F.
3. The Bases for TS 3.10.1 Rev 3.1a discusses conducting other unnamed testing while the TS 3.10.1 Rev 3.1a specifically mentions conducting only inservice leak or hydrostatic tests and control rod scram time tests. Please elaborate on the intent of the TS and Bases as written with regards to "other testing."
4. The use of the verbiage "as a consequence of" in the LCO under TS 3.10.1 Rev 3.1a could result in steady state Mode 4 with reactor coolant temperature > 200 F even though testing is over and no longer being conducted. This seems to be the reasoning for eliminating the statement in the Bases for TS 3.10.1 Rev 3.0 which states that normal Mode 4 requirements are in effect immediately prior to and immediately after LCO 3.10.1 operations. Please elaborate on what would require returning to normal Mode 4 requirements after testing is completed.

ENCLOSURE

Duane Arnold Energy Center

cc:

Mr. J. A. Stall
Senior Vice President, Nuclear and Chief
Nuclear Officer
Florida Power & Light Company
P. O. Box 14000
Juno Beach, FL 33408-0420

Mr. M. S. Ross
Managing Attorney
Florida Power & Light Company
P. O. Box 14000
Juno Beach, FL 33408-0420

Mr. R. E. Helfrich
Senior Attorney
Florida Power & Light Company
P. O. Box 14000
Juno Beach, FL 33408-0420

Mr. W. E. Webster
Vice President, Nuclear Operations
Florida Power & Light Company
P. O. Box 14000
Juno Beach, FL 33408-0420

John Bjorseth
Site Director
Duane Arnold Energy Center
3277 DAEC Road
Palo, IA 52324

Steven R. Catron
Manager, Regulatory Affairs
Duane Arnold Energy Center
3277 DAEC Road
Palo, IA 52324

U. S. Nuclear Regulatory Commission
Resident Inspector's Office
Rural Route #1
Palo, IA 52324

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
Suite 210
2443 Warrenville Road
Lisle, IL 60532-4351

Mr. M. Warner
Vice President, Nuclear Operations
Support
Florida Power & Light Company
P. O. Box 14000
Juno Beach, FL 33408-0420

Mr. D. A. Curtland
Plant Manager
Duane Arnold Energy Center
3277 DAEC Rd.
Palo, IA 52324-9785

Mr. R. S. Kundalkar
Vice President, Nuclear Engineering
Florida Power & Light Company
P. O. Box 14000
Juno Beach, FL 33408-0420

Daniel McGhee
Utilities Division
Iowa Department of Commerce
Lucas Office Buildings, 5th Floor
Des Moines, IA 50319

Chairman, Linn County
Board of Supervisors
930 1st Street SW
Cedar Rapids, IA 52404