

From: "Croulet, Donald" <dcroule@entergy.com>
 To: "Conroy, Pat" <PConroy@entergy.com>, "Cox, Mark R" <mcox90@entergy.com>, "Bowman, Greg" <GBowm90@cc--exs03.prod.entergy.com>, "James Noggle" <JDN@nrc.gov>, "Janicki, John" <JJanick@entergy.com>, "Timothy Rice" <tbrice@gw.dec.state.ny.us>, "PRICE, ERNEST JR" <EPRICE2@entergy.com>, "Robert Oliveira (boliveira@amnucins.com)" <boliveira@amnucins.com>
 Date: 3/20/06 6:59AM
 Subject: FW: MONITORING WELL STATUS

From: Sachatello, Ronald
 Sent: Monday, March 20, 2006 6:56 AM
 To: Mayer, Don; Axelson, William L; Hinrichs, Gary
 Cc: Croulet, Donald; Sachatello, Ronald
 Subject: MONITORING WELL STATUS

Latest Monitoring Well Results -March 20, 2006-0600 hours

Three wells remain to be drilled. <<MONITORING WELL STATUS-MARCH 13.doc>>

Ex. 4

- * MW-52 (North side of U-2 Turbine Bldg) 80' of 200' completed
- * MW-45 [] To be started this week
- * MW- 51 (South Hill, North of MW-40) To be started this week

Information in this record was deleted
 in accordance with the Freedom of Information
 Act, exemptions 4
 FOIA- 2006-0195

C-2

PHASE II WELL STATUS

<u>Well #</u>	<u>Location</u>	<u>Status</u>	<u>Notes</u>	<u>Most Recent IPEC Results</u>
MW-39	[]	In Service	N/A	798 pCi/L (3/2/06)
MW-40	Parking Lot above Sewerage Plant	In Service	N/A	ND (2/9/06)
MW-41	[]	Developed	To be sampled	
MW-42	[]	Drilling complete	Develop well next	
MW-43	[]	Developed	To be sampled	
MW-44	[]	Drilling complete	To be sampled	
MW-45	[]	To be drilled	Need to complete drilling	
MW-46	U3 Transformer Yard	In Service	N/A	1430 pCi/L (3/1/06)
MW-47	[]	Drilling completed	To be sampled	
MW-48	Far South Property Boundary	In Service	N/A	ND (2/10/06)
MW-49	West side of Discharge Canal	Drilling complete	Develop well	
MW-50	East side of Discharge Canal	Drilling complete	To be sampled	
MW-51	South Hill North of MW-40	To be drilled	Need to complete drilling	
MW-52	North end of U2 Turbine Bldg	Drilled 80' of 200'	Complete drilling	

Ex. 4