

From: Peter Wen
To: James Davis
Date: Fri, May 5, 2006 1:14 PM
Subject: Re: Bolting Integrity Program

Jim,

Since bolting integrity is yours, could you get back to them.

Peter
>>> <erachp@comcast.net> 05/05/06 1:06 PM >>>
Wayne,

PNPS does not have a bolting program. However, I believe NRC is requesting them to submit one. I do not know where they are with this. By copy of this maybe Peter or Jim can advise.

For SS bolting, there will not be LOM due to corrosion, however, for loss of pre-load, if in your experience or there is a past precedent where NRC asked an RAI on this subject, then we will have to address it.

Erach

----- Original message -----

From: wapavinich@comcast.net

> I need a little help here. PNPS says that the Bolting Integrity Program is not
> applicable. Bolting AEs are handle through other programs. However, stainless
> steel bolting in ESF systems are assigned no AEs although loss of preload is
> plausible. Will PNPS be required to have a bolting integrity program? Should
> loss of preload be captured for stainless steel bolting?
>
> Wayne

Mail Envelope Properties (445B87F3.207 : 20 : 35420)

Subject: Re: Bolting Integrity Program
Creation Date Fri, May 5, 2006 1:14 PM
From: Peter Wen

Created By: PXW@nrc.gov

Recipients

OWGWPO01.HQGWDO01
JAD (James Davis)

Post Office

OWGWPO01.HQGWDO01

Route

Files	Size	Date & Time
MESSAGE	2301	Friday, May 5, 2006 1:14 PM

Options

Expiration Date: None
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No
Security: Standard

Junk Mail Handling Evaluation Results

Message is not eligible for Junk Mail handling
Message is from an internal sender

Junk Mail settings when this message was delivered

Junk Mail handling disabled by User
Junk Mail handling disabled by Administrator
Junk List is not enabled
Junk Mail using personal address books is not enabled
Block List is not enabled