

- (5) ENO pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.

C. This amended license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

- (1) Maximum Power Level

ENO is authorized to operate the facility at steady state reactor core power levels not in excess of 2536 megawatts (thermal).

- (2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 285, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

- (3) Fire Protection

ENO shall implement and maintain in effect all provisions of the approved fire protections program as described in the Final Safety Analysis Report for the facility and as approved in the SER dated November 20, 1972; the SER Supplement No. 1 dated February 1, 1973; the SER Supplement No. 2 dated October 4, 1974; the SER dated August 1, 1979; the SER Supplement dated October 3, 1980; the SER Supplement dated February 13, 1981; the NRC Letter dated February 24, 1981; Technical Specification Amendments 34 (dated January 31, 1978), 80 (dated May 22, 1984), 134 (dated July 19, 1989), 135 (dated September 5, 1989), 142 (dated October 23, 1989), 164 (dated August 10, 1990), 176 (dated January 16, 1992), 186 (dated February 19, 1993), 190 (dated June 29, 1993), 191 (dated July 7, 1993), 206 (dated February 28, 1994), and 214 (dated June 27, 1994); and NRC Exemptions and associated safety evaluations dated April 26, 1983, July 1, 1983, January 11, 1985, April 30, 1986, September 15, 1986 and September 10, 1992 subject to the following provision:

ENO may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.