



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

JUL 28 2006

10 CFR 50.90

U. S. Nuclear Regulatory Commission  
Mail Stop: OFWN P1-35 [TS ONLY]  
ATTN: Document Control Desk  
Washington, D.C. 20555-0001

Gentlemen:

In the Matter of ) Docket No. 50-390  
Tennessee Valley authority )

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - TECHNICAL SPECIFICATION  
(TS) CHANGE NO. 04-013 - WITHDRAWAL OF PROPOSED LICENSE  
AMENDMENT REQUEST (TAC MC4586)

Reference: TVA Letter to NRC, "WBN Unit 1 - TS Change No.  
04-13 - Auxiliary Feedwater (AFW) Start Upon Trip of Turbine  
Driven Main Feedwater (TDMFW) Pumps," September 23, 2004

The referenced letter submitted a proposed license amendment request to change the TS for WBN Unit 1. The amendment would have revised Limiting Condition for Operation (LCO) 3.3.2 (6)(e) to allow the AFW Start upon Trip of TDMFW Pump function to be required only when the one or more of TDMFW Pump are operating. However, based upon further review, TVA has decided to withdraw this request.

There are no regulatory commitments associated with this submittal. If you have any questions concerning this matter, please call me at (423) 365-1824.

Sincerely,

P. L. Pace  
Manager, Site Licensing  
and Industry Affairs

cc: See Page 2

D030

U.S. Nuclear Regulatory Commission  
Page 2

**JUL 28 2006**

cc: NRC Resident Inspector  
Watts Bar Nuclear Plant  
1260 Nuclear Plant Road  
Spring City, Tennessee 37381

Mr. D. V. Pickett, Senior Project Manager  
U.S. Nuclear Regulatory Commission  
MS 08G9a  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

U.S. Nuclear Regulatory Commission, Region II  
Sam Nunn Atlanta Federal Center  
Suite 23T85, 61 Forsyth Street, SW  
Atlanta, Georgia 30303-8931

Mr. Lawrence E. Nanny, Director  
Division of Radiological Health  
3<sup>rd</sup> Floor  
L & C Annex  
401 Church Street  
Nashville, Tennessee 37243