



- NOTE**
1. FOR NOTES, LEGENDS & FIRE HOSE STATIONS NUMERICAL DESIGNATION CODES, SEE DWG. NO. FB-499.
  2. ISOLATION VALVE FOR HYDRANT 18 IS WEST OF THE TRANSFORMER, NORTH OF THE WAREHOUSE.
  3. ISOLATION VALVE FOR HYDRANT 22 IS NORTH OF THE HYDRANT.
  4. FIRE DEPT. CONNECTION IS 4" STORTZ.

