



JUL 21 2006

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Serial No. 06-583  
KPS Lic/MJH R0  
Docket No. 50-305  
License No. DPR-43

**DOMINION ENERGY KEWAUNEE, INC.**  
**KEWAUNEE POWER STATION**  
**WITHDRAWAL OF LICENSEE EVENT REPORT 2005-010-00**

On August 16, 2005, Dominion Energy Kewaunee Inc. (DEK) submitted Licensee Event Report (LER) 50-305/2005-010 pursuant to 10 CFR 50.73(a)(2)(v)(B). This LER reported a concern that engineering analysis did not support the manual actions necessary for service water (SW) pump operability.

Subsequent testing and detailed engineering analysis were performed and demonstrated that there was sufficient time to perform the required manual actions; therefore, the SW pumps were operable in the as-found condition. The testing also substantiated the vendor's position that a bearing water flow rate of greater than zero is adequate, and that there was no safety system functional failure.

Based on the above, LER 50-305/2005-010-00 is formally withdrawn.

If you have any questions or require additional information, please contact Ms. Mary Jo Haese at (920) 388-8277.

Very truly yours,

Leslie N. Hartz  
Site Vice President, Kewaunee Power Station

Commitments made in this letter: None

FE22

cc: U.S. Nuclear Regulatory Commission  
Region III Regional Administrator  
2443 Warrenville Road  
Suite 210  
Lisle, IL 60532-4352

Mr. D. H. Jaffe  
NRC Senior Project Manager  
U.S. Nuclear Regulatory Commission  
Mail Stop O-7-D-1  
Washington, D.C. 20555

NRC Senior Resident Inspector  
Kewaunee Power Station