

Braidwood Annual Assessment Meeting

Reactor Oversight Program - CY 2005



Nuclear Regulatory Commission - Region III

Braceville, IL

July 31, 2006

Purpose of Today's Meeting

- A public forum for discussion of the licensee's performance
- NRC will address the licensee performance issues identified in the annual assessment letter
- Licensee will be given the opportunity to respond to the information in the letter and inform the NRC of new or existing programs to maintain or improve their performance

Agenda

- Introduction
- Review of Reactor Oversight Process
- National Summary of Plant Performance
- Discussion of Plant Performance Results
- Licensee Response and Remarks
- NRC Closing Remarks
- Break
- NRC available to address public questions

Region III Organization

James Caldwell
Regional Administrator

Geoff Grant
Deputy Regional Administrator

Mark Satorius
Director Division of Reactor Projects

Steve West
Deputy Director

Cynthia Pederson
Director Division of Reactor Safety

Anne Boland
Deputy Director

Richard Skokowski
Branch Chief

Regional Specialists

Braidwood
Resident Inspectors
Steve Ray
Greg Roach

Project Engineer
Desiree Smith


NRC Representatives

- Steve Ray, Senior Resident Inspector
 - (815) 458-2852
- Greg Roach, Resident Inspector
 - (815) 458-2852
- Desiree Smith, Senior Project Engineer, DRP
 - (630) 829-9637
- Rob Kuntz, Project Manager, NRR
 - (301) 415-3733
- Steven Orth, Health Physics Team Leader, DRS
 - (630) 829-9827
- Viktoria Mitlyng, Region III Public Affairs Officer
 - (630) 829-9662
- Richard Skokowski, Branch Chief, DRP
 - (630) 829-9620

NRC Performance Goals

- Safety: Ensure protection of the public health and safety and the environment
- Security: Ensure the secure use and management of radioactive materials
- Openness: Ensure openness in our regulatory process
- Effectiveness: Ensure that NRC actions are effective, efficient, realistic, and timely
- Management: Ensure excellence in agency management to carry out the NRC' strategic objective

Reactor Oversight Process



Examples of Baseline Inspections

- Equipment Alignment ~80 hrs/yr
- Triennial Fire Protection ~200 hrs every 3 yrs
- Operator Response ~125 hrs/yr
- Emergency Preparedness ~80 hrs/yr
- Rad Release Controls ~110 hrs every 2 yrs
- Worker Radiation Protection ~90 hrs/yr
- Corrective Action Program ~250 hrs every 2 yrs
- Corrective Action Case Reviews ~60 hrs/yr

Significance Threshold


Performance Indicators

- Green:** Only Baseline Inspection
- White:** May increase NRC oversight
- Yellow:** Requires more NRC oversight
- Red:** Requires more NRC oversight

Inspection Findings

- Green:** Very Low safety issue
- White:** Low to moderate safety issue
- Yellow:** Substantial safety issue
- Red:** High safety issue

Action Matrix Concept



Increasing Safety Significance

Increasing NRC Inspection Efforts

Increasing NRC/Licensee Management Involvement

Increasing Regulatory Actions

National Summary of Plant Performance

Status at End of CY 2005

Licensee Response	84
Regulatory Response	12
Degraded Cornerstone	4
Multiple/Repetitive Degraded Cornerstone	3
Unacceptable	0
<u>Total</u>	<u>103</u>

National Summary

- Performance Indicator Results (at end of CY 2005)

▶ Green	1850
▶ White	4
▶ Yellow	0
▶ Red	0

- Total Inspection Findings (CY 2005)

▶ Green	849
▶ White	10
▶ Yellow	1
▶ Red	0

Braidwood Assessment Results

(Jan 1 - Dec 31, 2005)

- Licensee Response Action Matrix Column with no greater than green findings/Pis
- No supplemental inspections were conducted

Braidwood Inspection Activities

(Jan 1 - Dec 31, 2005)

- Steve Ray returned to assume duties as Senior Resident Inspector from Nirodh (Nick) Shah who was assigned to Region III. Greg Roach assumed duties as Resident Inspector in July 2005.
- There was one refueling outage for Unit 2 from April 19 to May 7
- A Safety System Design and Performance Capability inspection (SSDPC) was performed in August
- A Problem Identification and Resolution (PI&R) was conducted in October

Braidwood Inspection Activities Results

(Jan 1 - Dec 31, 2005)

- The Residents and regional inspectors reported a total of eight (8) findings of very low safety significance (GREEN)

Safety Significant Findings or PIs

- There were no significant findings greater than GREEN (very low safety significance) during 2005
- Tritium Unresolved Item

Braidwood

Annual Assessment Summary

January 1 - December 31, 2005

- Exelon operated Braidwood Units 1 & 2 in a manner that preserved public health and safety
- All cornerstone objectives were met. All findings were of very low safety significance (GREEN)
- At the time the Annual Assessment was completed, NRC planned only baseline inspections at Braidwood for the remainder of the assessment period
- Based on the recently issued WHITE finding for the unmonitored release of tritium a Supplemental Inspection is being planned

Licensee Response and Remarks

Keith Polson
Site Vice President
Braidwood Generating Station

Contacting the NRC

- Report an emergency
 - ▶ (301) 816-5100 (call collect)
- Report a safety concern:
 - ▶ (800) 695-7403
 - ▶ Allegation@nrc.gov
- General information or questions
 - ▶ www.nrc.gov
 - ▶ Select “What We Do” for Public Affairs

Reference Sources

- Public Electronic Reading Room

- ▶ <http://www.nrc.gov/reading-rm.html>

- Reactor Oversight Process

- ▶ <http://www.nrc.gov/NRR/OVERSIGHT/ASSESS/index.html>

- Groundwater Contamination (Tritium)

- ▶ <http://www.nrc.gov/reactors/operating/ops-experience/grndwtr-contam-tritium.html>

- Public Document Room

- ▶ 1-800-397-4209 (Toll Free)

Braidwood

Annual Assessment Summary

January 1 - December 31, 2005

- Exelon operated Braidwood Units 1 & 2 in a manner that preserved public health and safety
- All cornerstone objectives were met. All findings were of very low safety significance (GREEN)
- At the time the Annual Assessment was completed, NRC planned only baseline inspections at Braidwood for the remainder of the assessment period
- Based on the recently issued WHITE finding for the unmonitored release of tritium a Supplemental Inspection is being planned