



Functional Design, Qualification, and Inservice Testing of Pumps, Valves, and Dynamic Restraints

Jack Grobe

Director

Division of Component Integrity

Office of Nuclear Reactor Regulation

U.S. Nuclear Regulatory Commission

July 17, 2006

Challenge

- Current nuclear power plants are extending their operating lives and uprating their power levels
- Applications for new nuclear power plants are anticipated to be submitted in 2007
- We have a shared responsibility to ensure that functional design, qualification, and inservice testing that incorporate risk insights and performance-based provisions continue to provide assurance of operational readiness of pumps, valves, and dynamic restraints.

Summary Estimate of New Nuclear Power Plants

(as of 7/3/06)

	COLs	Units
AP 1000	6	11
ESBWR	3	3
EPR	5	5
ABWR	2	4
Unspecified	3	3
<hr/>		
Total	19	26

Number of Reference COLs: 4

Number of Environmental Reviews: 19+

Common Goals of NRC, ASME, and Nuclear Industry

- Safe and reliable operation of existing nuclear power plants
- Practical requirements for functional design, qualification, and inservice testing (IST) of pumps, valves, and dynamic restraints
- Adequate functional design, qualification, and inservice testing
- Effective preparation for, and licensing and operation of, safe and reliable new nuclear power plants

Transition of Functional Design, Qualification, and Inservice Testing

- In the past, functional design, qualification, and IST focused on deterministic parameters and approaches (e.g., valve stroke time)
- Risk insights and performance-based parameters and approaches are being incorporated (e.g., valve diagnostics and comprehensive pump testing)
- Importance of maintaining performance capability that supports Probabilistic Risk Assessment assumptions

ASME Roles

- Prepare and update functional design and qualification provisions for pumps, valves, and dynamic restraints in ASME Standard QME-1
- Prepare and update IST provisions to assess operational readiness of pumps, valves, and dynamic restraints in *Code for Operation and Maintenance of Nuclear Power Plants* (OM Code)
- Develop OM Code cases to provide safe and reliable alternatives to specific Code provisions
- Respond to questions on implementation of specific Code provisions

NRC Roles

- Adopt consensus Codes and Standards where safe, reliable, and relevant
- Participate on ASME QME and OM committees to provide input related to regulatory issues
- Review updates to OM Code for incorporation by reference in 10 CFR 50.55a
- Review ASME QME-1 standard for generic acceptance
- Review plant-specific IST program updates, requests for relief from Code provisions, and alternatives to Code
- Review OM Code cases for acceptance in Regulatory Guide (RG) 1.192
- Prepare for operating and new reactor applications

NRC Activities on Functional Design, Qualification, and Inservice Testing

- Rulemaking to update 10 CFR 50.55a to reference recent edition of ASME OM Code on IST provisions
- Regulatory guide will be developed for QME-1 standard on functional design and qualification
- Regulatory guide being considered for NUREG-1482 on IST guidance
- Standard Review Plan and other regulatory guidance being updated to support review of operating and new nuclear power plant applications

NRC Risk-Informed Initiatives

- Apply risk insights to support safe operation of current and new nuclear power plants
- Evaluate plant-specific requests for application of risk-informed inservice testing
- Review risk-informed OM Code cases for acceptance in RG 1.192
- Issued 10 CFR 50.69 to allow risk-informed treatment of plant components and RG 1.201 to provide guidance on categorization
- Developing review and inspection guidance for 10 CFR 50.69

Industry Roles

- Participate in ASME QME and OM committees as technical experts
- Establish programs that satisfy QME-1 standard and OM Code provisions
- Prepare IST program updates, requests for relief from applicable Code provisions, and proposed alternatives to Code, as necessary
- Develop new technology to provide improved and more efficient implementation of QME-1 and OM provisions
- Develop guidance for implementing 10 CFR 50.69
- Standardize new reactor designs

Risk Insights and Performance-based Methods

- Application of risk insights in functional design, qualification, and IST requires understanding of PRA and component performance
- Risk-informed IST programs need to provide efficient and effective implementation of risk insights
- Performance-based methods need to maintain reasonable confidence in design-basis capability of low-risk safety-related components
- Treatment guidance can help provide appropriate implementation of 10 CFR 50.69

Meeting the Challenge

- Focus on common goals for
 - Safe and reliable nuclear power plant operation
 - Practical requirements for functional design, qualification, and inservice testing
 - Adequate functional design, qualification, and inservice testing
- Strengthen roles and interactions
- Improve performance-based provisions
- Implement efficient and effective risk-informed programs

