

August 15, 2006

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - REQUEST FOR ADDITIONAL INFORMATION
RE: REQUEST FOR A ONE-TIME EXTENSION OF CONTAINMENT
INTEGRATED LEAKAGE RATE TEST INTERVAL (MC9732)

Dear Mr. Edington:

The Nuclear Regulatory Commission (NRC) staff has reviewed the information provided in the January 30, 2006, submittal and has determined that the additional information identified in this enclosure is required in order for the NRC staff to complete its review. To meet our target date, the NRC staff requests that the licensee provide its response no later than August 20, 2006.

Sincerely,

/RA/

Brian Benney, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Request for Additional Information

cc w/encl: See next page

August 15, 2006

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - REQUEST FOR ADDITIONAL INFORMATION
RE: REQUEST FOR A ONE-TIME EXTENSION OF CONTAINMENT
INTEGRATED LEAKAGE RATE TEST INTERVAL (MC9732)

Dear Mr. Edington:

The Nuclear Regulatory Commission (NRC) staff has reviewed the information provided in the January 30, 2006, submittal and has determined that the additional information identified in this enclosure is required in order for the NRC staff to complete its review. To meet our target date, the NRC staff requests that the licensee provide its response no later than August 20, 2006.

Sincerely,

/RA/

Brian Benney, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDorl (CHaney/CHolden)
LPLIV r/f	RidsRgn4MailCenter (KKennedy)
RidsNrrLALFeizollahi	RidsNrrDorlDpr
RidsNrrPMBBenney	RidsOgcRp
RidsNrrDorlLp4 (DTerao)	RidsNrrDeEgcb (RKaras)
RidsAcrsAcnwMailCenter	

ADAMS ACCESSION NO: ML062150178

NRR-106

OFFICE	LPL4/PM	LPL4/LA	LPL4/BC
NAME	BBenney	LFeizollahi	DTerao
DATE	0/10/06	08/10/06	08/15/06

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION
BY THE OFFICE OF NUCLEAR REACTOR REGULATION
REQUEST FOR A ONE-TIME EXTENSION OF
CONTAINMENT INTEGRATED LEAKAGE RATE TEST INTERVAL
FACILITY OPERATING LICENSE NO. DPR-46
NEBRASKA PUBLIC POWER DISTRICT
COOPER NUCLEAR STATION
DOCKET NO. 50-298

1. IWE-1240 requires licensees to identify the containment surface areas requiring augmented examinations. Provide the locations of the steel containment surfaces that have been identified as requiring augmented examination and a summary of the findings of the examinations performed.
2. For the examination of penetration seals and gaskets, and examination and testing of bolted connections associated with the primary containment pressure boundary, the licensee requested relief from the requirements of the code. As an alternative, the licensee proposed to examine the above items during the leak-rate testing of the primary containment. Option B of Appendix J for Type B and Type C testing (per Nuclear Energy Institute (NEI) 94-01 and Regulatory Guide (RG) 1.163), and the integrated leakage rate test extension requested in this amendment for Type A testing, provide flexibility in the scheduling of these inspections. Discuss your schedule for examination and testing of seals, gaskets, and bolted connections that provide assurance regarding the integrity of the containment pressure boundary.
3. Inspections of some steel containment structures have identified degradation of uninspectable areas (gap between the shield wall and drywell). These degradations cannot be found by visual (i.e., VT-1 or VT-3) examinations unless they are through the thickness of the shell or when 100 percent of the uninspectable surfaces are periodically examined by ultrasonic testing. Discuss what approach is used in the Cooper Nuclear Station (CNS) to identify degradation of uninspectable areas of the containment.
4. In response to Generic Letter 87-05, CNS committed to implement new surveillance procedures for inspection of sand cushion drains during refueling outages. Discuss the results obtained from the inspection.

Cooper Nuclear Station

cc:

Mr. William J. Fehrman
President and Chief Executive Officer
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

Mr. Gene Mace
Nuclear Asset Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. John C. McClure
Vice President and General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, NE 68602-0499

Mr. Paul V. Fleming
Licensing Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. Michael J. Linder, Director
Nebraska Department of Environmental
Quality
P. O. Box 98922
Lincoln, NE 68509-8922

Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, NE 68305

Ms. Julia Schmitt, Manager
Radiation Control Program
Nebraska Health & Human Services R & L
Public Health Assurance
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. H. Floyd Gilzow
Deputy Director for Policy
Missouri Department of Natural Resources
P. O. Box 176
Jefferson City, MO 65102-0176

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 218
Brownville, NE 68321

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Director, Missouri State Emergency
Management Agency
P. O. Box 116
Jefferson City, MO 65102-0116

Chief, Radiation and Asbestos
Control Section
Kansas Department of Health
and Environment
Bureau of Air and Radiation
1000 SW Jackson
Suite 310
Topeka, KS 66612-1366

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
Lucas State Office Building, 5th Floor
321 East 12th Street
Des Moines, IA 50319

Mr. Keith G. Henke, Planner
Division of Community and Public Health
Office of Emergency Coordination
930 Wildwood P.O. Box 570
Jefferson City, MO 65102

Jerry C. Roberts, Director of Nuclear
Safety Assurance
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. John F. McCann, Director
Licensing, Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601-1813