



UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION II
SAM NUNN ATLANTA FEDERAL CENTER
61 FORSYTH STREET, SW, SUITE 23T85
ATLANTA, GEORGIA 30303-8931

August 3, 2006

Duke Energy Corporation
ATTN: Mr. Bruce H. Hamilton
Vice President
Oconee Site
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: OCONEE NUCLEAR STATION, UNIT 1 - NOTIFICATION OF INSPECTION
AND REQUEST FOR INFORMATION

Dear Mr. Hamilton:

On or about October 16 - 27, 2006, the NRC will perform the baseline inservice inspection (ISI) at the Oconee Nuclear Station, Unit 1 (NRC Inspection Procedure 71111.08). Experience has shown that this inspection is resource intensive both for the NRC inspector and your staff. In order to minimize the impact to your on-site resources and to ensure a productive inspection, we have enclosed a request for documents needed for this inspection. These documents have been divided into two groups. The first group identifies information to be provided prior to the inspection to ensure that the inspector is adequately prepared. The second group identifies the information the inspector will need upon arrival at the site. It is important that all of these documents are up to date and complete in order to minimize the number of additional documents requested during the preparation and/or the onsite portions of the inspection.

We have discussed the schedule for these inspection activities with your staff and understand that our regulatory contact for this inspection will be Judy Smith, of your organization. Our inspection dates are subject to change based on your updated schedule of outage activities. If there are any questions about this inspection or the material requested, please contact the lead inspector, Eric Michel, at (404) 562-4555.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA By J. Lenahan For/

Mark S. Lesser, Chief
Engineering Branch 3
Division of Reactor Safety

Docket No. 50-269
License No. DPR-38

Enclosure: See next page

August 3, 2006

Duke Energy Corporation
ATTN: Mr. Bruce H. Hamilton
Vice President
Oconee Site
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: OCONEE NUCLEAR STATION, UNIT 1 - NOTIFICATION OF INSPECTION
AND REQUEST FOR INFORMATION

Dear Mr. Hamilton:

On or about October 16 - 27, 2006, the NRC will perform the baseline inservice inspection (ISI) at the Oconee Nuclear Station, Unit 1 (NRC Inspection Procedure 71111.08). Experience has shown that this inspection is resource intensive both for the NRC inspector and your staff. In order to minimize the impact to your on-site resources and to ensure a productive inspection, we have enclosed a request for documents needed for this inspection. These documents have been divided into two groups. The first group identifies information to be provided prior to the inspection to ensure that the inspector is adequately prepared. The second group identifies the information the inspector will need upon arrival at the site. It is important that all of these documents are up to date and complete in order to minimize the number of additional documents requested during the preparation and/or the onsite portions of the inspection.

We have discussed the schedule for these inspection activities with your staff and understand that our regulatory contact for this inspection will be Judy Smith, of your organization. Our inspection dates are subject to change based on your updated schedule of outage activities. If there are any questions about this inspection or the material requested, please contact the lead inspector, Eric Michel, at (404) 562-4555.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,
/RA By J. Lenahan For/
Mark S. Lesser, Chief
Engineering Branch 3
Division of Reactor Safety

Docket No. 50-269
License No. DPR-38

Enclosure: See next page

*FOR PREVIOUS CONCURRENCE SEE ATTACHED SHEET

PUBLICLY AVAILABLE NON-PUBLICLY AVAILABLE SENSITIVE NON-SENSITIVE

ADAMS: Yes ACCESSION NUMBER: _____

OFFICE	RII:DRS	RII:DRS	RII:DRS	RII:DRP			
SIGNATURE	/RA/	/RA By JLenahan for/	/RA/	/RA By CRapp for/			
NAME	EMichel	MLesser	GHopper	MErnstes			
DATE	8/3/06	August 11, 2006	August 11, 2006	August 11, 2006			
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

Enclosure: INSERVICE INSPECTION DOCUMENT REQUEST

cc w/encl:

B. G. Davenport
Compliance Manager (ONS)
Duke Energy Corporation
Electronic Mail Distribution

Lisa Vaughn
Associate General Counsel
Duke Energy Corporation
526 South Church Street
Mail Code EC 07H
Charlotte, NC 28202

Timika Shafeek-Horton
Assistant General Counsel
Duke Energy Corporation
526 South Church Street-EC07H
Charlotte, NC 28202

David A. Repka
Winston & Strawn LLP
Electronic Mail Distribution

Beverly Hall, Acting Director
Division of Radiation Protection
N. C. Department of Environmental
Health & Natural Resources
Electronic Mail Distribution

Henry J. Porter, Assistant Director
Div. of Radioactive Waste Mgmt.
S. C. Department of Health and
Environmental Control
Electronic Mail Distribution

Distribution w/encl:

L. Olshan, NRR
C. Evans (Part 72 Only)
L. Slack, RII EICS
OE Mail (email address if applicable)
RIDSNRRDIRS
PUBLIC

R. Mike Gandy
Division of Radioactive Waste Mgmt.
S. C. Department of Health and
Environmental Control
Electronic Mail Distribution

County Supervisor of
Oconee County
415 S. Pine Street
Walhalla, SC 29691-2145

Lyle Graber, LIS
NUS Corporation
Electronic Mail Distribution

R. L. Gill, Jr., Manager
Nuclear Regulatory Issues
and Industry Affairs
Duke Energy Corporation
526 S. Church Street
Charlotte, NC 28201-0006

Charles Brinkman
Director, Washington Operations
Westinghouse Electric Company
12300 Twinbrook Parkway, Suite 330
Rockville, MD 20852

INSERVICE INSPECTION DOCUMENT REQUEST

Inspection Dates: October 16 - 27, 2006
Inspection Procedures: IP 71111.08 "Inservice Inspection (ISI) Activities"
Inspector: Eric Michel

A. Information Requested One Month Before the Entrance Meeting

The following information should be sent to the Region II office in electronic format (CD preferred) or hard-copy, care of, Eric Michel, by September 18, 2006 to facilitate the selection of specific items that will be reviewed during the onsite inspection week(s). The inspector will select specific items from the information requested below, and then request additional documents as needed for the onsite inspection week. We ask that the specific items selected from the lists be available and ready for review on the first day of inspection. All information requests relate to Unit 1 unless otherwise stated.

***Please provide requested documentation electronically if possible. If requested documents are large and only hard copy formats are available, please inform the inspector, and provide subject documentation during the first day of the onsite inspection.** If you have any questions regarding this information request, please call the inspector as soon as possible.

A.1 ISI / Welding Programs and Schedule Information

a) A detailed schedule of:

- i) Nondestructive examinations (NDE) planned for Class 1 & 2 systems and containment, performed as part of your ASME Section XI, Risk Informed (*if applicable*), and augmented ISI Programs during the upcoming outage.

Provide a status summary of the NDE inspection activities vs. the required inspection period percentages for this Interval by category per ASME Section XI, IWX-2400. (*Do not provide separately if other documentation requested contains this information.*)

- ii) Reactor vessel head (RPVH) examinations planned for the upcoming outage. (*if applicable*)
- iii) Examinations planned for Alloy 82/182/600 components that are not included in the Section XI scope. (*if applicable.*)
- iv) Examinations performed as part of your Boric Acid Corrosion Control Program (Mode 3 walkdowns, bolted connection walkdowns, etc.)
- v) Welding activities that are scheduled to be completed during the upcoming outage (ASME Class 1, 2, or 3 structures, systems or components (SSCs)).

Enclosure

- b) A copy of ASME Section XI, Code Relief Requests, proposed alternatives and associated NRC Safety Evaluations applicable to the examinations identified above. Additionally, please provide documentation associated with ASME Code Cases that are being incorporated in work activities being performed this outage.
- c) A list of NDE reports (ultrasonic, radiography, magnetic particle, dye penetrant, visual VT-1, VT-2, and VT-3) which have identified recordable indications (geometric or flaw) on Code Class 1 & 2 systems since the beginning of the last refueling outage. Also, include NDE reports with recorded indications in the RPVH penetration nozzles which have been accepted for continued service.
- d) A list with a brief description of the welds in Code Class 1 and 2 systems which have been fabricated due to component repair/replacement activities since the beginning of the last refueling outage, or are planned to be fabricated this refueling outage. Please identify the system, weld number, and reference applicable documentation.
- e) If reactor vessel weld examinations required by the ASME Code are scheduled to occur during the upcoming outage, provide a detailed description of the welds to be examined, and the extent of the planned examination. Please also provide reference numbers for applicable procedures that will be used to conduct these examinations.
- f) Copy of any 10 CFR Part 21 reports applicable to your SSCs within the scope of Section XI of the ASME Code that have been identified since the beginning of the last refueling outage.
- g) A list of any temporary non-code repairs in service (e.g., pinhole leaks).
- h) Please provide copies of the most recent self assessments for the ISI, Welding, and Alloy 600 Programs.

A.2 Reactor Pressure Vessel Head (RPVH) (If Applicable)

- a) Provide a copy of the document describing the scope of RPVH examinations, including inspection methods.

A.3 Boric Acid Corrosion Control Program (BACCP)

- a) Copy of the procedures that govern the scope, equipment and implementation of the inspections required to identify boric acid leakage. Additionally, please provide the procedures for boric acid leakage/corrosion evaluation.
- b) Please provide a list of boric acid leaks and their location (component description/number) that have been identified since the last refueling outage. Please include the component Code class and associated corrective action document number.
- c) Please provide a copy of the most recent self-assessment performed for the BACCP.

A.4 Information related to Steam Generator (SG) inspections

- a) A detailed schedule of:
 - i) SG tube inspection and repair activities for the upcoming outage. *(If occurring)*
 - ii) SG secondary side inspection activities for the upcoming outage. *(If occurring)*
- b) A copy of the NDE procedures used to perform the SG ISI (including calibration and flaw characterization/sizing procedures). Also, include documentation for the specific equipment to be used. *(These documents can be provided to the inspector on the first day of the inspection if not available electronically.)*
- c) A copy of ASME Section XI, Code Relief Requests applicable to the examinations of SG tubes. *(If applicable.)*
- d) Please provide a copy of your SG ISI Inspection Program and Plan. Please include a copy of the Operational Assessment from last outage, and a copy of the following documents for this outage as they become available:
 - i) Degradation Assessment
 - ii) Condition Monitoring Assessment
- e) If you have modified your Technical Specifications such that they are consistent with TSTF-449, please provide copies of your correspondence with the NRC regarding deviations from the Standard Technical Specifications.
- f) Copy of SG history documentation given to vendors performing eddy current (ET) testing of the SGs during the upcoming outage.
- g) Copy of procedure containing screening criteria used for selecting tubes for in-situ pressure testing and the procedure to be used for in-situ pressure testing.
- h) Copy of the document defining the planned ET scope for the SGs, including percentage of tubes to be inspected, inspection methods, and the scope expansion criteria which will be used. Also, identify and describe any deviations in this scope or expansion criteria from the EPRI Guidelines. *(Do not provide separately if other documentation requested contains this information.)*
- i) Copy of SG Eddy Current Data Analyst Guidelines, and Site Validated Eddy Current Technique. Additionally, please provide a copy of EPRI Appendix H Eddy Current Technique Qualification Records.
- j) Identify and quantify any SG tube leakage experienced during the previous operating cycle. Also provide documentation identifying which SG was leaking and corrective actions completed or planned for this condition. *(If applicable.)*
- k) Provide past history of the condition and issues pertaining to the secondary side of the steam generators (including items such as loose parts, fouling, top of tube sheet condition, crud removal amounts, etc).

- l) Please provide copies of your most recent self assessments of the SG monitoring, loose parts monitoring, and secondary side water chemistry control programs.
- m) Please also indicate where the primary and secondary analysis is scheduled to take place.

A.5 Additional information related to all ISI activities

- a) A list with a brief description of ISI and SG related issues (e.g., condition reports) entered into your corrective action program since the beginning of the last refueling outage (for Units 1, 2, and 3). For example, a list based upon data base searches using key words related to piping or SG tube degradation such as: ISI, ASME Code, Section XI, NDE, cracks, wear, thinning, leakage, rust, corrosion, boric acid or errors in piping/SG tube examinations.
- b) Please provide names and phone numbers for the following program leads:
 - ISI contacts (Examination, planning)
 - Containment Exams
 - Snubbers and Supports
 - Repair and Replacement Program Manager
 - Licensing Contact
 - Site Welding Engineer
 - Boric Acid Corrosion Control Program
 - SG ISI Coordinator, Program Manager, site lead, or/and vendor contact
- c) Please indicate which of the above program leads will not be available during the day shift of the inspection week, and what provisions will be made to provide acceptable substitutes, or work-arounds.

**B. Information Requested at the Entrance Meeting
(October 16, 2006):**

B.1 ISI / Welding Programs and Schedule Information

- a) Updated schedules for ISI / NDE activities, including SG ISI, planned welding activities, and schedule showing contingency repair plans, if available.
- b) For ASME Class 1 and 2 welds selected by the inspector from the lists provided from part A of this enclosure, please provide copies of the following documentation for each subject weld:
 - i) The weld data sheet (traveler)
 - ii) Weld configuration and system location
 - iii) Applicable Code Edition and Addenda for weldment
 - iv) Applicable Code Edition and Addenda for welding procedures
 - v) Applicable weld procedures (WPS) used to fabricate the welds
 - vi) Copies of procedure qualification records (PQRs) supporting the WPS from B.1.b.v)

- vii) Copies of mechanical test reports identified in the PQRs above
 - viii) Copies of the nonconformance reports for the selected welds *(If applicable)*
 - ix) Radiographs of the selected welds and access to equipment to allow viewing radiographs *(If RT was performed)*
 - x) Copies of the preservice examination records for the selected welds.
 - xi) Copies of welder performance qualifications records applicable to WPS, including documentation that welder maintained proficiency in the applicable welding processes specified in the WPS (At least six months prior to date subject work)
 - xii) Copies of Inspector Certifications (VT, PT, UT, RT) *(As applicable)*
- c) For the ISI related corrective action issues selected by the inspector from part A of this enclosure, provide a copy of the corrective actions and supporting documentation.
 - d) For the nondestructive examination reports with recordable indications on Code Class 1 & 2 systems selected by the inspector from part A above, provide a copy of the examination records, examiner qualification records, and associated corrective action documents.
 - e) A copy of (or ready access to) the most current revision of the ISI Program Manual and Plan for this Interval.
 - f) Copy of the NDE procedures used to perform the examinations selected by the inspector from the activities identified in part A of this enclosure (including calibration and flaw characterization/sizing procedures). For ultrasonic examination procedures qualified in accordance with ASME Code, Section XI, Appendix VIII, provide documentation supporting the procedure qualification (e.g., the EPRI performance demonstration qualification summary sheets). Also, include documentation of the specific equipment to be used (e.g., ultrasonic unit, cables, and transducers including serial numbers).

B.2 Reactor Pressure Vessel Head (RPVH) (As Applicable)

- a) Provide a list which identifies the NDE personnel who will perform inspections of the RPVH. Also, provide the qualification and certification records for these personnel. *(If applicable)*
- b) Provide drawings showing the following: *(Provide only if RPVH inspections are scheduled for the upcoming outage)*
 - i) RPVH and CRDM nozzle configurations
 - ii) RPVH insulation configuration

The drawings listed above should include fabrication drawings for the nozzle attachment welds as applicable.

- c) Provide a copy of the procedures that will be used to identify the source of any boric acid deposits identified on the RPVH. If no explicit procedures exist which govern this activity, provide a description of the process to be followed including personnel responsibilities and expectations. *(If applicable)*

- d) Provide a copy of the procedures that will be used to perform the RPVH examinations described in part A of this enclosure. *(If applicable)*

B.3 *Boric Acid Corrosion Control Program (BACCP)*

- a) Please provide the inspection results of boric acid walk-down performed since the end of the last refueling outage, including boric acid leaks identified so far this outage. Additionally, provide an updated list of associated corrective action document numbers, and overall status of planned boric acid inspections.
- b) Please provide any engineering evaluations completed for boric acid leaks identified since the end of the last refueling outage. Please include a status of corrective actions to repair and/or clean these boric acid leaks. Please specifically indicate which known leaks, if any, have remained in service or will remain in service as active leaks.
- c) In accordance with NRC inspection procedure 71111.08, the inspector(s) would like to conduct an independent boric acid walk down of the Reactor Building early in the inspection week. Please have knowledgeable BACCP staff available to accompany the inspector during the walk down.

B.4 *Information related to Steam Generator (SG) inspections*

- a) Copy of the Technique Specification Sheets (ETSS), and associated justification for any revisions.
- b) Copy of the guidance to be followed if a loose part or foreign material is identified in the SGs.
- c) Please provide copies of your responses to NRC and industry operating experience communications such as Generic Letters, Information Notices, etc. *(As applicable to SG inspections. Do not provide these documents separately if already included in other information requested such as the degradation assessment.)*
- d) List of corrective action documents generated by the vendor and/or site with respect to SG inspection activities.

B.5 *Codes and Standards*

- a) Ready access to: (i.e. copies provided to the inspector to use for the duration of the inspection at the on-site inspection location)
 - i) Applicable editions of the ASME Code (Sections V, IX and XI) for the inservice inspection program and the repair/replacement program.
 - ii) EPRI and industry standards referenced in the procedures used to perform the SG tube eddy current examination.

Inspector Contact Information:

Eric Michel
Reactor Inspector
(404) 562-4555
jer6@nrc.gov

Mailing Address

US NRC Region 2
Attn: Eric Michel
61 Forsyth Street, SW Suite 23T85
Atlanta, GA 30303