

August 4, 2006

TVA-BFN-TS-426

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop: OWFN P1-35
Washington, D.C. 20555-0001

Gentlemen:

In the Matter of)
Tennessee Valley Authority)

Docket No. 50-259

**BROWNS FERRY NUCLEAR PLANT (BFN) - UNIT 1 - WITHDRAWAL OF
TECHNICAL SPECIFICATION (TS) CHANGE 426 - REVISION TO
DIESEL GENERATORS ALLOWED OUTAGE TIME**

By letter dated December 6, 2004 (ADAMS Accession No. ML043430120), Tennessee Valley Authority (TVA) submitted a request for an amendment to license DPR-33 for BFN Unit 1. The proposed amendment revises the current diesel generators seven day allowed outage time to fourteen days. The purpose of increasing the allowed outage time is to provide additional flexibility for preventive or corrective maintenance and repair of the diesel generators. The change was also noted as ensuring consistency with the current Units 2 and 3 Technical Specifications.

Due to higher priority, ongoing items concerning the restart of Unit 1 and the requests for Extended Power Uprate for Unit 1 and Units 2 and 3, TVA hereby withdraws this TS request.

U.S. Nuclear Regulatory Commission
Page 2
August 04, 2006

There are no regulatory commitments associated with this submittal. If you have any questions about this amendment, please contact me at (256)729-2636.

I declare under penalty of perjury that the foregoing is true and correct. Executed August 4th, 2006.

Sincerely,

Original signed by:

William D. Crouch
Manager of Licensing
and Industry Affairs

U.S. Nuclear Regulatory Commission
Page 3
August 4, 2006

cc: State Health Officer
Alabama Dept. of Public Health
RSA Tower - Administration
Suite 1552
P.O. Box 303017
Montgomery, AL 36130-3017

U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-3415

Mr. Malcolm T. Widmann, Branch Chief
U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-8931

NRC Senior Resident Inspector
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, Alabama 35611-6970

NRC Unit 1 Restart Senior Resident Inspector
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, Alabama 35611-6970

Margaret Chernoff, Project Manager
U.S. Nuclear Regulatory Commission
(MS 08G9)
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

Ms. Eva A. Brown, Project Manager
U.S. Nuclear Regulatory Commission
(MS 08G9) One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

U.S. Nuclear Regulatory Commission
Page 4
August 4, 2006

JEM:TLE:BAB

cc:. Bajestani, NAB 1A-BFN
A. S. Bhatnagar, LP 6A-C
J. C. Fornicola, LP 6A-C
R. G. Jones, POB 2C-BFN
G. V. Little, NAB 1D-BFN
R. F. Marks, Jr., PAB 1C-BFN
B. J. O'Grady, PAB 1E-BFN
P. D. Swafford, LP 6A-C
K. W. Singer, LP 6A-C
E. J. Vigluicci, WT 6A-K
EDMS-WT CA-K

S:\lic\submit\subs\Withdrawal of TechSpec 426.doc