

Prairie Island Nuclear Generating Plant Operated by Nuclear Management Company, LLC

MAY 05 2006

L-PI-06-037 TS 5.6.2 ISFSI TS 6.2

U S Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555

Prairie Island Nuclear Generating Plant Units 1 and 2 Dockets 50-282, 50-306 and 72-10 License Nos. DPR-42, DPR-60 and SNM-2506

2005 Annual Radiological Environmental Monitoring Program (REMP) Report

Pursuant to Prairie Island Nuclear Generating Plant (PINGP) Technical Specification (TS) 5.6.2, Appendix A to Operating Licenses DPR-42 and DPR-60, and pursuant to Prairie Island Independent Spent Fuel Storage Installation Technical Specification (ISFSI TS) 6.2, Appendix A to Materials License SNM-2506, the Nuclear Management Company, LLC submits one copy of the Annual Radiological Environmental Monitoring Program report for the period January 1, 2005 through December 31, 2005.

Summary of Commitments

This letter contains no new commitments and no revisions to existing commitments.

Thomas J. Palmisano Site Vice President, Prairie Island Nuclear Generating Plant Nuclear Management Company, LLC

Enclosure (1)

cc: Regional Administrator, USNRC, Region III Project Manager, Prairie Island Nuclear Generating Plant, USNRC, NRR NRC Resident Inspector – Prairie Island Nuclear Generating Plant Dr. John House, USNRC, Region III Director of NMSS, USNRC Tim Donakowski, State of Minnesota PI Dakota Community Environmental Coordinator

ENCLOSURE 1

Annual Report to the United States Nuclear Regulatory Commission

Radiation Environmental Monitoring Program

January 1, 2005 through December 31, 2005

.



700 Landwehr Roed • Northbrook, IL 60062-2310 ph. (847) 564-0700 • fax (847) 564-4517

XCEL ENERGY CORPORATION

PRAIRIE ISLAND NUCLEAR GENERATING PLANT

ANNUAL REPORT TO THE UNITED STATES NUCLEAR REGULATORY COMMISSION

Radiation Environmental Monitoring Program

January 1 to December 31, 2005

Prepared under Contract by

ENVIRONMENTAL, Inc. MIDWEST LABORATORY

Project No. 8010

Brohia Grob, M.S. Laboratory Manager

Approved:

PREFACE

The staff of Environmental, Inc., Midwest Laboratory was responsible for the acquisition of data presented in this report. Samples were collected by members of the staff of the Prairie Island Nuclear Generating Plant, operated by Nuclear Management Company, LLC for XCEL Energy Corporation. The report was prepared by Environmental, Inc., Midwest Laboratory.

Section	<u>.</u> <u>F</u>	<u>'age</u>
	Preface	ii
	List of Tables	iv
	List of Figures	v
1.0		1
2.0	SUMMARY	2
3.0	RADIATION ENVIRONMENTAL MONITORING PROGRAM (REMP)	3
4.0 5.0	 3.1 Program Design and Data Interpretation	3 4 5 6 6 6 7 7 7 7 7
	IDICES	
	Interlaboratory Comparison Program Results	A -1
~	Attachment 1, Acceptance Criteria for "Spiked" Samples	A-2
в	Data Reporting Conventions	B-1
С	Maximum Permissible Concentrations of Radioactivity in Air and Water Above Natural Background in Unrestricted Areas	C-1
D	Sampling Location Maps	D-1

TABLE OF CONTENTS

LIST OF TABLES

<u>No</u> .	Title	<u>Page</u>
5.1	Sample Collection and Analysis Program	15
5.2	Sampling Locations	16
5.3	Missed Collections and Analyses	19
5.4	Radiation Environmental Monitoring Program Summary	20
in ad	dition, the following tables are in the Appendices:	

Appendix A

A1-1	Environmental Resources Associates,	A-1
A2-1	Program Results; (TLDs)	A-2
A3-1	In-house "Spiked" Samples	A-3
A4-1	In-house "Blank" Samples	A-4
A5-1	In-house "Duplicate" Samples	A-5
A6-1	Department of Energy MAPEP compa	A-6

Appendix C

C-1	Maximum Permissible Concentrations of Radioactivity in Air and Water
	Above Natural Background in Unrestricted AreasC-2

LIST OF FIGURES

<u>No</u> .	<u>Title</u>	<u>Page</u>
5.1	Offsite Ambient Radiation (TLDs), average of inner and outer ring indicator locations versus control	13
5.2	Airborne Particulates; analysis for gross beta, average mean of all indicator locations (P-2,3,4,6) versus control location (P-1)	14

.

1.0 INTRODUCTION

This report summarizes and interprets results of the Radiation Environmental Monitoring Program (REMP) conducted by Environmental, Inc., Midwest Laboratory at the Prairie Island Nuclear Generating Plant, Red Wing, Minnesota, during the period January - December, 2005. This program monitors the levels of radioactivity in the air, terrestrial, and aquatic environments in order to assess the impact of the plant on its surroundings.

Tabulations of the individual analyses made during the year are not included in this report. These data are included in a reference document (Environmental, Inc., Midwest Laboratory, 2006b) available at Prairie Island Nuclear Generating Plant.

Prairie Island Nuclear Generating Plant is located on the Mississippi River in Goodhue County, Minnesota, owned by Xcel Energy Corporation and operated by Nuclear Management Company, LLC. The plant has two 575 MWe pressurized water reactors. Unit 1 achieved initial criticality on 1 December 1973. Commercial operation at full power began on 16 December 1973. Unit 2 achieved initial criticality on 17 December 1974. Commercial operation at full power began on 21 December 1974.

2.0 SUMMARY

The Radiation Environmental Monitoring Program (REMP) required by the U.S. Nuclear Regulatory Commission (NRC) Technical Specifications for the Prairie Island Nuclear Generating Plant and the Independent Spent Fuel Storage Installation (ISFSI) is described. Results for 2005 are summarized and discussed.

Program findings show background levels of radioactivity in the environmental samples collected in the vicinity of the Prairie Island Nuclear Generating Plant.

3.0 RADIATION ENVIRONMENTAL MONITORING PROGRAM (REMP)

3.1 Program Design and Data Interpretation

The purpose of the Radiation Environmental Monitoring Program (REMP) at the Prairie Island Nuclear Generating Plant is to assess the impact of the plant on its environment. For this purpose, samples are collected from the air, terrestrial, and aquatic environments and analyzed for radioactive content. In addition, ambient gamma radiation levels are monitored by thermoluminescent dosimeters (TLDs).

Sources of environmental radiation include the following:

- Natural background radiation arising from cosmic rays and primordial radionuclides;
- (2) Fallout from atmospheric nuclear detonations;
- Releases from nuclear power plants;
- (4) Industrial and medical radioactive waste; and
- (5) Fallout from nuclear accidents.

In interpreting the data, effects due to the plant must be distinguished from those due to other sources.

A major interpretive aid in assessment of these effects is the design of the monitoring program at the Prairie Island Plant which is based on the indicator-control concept. Most types of samples are collected both at indicator locations (nearby, downwind, or downstream) and at control locations (distant, upwind, or upstream). A plant effect would be indicated if the radiation level at an indicator location was significantly larger than that at the control location. The difference would have to be greater than could be accounted for by typical fluctuations in radiation levels arising from other sources.

An additional interpretive technique involves analyses for specific radionuclides present in the environmental samples collected from the plant site. The plant's monitoring program includes analyses for tritium and iodine-131. Most samples are also analyzed for gamma-emitting isotopes with results for the following groups quantified: zirconium-95, cesium-137, cerium-144, beryllium-7, and potassium-40. The first three gamma-emitting isotopes were selected as radiological impact indicators because of the different characteristic proportions in which they appear in the fission product mix produced by a nuclear reactor and that produced by a nuclear detonation. Each of the three isotopes is produced in roughly equivalent amounts by a reactor: each constitutes about 10% of the total activity of fission products 10 days after reactor shutdown. On the other hand, 10 days after a nuclear explosion, the contributions of zirconium-95, cerium-144, and cesium-137 to the activity of the resulting debris are in the approximate ratio 4:1:0.03 (Eisenbud, 1963). Beryllium-7 is of cosmogenic origin and potassium-40 is a naturally-occurring isotope. They were chosen as calibration monitors and should not be considered radiological impact indicators.

The other group quantified consists of niobium-95, ruthenium-103 and -106, cesium-134, barium-lanthanum-140, and cerium-141. These isotopes are released in small quantities by nuclear power plants, but to date their major source of injection into the general environment has been atmospheric nuclear testing. Nuclides of the final group, manganese-54, iron-59, cobalt-58 and -60, and zinc-65, are activation products and arise from activation of corrosion products. They are typical components of a nuclear power plant's effluents, but are not produced in significant quantities by nuclear detonations.

3.1 Program Design and Data Interpretation (continued)

Other means of distinguishing sources of environmental radiation are employed in interpreting the data. Current radiation levels are compared with previous levels, including those measured before the Plant became operational. Results of the plant's monitoring program can be related to those obtained in other parts of the world. Finally, results can be related to events known to cause elevated levels of radiation in the environment, e.g., atmospheric nuclear detonations.

3.2 Program Description

The sampling and analysis schedule for the radiation environmental monitoring program at Prairie Island is summarized in Table 5.1 and briefly reviewed below. Table 5.2 defines the sampling location codes used in Table 5.1 and specifies for each location its type (indicator or control) and its distance, direction, and sector relative to the reactor site or ISFSI facility, as appropriate. To assure that sampling is carried out in a reproducible manner, detailed sampling procedures have been prescribed (Prairie Island Nuclear Generating Plant, 2005). Maps of fixed sampling locations are included in Appendix D.

To monitor the air environment, airborne particulates are collected on membrane filters by continuous pumping at five locations. Airborne iodine is collected by continuous pumping through charcoal filters at these same locations. Filters are changed and counted weekly. Particulate filters are analyzed for gross beta activity and charcoal filters for iodine-131. Quarterly composites of particulate filters from each location are determined by gamma spectroscopy. One of the five locations is a control (P-1), and four are indicators (P-2, P-3, P-4, and P-6).

Offsite ambient gamma radiation is monitored at thirty-four locations, using CaSO₄:Dy dosimeters with four sensitive areas at each location: ten in an inner ring in the general area of the site boundary, fifteen in the outer ring within a 4-5 mile radius, eight at special interest locations, and one control location, 11.1 miles distant from the plant. They are replaced and measured quarterly. Also, a complete emergency set of TLDs for the inner ring, outer ring and special interest locations are placed in the field at the same time as regular sets. The emergency set is returned to EIML quarterly for annealing and repackaging.

Ambient gamma radiation is monitored at the Independent Spent Fuel Storage Installation (ISFSI) Facility by twenty CaSO₄:Dy dosimeters. Twelve dosimeters are located inside of the earthen berm in direct line of sight from the storage casks and eight dosimeters are located outside of the earthen berm. They are replaced and measured quarterly.

Milk samples are collected monthly from six farms (five indicator and one control) and analyzed for iodine-131 and gamma-emitting isotopes. The milk is collected biweekly during the growing season (May - October), because the milk animals may be on pasture.

For additional monitoring of the terrestrial environment, green leafy vegetables (cabbage) are collected annually from the highest D/Q garden and a control location (P-38), and analyzed for gamma-emitting isotopes, including iodine-131. Corn is collected annually only if fields are irrigated with river water and analyzed for gamma-emitting isotopes. Well water and ground water are collected quarterly from four locations near the plant and analyzed for tritium and gamma-emitting isotopes.

River water is collected weekly at two locations, one upstream of the plant (P-5) and one downstream (P-6, Lock and Dam No.3). Monthly composites are analyzed for gamma-emitting isotopes. Quarterly composites are analyzed for tritium.

3.2 Program Description (continued)

Drinking water is collected weekly from the City of Red Wing well. Monthly composites are analyzed for gross beta, iodine-131, and gamma-emitting isotopes. Quarterly composites are analyzed for tritium.

The aquatic environment is also monitored by semi-annual upstream and downstream collections of fish, periphyton or invertebrates, and bottom sediments. Shoreline sediment is collected semi-annually from one location. All samples are analyzed for gamma-emitting isotopes.

3.3 Program Execution

The Program was executed as described in the preceding section with the following exceptions:

(1) No milk was available from location P-44 for the months of January, February, March, November and December, 2005.

Deviations from the program are summarized in Table 5.3.

3.4 Laboratory Procedures

Analyses for iodine-131 in milk and drinking water utilize a sensitive radiochemical procedure involving the separation of the element by ion-exchange and subsequent beta counting. Gamma-spectroscopic analysis is performed using a high-purity germanium (HPGe) detector. Levels of airborne iodine-131 in charcoal samples are measured by gamma spectroscopy.

Levels of iodine-131 in cabbage are determined by gamma spectrometry.

Tritium levels are determined by liquid scintillation technique.

Analytical Procedures used by Environmental, Inc. are on file and are available for inspection. Procedures are based on those prescribed by the Health and Safety Laboratory of the U.S. Dep't of Energy, Edition 28, 1997, U.S. Environmental Protection Agency for Measurement of Radioactivity in Drinking Water, 1980, and the U.S. Environmental Protection Agency, EERF, Radiochemical Procedures Manual, 1984.

Environmental, Inc., Midwest Laboratory has a comprehensive quality control/quality assurance program designed to assure the reliability of the data obtained. Details of the Quality Assurance Program are presented elsewhere (Environmental, Inc., Midwest Laboratory, 2003). The program includes participation in Interlaboratory Comparison (Crosscheck) programs and results are presented in Appendix A.

3.5 Program Modifications

The Yoemans' Farm (P-44) was added to the program in January, 2005, as an indicator location for goat milk.

3.6 Land Use Census

In accordance with the Prairie Island Nuclear Generating Plant Offsite Dose Calculation Manual, H4, (ODCM) a land use census is conducted in order to identify the location of the nearest milk animal, the nearest residence, and the nearest garden of greater than 500 ft² producing fresh leafy vegetables in each of the 16 meteorological sectors within a distance of 5 miles. This census is conducted at least once per 12 months between the dates of May 1 and October 31. If new locations yield a calculated dose or dose equivalent (via the same exposure pathway) twenty percent greater than the required locations per the ODCM, then the new locations are added to the radiation environmental monitoring program within 30 days, and sampling locations having lower calculated doses or a lower dose commitment may be deleted from this monitoring program after October 31 of the year in which the land use census was conducted.

This land use census insures the updating of the radiation environmental monitoring program should sampling locations change within the 5 mile radius from the plant.

The Land Use Census was completed in August and September, 2005. There were no changes to any of the highest D/Q locations for nearest residence, milk animal or garden sites. A goat dairy location was established in 2005 with a higher D/Q than the other dairy farms. The critical receptor location did not change in 2005, based on the results of the land use census.

No downstream irrigation of corn was discovered within 5 miles of the Prairie Island Plant. Therefore, no corn samples were collected for analysis.

4.0 RESULTS AND DISCUSSION

All scheduled collections and analyses were made except those listed in Table 5.3.

The results are summarized in Table 5.4 in a format recommended by the Nuclear Regulatory Commission in Regulatory Guide 4.8. For each type of analysis of each sampled medium, this table lists the mean and range for all indicator locations and for all control locations. The locations with the highest mean and range are also shown.

4.1 Atmospheric Nuclear Detonations and Nuclear Accidents

There were no reported atmospheric nuclear tests in 2005. The last reported test was conducted on October 16, 1980 by the People's Republic of China. There were no reported accidents involving a release to the environment at nuclear reactor facilities in 2005.

4.2 Summary of Preoperational Data

The following constitutes a summary of preoperational studies conducted at the Prairie Island Nuclear Power Plant during the years 1970 to 1973, to determine background levels expected in the environment, and provided, where applicable, as a means for comparison with present day levels. Strict comparisons, however, are difficult, since background levels of radiation were much higher in these years due to radioactive fallout from the atmosphere. Gross beta measurements in fallout declined yearly from a level of 12,167 pCi/m² to 1,020 pCi/m², and these declining values are reflected throughout the various media tested.

In the air environment, ambient gamma radiation (TLDs) averaged 9.4 mR/4 weeks during preoperational studies. Gross beta in air particulates declined from levels of 0.38 to 0.037 pCi/m³. Average present day levels have stabilized at around 0.025 pCi/m³. Airborne radioiodine remained below detection levels.

in the terrestrial environment of 1970 to 1973, milk, agricultural crops, and soil were monitored. In milk samples, low levels of Cs-137, I-131, and Sr-90 were detected. Cs-137 levels declined from 16.5 to 8.6 pCi/L. Present day measurements for both Cs-137 and I-131 are below detection levels. Agricultural crop measurements averaged 57.7 pCi/g for gross beta and 0.47 pCi/g for Cs-137. Gross beta measured in soil averaged 52 pCi/g.

The aqueous environment was monitored by testing of river , well and lake waters, bottom sediments, fish , aquatic vegetation and periphyton. Specific location comparison of drinking, river and well water concentrations for tritium and gross beta are not possible. However, tritium background levels, measured at eight separate locations, declined steadily from an average concentration of 1020 pCi/L to 490 pCi/L. Present day environmental levels of tritium are below detection limits. Values for gross beta, measured from 1970 to 1973, averaged 9.9 pCi/L in downstream Mississippi River water, 8.2 pCi/L for well water, and 11.0 pCi/L for lake water. Gamma emitters were below the lower limit of detection (LLD). In bottom sediments, gross beta background levels were determined at 51.0 pCi/g. Cs-137 activity during preoperational studies in 1973 measured 0.25 pCi/g upstream and 0.21 pCi/g downstream. The lower levels occasionally observed today can still be attributed to residual activity from atmospheric fallout. Gross beta in fish, measured in both flesh and skeletal samples, averaged 7.3 and 11.7 pCi/g, respectively. Gross beta background levels in aquatic vegetation, algae and periphyton samples measured 76.0 pCi/g, 46.0 pCi/g, and 13.6 pCi/g, respectively.

4.3 Program Findings

Slight tritium activity was detected in two downstream river water composites (pg. 11). It was determined that the collections coincided with planned radioactive discharges from the plant. All other results indicate background levels of radioactivity in environmental samples collected in the vicinity of the Prairie Island Nuclear Generating Plant.

Ambient Radiation (TLDs)

Ambient radiation was measured in the general area of the site boundary, at the outer ring 4 - 5 mi distant from the Plant, at special interest areas and at one control location. The means ranged from 16.3 mR/91 days at inner ring locations to 17.2 mR/91 days at outer ring locations. The mean at special locations was 16.1 mR/91 days and 16.3 mR/91 days at the control location. Dose rates measured at the inner and outer ring and the control locations were similar to those observed from 1990 through 2004. The results are tabulated below. No plant effect on ambient gamma radiation was indicated (Figure 5-1).

<u>Year</u>	Average (<u>Inner and</u> Outer Rings)	Control	Year	Average (Inner and Outer Rings)	<u>Control</u>
1990	15.9	16.3	1998	16.7	17.3
1991	14.9	14.5	1999	16.6	17.5
1992	16.3	14.8	2000	17.0	17.1
1993	15.9	15.4	2001	16.8	17.2
1994	15.2	16.0	2002	17.4	16.9
1995	15.6	16.6	2003	16.2	16.0
1996	14.8	16.4	2004	17.6	17.6
1997	15,1	16.0	2005	16.8	16.3

Ambient gamma radiation as measured by thermoluminescent dosimetry. Average quarterly dose rates (mR/91 days).

ISFSI Facility Operations Monitoring

Ambient radiation was measured inside the ISFSI earth berm, outside the ISFSI earth berm and at two special locations between the plant ISFSI and the Prairie Island Indian Community. The mean dose rates measured 86.2 mR/91 days inside the ISFSI earth berm and 20.2 mR/91 days outside the ISFSI earth berm. Three additional casks were placed on the ISFSI pad in 2005, a total of twenty loaded casks remain. The higher levels inside the earth berm are expected, due to the loaded spent fuel casks being in direct line-of-sight of the TLDs.

Ambient radiation levels measured outside the earth berm show a slight increase as compared to other offsite dose rates around the plant. If the dose rates outside the earth berm are an indication of gamma skyshine from the casks, they are consistent with predictions given in the ISFSI Safety Analysis Report, Table 7A-7, "Total Skyshine Dose Rate". The cumulative average of the two special Prairie Island Indian Community TLDs measured 15.9 and 15.5 mR/91 days. Although the skyshine neutron dose rates are not directly measured, the neutron levels measured next to the casks are below the levels predicted in the ISFSI SAR Report, Table 7A-4, "TN-40 Dose Rates at Short Distances". Therefore, the skyshine dose rates at farther distances from the casks should be at or below the calculated dose rates. No spent fuel storage effect on offsite ambient gamma radiation was indicated (Fig. 5-1).

Airborne Particulates

Average annual gross beta concentrations in airborne particulates were slightly higher at indicator versus control locations (0.027 pCi/m³ and 0.025 pCi/m³, respectively) and similar to levels observed from 1990 through 2004. The results are tabulated below.

	Average of	
<u>Year</u>	Indicators	Control
	Concentratio	<u>n (pCi/m³)</u>
1990	0.024	0.023
1991	0.025	0.025
1992	0.023	0.021
1993	0.022	0.019
1994	0.022	0.022
1995	0.022	0.022
1996	0.023	0.020
1997	0.021	0.021
1998	0.022	0.018
1999	0.024	0.022
2000	0.025	0.025
2001	0.023	0.023
2002	0.028	0.023
2003	0.027	0.025
2004	0.025	0.026
2005	0.027	0.025

Average annual gross beta concentrations in airborne particulates.

A spring peak in beta activity had been observed almost annually for many years (Wilson et al., 1969). It had been attributed to fallout of nuclides from the stratosphere (Gold et al., 1964). It was pronounced in 1981, occurred to a lesser degree in 1982, and has not occurred since 1983. Typically, the highest averages for gross beta occur during the months of January and December, and the first and fourth quarters, as in 1990 through 2005.

Two pieces of evidence indicate conclusively that the elevated activity observed during the winter months was not attributable to the Plant operation. In the first place, elevated activity of similar size occurred simultaneously at both indicator and control locations. Secondly, an identical pattern was observed at the Monticello Nuclear Generating Plant, about 100 miles distant from the Prairie Island Nuclear Generating Plant (Xcel Energy Corp., 2006).

Gamma spectroscopic analysis of quarterly composites of air particulate filters yielded similar results for indicator and control locations. Beryllium-7, which is produced continuously in the upper atmosphere by cosmic radiation (Arnold and Al-Salih, 1955), was detected in all samples. All other gamma-emitting isotopes were below their respective LLD limits.

Airborne lodine

Weekly levels of airborne iodine-131 were below the lower limit of detection (LLD) of 0.03 pCi/m^3 in all samples. There was no indication of a plant effect.

lodine-131 results were below the detection limit of 0.5 pCi/L in all samples. Cs-137 results were below the LLD level of 5 pCi/L in all samples. No other gamma-emitting isotopes, except naturally-occurring potassium-40, were detected in any milk samples. This is consistent with the findings of the National Center for Radiological Health that most radiocontaminants in feed do not find their way into milk due to the selective metabolism of the cow. The common exceptions are radioisotopes of potassium, cesium, strontium, barium, and iodine (National Center for

In summary, the milk data for 2005 show no radiological effects of the plant operation,

Drinking Water

Radiological Health, 1968).

In drinking water from the City of Red Wing well, tritium activity measured below the LLD level of 179 pCi/L in all samples.

Gross beta concentrations averaged 11.5 pCi/L throughout the year, ranging from 8.3–14.0 pCi/L. These concentrations were similar to or slightly higher than levels observed from 1990 through 2004. The most likely contribution is the relatively high levels of naturally-occurring radium. Gamma spectroscopy indicates the presence of lead and bismuth isotopes, which are daughters of the radium decay chain. There is no indication from the 2005 data of any effect of plant operation.

<u>Year</u>	Gross Beta (pCi/L)
1990	7.0
1991	8.0
1992	7.6
1993	7.5
1994	5.8
1995	3.9
1996	6.3
1997	5.1
1998	5.4
1999	5.3
2000	10.1
2001	8.3
2002	8.7
2003	9.9
2004	9.8
2005	11.5

Average annual concentrations; Gross beta in drinking water.

River Water

For the first and fourth quarters of 2005, measurable tritium was detected in downstream river water composites, at concentrations of 478 and 214 pCi/L, respectively. This is well below the Environmental Protection Agency's drinking water standard of 20,000 pCi/L. For the remaining upstream and downstream collections, tritium levels measured below the LLD level of 173 pCi/L.

Gamma-emitting isotopes were below detection limits in all samples.

Well Water

At the control well P-43, Huppert Farm and four indicator wells (P-8, Community Center, P-6, Lock and Dam No. 3, P-9, Plant Well No. 2 and P-24, Suter Farm) no tritium was detected above the LLD level of 194 pCi/L. Gamma-emitting isotopes were below detection limits in all samples.

In summary, well water data for 2005 show no radiological effects of the plant operation.

<u>Crops</u>

Three samples of broadleaf vegetation, cabbage leaves, were collected in July and analyzed for gamma-emitting isotopes, including iodine-131. The I-131 level was below 0.013 pCi/g wet weight in all samples. With the exception of naturally-occurring potassium-40, all other gamma-emitting isotopes were below their respective detection limits. There was no indication of a plant effect.

Field sampling personnel conducted an annual land use survey and found no river water taken for irrigation into fields within 5 miles downstream from the Prairie Island Plant. The collection and analysis of corn samples was not required.

<u>Fish</u>

Fish samples were collected in May and September, 2005 and analyzed for gamma emitting isotopes. Only naturally-occurring potassium-40 was detected, and there was no significant difference between upstream and downstream results. There was no indication of a plant effect.

Aquatic Insects or Periphyton

Aquatic insects (invertebrates) or periphyton were collected in May and September, 2005. With the exception of naturally occurring potassium-40, all gamma-emitting isotopes were below their respective detection limits. There was no indication of a plant effect.

Bottom and Shoreline Sediments

Upstream, downstream and downstream recreational area shoreline sediment collections were made in May and September, 2005 and analyzed for gamma-emitting isotopes. Trace levels of cesium-137 were detected in two of the six samples collected, measuring 0.026 pCi/g dry weight in one downstream sample and one control sample, indicating the influence of fallout deposition. The only other gamma-emitting isotopes detected were naturally-occurring beryllium-7 and potassium-40. There was no indication of a plant effect.

5.0 FIGURES AND TABLES



.

Figure 5-1. Offsite Ambient Radiation (TLDs); average of inner and outer ring indicator locations versus control location.





Figure 5-2. Airborne Particulates; analysis for gross beta, average mean of all indicator locations versus control location.

PRAIRIE ISLAND

<u></u>			Collection	Analysis
		Location	Type and	Type and
Medium	No.	Codes (and Type)*	Frequency	Frequency
Ambient radiation (TLD's)	54	P-01A - P-10A	C/Q	Ambient gamma
		P-01B - P-15B		
		P-01S - P-08S		
		P-01IA - P-08IA		
		P-01IB - P-08IB		
		P-01IX- P-04IX, P-01C		
Airborne Particulates	5	P-1(C), P-2.	c/W	GB, GS (QC of
		P-3, P-4, P-6	-,	each location)
Airborne Iodine	5	P-1(C), P-2, P-3, P-4, P-6	C/W	I-131
Milk	5	P-14, P-18, P-37, P-42, P-44,	G∕M⁴	1-131, GS
		P-43 (C)		
River water	2	P-5(C), P-6	G/W	GS(MC), H-3(QC)
Drinking water	1	P.11	G/W	GB(MC) L131(MC)
	-		G / H	GS (MC), H-3 (QC)
Weil water	5	P-6, P-8, P-9, P-24,	G/Q	H-3, G5
		P-43 (C)		
Edible cultivated crops -	2	P-38(C), P-24	G/A	GS (1-131)
leafy green vegetables	-		•)	
Fish (one species, edible portion)	2	P-19(C), P-13	G/SA	GS
Davishutan as lavast-bustos	~		0/54	<u></u>
renphyton or invertebrates	2	r-40(c), r-6	G/SA	65
Bottom sediment	2	P-20(C), P-6	G/SA	GS
		• •		
Shoreline sediment	1	P-12	G/SA	GS

Table 5.1. Sample collection and analysis program, Prairie Island Nuclear Generating Plant.

^a Location codes are defined in Table D-2. Control stations are indicated by (C). All other stations are indicators.

^b Collection type is coded as follows: C/ = continuous, G/ = grab. Collection frequency is coded as follows:

W= weekly, M = monthly, Q = quarterly, SA = semiannually, A = annually.

^c Analysis type is coded as follows: GB = gross beta, GS = gamma spectroscopy, H-3 = tritlum, H131 = lodine-131.

Analysis frequency is coded as follows: MC = monthly composite, QC = quarterly composite.

^d Milk is collected biweekly during the grazing season (May - October).

Та	ble 5.2.	Sampling	locations,	Prairie	Island Nuclear	Generating Plant.	
						-	

Code	Type"	Collection Site	Sample Type [®]	Distance and Direction from Reactor
P-1	с	Air Station P-1	AP, AI	11.8 mi @ 316°/NNW
P-2		Air Station P-2	AP, AI	0.5 mi@294°/WNW
P-3		Air Station P-3	AP, AI	0.8 mi @ 313°/NW
P-4		Air Station P-4	AP, AI	0.4 mi @ 359°/N
P-5	С	Upstream of Plant	RW	1.8 mi @ 11°/N
P-6		Lock and Dam #3 & Air	AP, AI, RW	
		Station P-6	WW, BS, BO ^c	1.6 mi @ 129°/SE
P-8		Community Center	ww	1.0 mi @ 321°/WNW
P.g		Plant Well #2	ww	0.3 mi @ 306°/NW
P-11		Red Wing Service Center	DW	3.3 mi @ 158°/SSE
P-12		Downstream of Plant	SS	3.0 mi @ 116°/ESE
P-13		Downstream of Plant	F	3.5 mi @ 113°/ESE
P-14		Gustafson Farm	M	2.3 mi @ 173°/S
P-18		Christiansen Farm	M	3.8 mi @ 88°/E
P-19	С	Upstream of Plant	F	1.3 mi @ 0°/N
P-20	С	Upstream of Plant	BS	0.9 mi @ 45°/NE
P-24		Suter Residence	VE, WW	0.6 mi @ 158°/SSE
P-37		Welsch Farm	M	4.1 mi @ 87°/E
P-38	с	Cain Residence	VE	14.2 mi @ 359°/N
P-40	с	Upstream of Plant	BO°	0.4 mi @ 0°/N
P-42		Rother Farm	M	4.3 mi. @ 264°/W
P-43	С	Peterson Farm	M, WW	13.9 mi. @ 355°/N
P-44		Yoemans Farm	M	2.0 mi. @ 214°/SW
<u>General</u>	Area of t	he Site Boundary		
P-01A		Property Line	TLD	0.4 mi @ 359°/N
P-02A		Property Line	TLD	0.3 mi @ 10°/N
P-03A		Property Line	TLD	0.5 mi @ 183°/S
P-04A		Property Line	TLD	0.4 mi @ 204°/SWW
P-05A		Property Line	TLD	0.4 mi @ 225°/SW
P-06A		Property Line	TLD	0.4 mi @ 249°/WSW
P-07A		Property Line	TLD	0.4 mí @ 268°/W
P-08A		Property Line	TLD	0.4 mi @ 291°/WNW
P-09A		Property Line	TLD	0.7 ml@317°/NW
P-10A		Property Line	TLD	0.5 mi @ 333°/NNW

PRAIRIE ISLAND

. .			•	Distance and Direction from
Code	Туре"	Collection Site	Sample Type"	Reactor
Approxim	nately 4 to	o 5 miles Distant from the Plant		
P-01B		Thomas Killian Residence	TLD	4.7 mi @ 355°/N
P-02B		Roy Kinneman Residence	TLD	4.8 ml @ 17°/NNE
P-03B		Wayne Anderson Farm	TLD	4.9 mi @ 46°/NE
P-04B		Nelson Drive (Road)	TLD	4.2 mi @ 61°/ENE
P-05B		County Road E and Coulee	TLD	4.2 ml @ 102°/ESE
P-06B		William Hauschibit Residence	TLD	4.4 mi @ 112°/ESE
P-07B		Red Wing Public Works	TLD	4.7 mi @ 140°/SE
P-088		David Wnuk Residence	TLD	4.1 mi @ 165°/SSE
P-098		Highway 19 South	TLD	4.2 mi @ 187°/S
P-108		Cannondale Farm	TLD	4.9 ml @ 200°/SSW
- <u>118</u>		Wallace Weberg Farm	TLD	4.5 mi @ 221°/SW
P-12B		Ray Gergen Farm	TLD	4.6 mi @ 251°/WSW
P-13B		Thomas O'Rourke Farm	TLD	4.4 mi @ 270°/W
P-14B		David J. Anderson Farm	TLD	4.9 mi @ 306°/NW
P-15B		Holst Farms	TLD	3.8 mi @ 345°/NNW
Special I	<u>ntereșt L</u> c	ocations		
P-01S		Federal Lock & Dam #3	TLD	1.6 mi @ 129°/SE
P-02S		Charles Suter Residence	TLD	0.5 mi @ 155°/SSE
P-03S		Carl Gustafson Farm	TLD	2.2 mi @ 173°/S
P-045		Richard Burt Residence	TLD	2.0 mi @ 202°/SSW
P-05S		Kinney Store	TLD	2.0 mi @ 270°/W
P-06S		Earl Flynn Farm	TLD	2.5 mi @ 299°/WNW
P-075		Indian Community	TLD	0.7 mi @ 271°/W
P-085		Indian Community	TLD	0.7 mi @ 287°/NWW
P-01C	С	Robert Kinneman Farm	TLD	11.1 ml @ 331°/NNW

Table 5.2. Sampling locations, Prairie Island Nuclear Generating Plant, (continued).

~ Code	Type"	Collection Site	Type of Sample ^⁵	Approximate Distance and Direction from ISFSI Center.
ISFSI Are	ea Inside I	Earth Berm		<u> </u>
P-01 A		ISFSI Nuisance Fence	TLD	190' @ 45°/NE
P-02IA		ISFSI Nuisance Fence	TLD	360' @ 82°/E
P-03IA		ISFSI Nuisance Fence	TLD	370' @ 100°/E
P-041A		ISFSI Nuisance Fence	TLD	200' @ 134°/SE
P-051A		ISFSI Nuisance Fence	TLD	180' @ 219°/SW
P-06IA		ISFSI Nuisance Fence	TLD	320' @ 258°/WSW
P-071A		ISFSI Nuisance Fence	TLD	320' @ 281°/WNW
P-08IA		ISFSI Nulsance Fence	TLD	190' @ 318°/NW
P-01IX		ISFSI Nuisance Fence	TLD	140' @ 1 80°/S
P-02IX		ISFSI Nuisance Fence	TLD	310' @ 270°/W
P-03IX		ISFSI Nuisance Fence	TLD	140' @ 0°/N
P-04IX		ISFSI Nuisance Fence	TLD	360' @ 90°/E
ISFSI Are	ea Outside	Earth Berm		
P-0118		ISFSI Berm Area	TLD	340' @ 3°/N
P-021B		ISFSI Berm Area	TLD	380' @ 28°/NNE
P-03IB		ISFSI Berm Area	TLD	560' @ 85°/E
P-04IB		ISFSI Berm Area	TLD	590' @ 165°/SSE
P-051B		ISFSI Berm Area	TLD	690' @ 186°/S
P-061B		ISFSI Berm Area	TLD	720' @ 201°/SSW
P-071B		ISFSI Berm Area	TLD	610' @ 271°/W
P-08IB		ISFSI Berm Area	TLD	360' @ 332°/NNW
* "C" den	otes cont	rol location. All other locations are indicator	S .	
Sample	e Codes:		_	-
	AP	Airborne particulates	F	Fish
	Al	Airborne lodine	M	Milk
	BS	Bottom (river) sediments	SS	Shoreline Sediments
	BO	Bottom organisms	SW	Surface Water
		(periphyton or macroinvertebrates)	VE	Vegetation/vegetables

PRAIRIE ISLAND

Table 5.2	Sampling locations	Prairie Island Nuclear Generating Pla	nt (continued)
	Anthrough the section of the section		ing teomanacay.

Ċ

⁶ Distance and direction data for fish and bottom organisms are approximate since availability of sample specimen may vary at any one location. Table 5.3. Missed collections and analyses at the Prairie Island Nuclear Generating Plant.

Sample Type	Analysis	Location	Collection Date or Period	Reason for not conducting REMP as required	Plans for Preventing Recurrence
MI	Gamma, I-131	P-44	Jan Mar. 2005	Goats were dry.	None, The goat milk is available during the grazing season.
MI	Gamma, I-131	P-44	Nov Dec. 2005	Goats were dry.	None, The goat milk is available during the grazing season.

All required samples were collected and analyzed as scheduled with the following exceptions:

Name of Facility			Prairie Island Nuclear Power Station			Docket No.	50-282, 50-306	
Locatio	on of Facility	, [`]	Goodhue, Minnesota		Reporting Period	porting Period January-December, 200		
			<u></u>	(County	/, State)		- <u>_</u> , <u> </u>	
				Indicator	Location with H	lighest	Control	Number
Sample	Type ar	и		Locations	Annual Me	an	Locations	Non-
Туре	Number	of	LLD	Mean (E) ^c	,	Mean (F) ^c	Mean (F) ^c	Routine
(Units)	Analyse	s"		Range	t ocation ^d	Range	Rance	Results*
(01#10)		<u> </u>		. tarige				
TLD (Inner Sing	Gamma	_∡∩	3.0	16.3 (40/40)	P-06A	17 5 (4/4)	/See Control	(
Area at Site	Variano	~	0.0	(13.2.17.0)	0.4 mi @ 240* MISWI	(17.5.17.5)	(000 Conalda below)	~ ~
Sind an unit.				(10.2-11.0)	0.4111 (g 243 70000	(17.0-17.0)	Deitow.j	
mBiO1 days)) 1	
11/03 (08 y 3)							[
TLD (Outer Riog	Gamma	60	30	17.2 (60/60)	P-028 Roy Kinneman	19 (4/4)	(See Control	0
4-5 mi_distant\	Conning		0.0	(14 1-19 8)	A B mi @ 17* /NNE	(18.6.19.6)	(Coc Control below)	
mR/91 days)				(14.1-15.0)	4.0 00 00 11 1000	(10.0-15.0)	Dolow.y	
maardayay								
TLD (Special	Gamma	22	30	16 1 (32/32)	P-03S Guetafson Farm	18.6 (4/4)	(See Control	
Interest Areas)	Canana	<i>92</i>	0.0	(13.9-19.3)	2.2 mi@ 173°/S	(18.4.19.3)	(dec control below)	
mB(01 days)				(10.9-19.0)	2.2 111 (22 17 0 7 3	(10.4-10.0)	00000.7	
(114314893)								
TLD (Control)	Commo		20	None	D.01C P. Kinnomen	46 2 (414)	16.2 (4)4)	
TED (Control)	Gamma	1	3.0	none		10.3 (4/4)	(15.4.16.0)	U I
metro (ays)					LITUR COST MARAAA	(15.4-10.9)	(10.4-10.5)	
							0.005 (50)50)	
Airborne	GB	265	0.005	0.027 (212/212)	P-06, Air Station	0.027 (53753)	0.025 (53/53)	U
Particulates	Ì		' I	(0.009-0.069)	1.6 mi@0,129*/SE	(0.011-0.066)	(0.011-0.061)	
(pCI/m ⁻)								
	GS	20				0.070 (111)	0.050 (114)	
	Be-7		0.015	0.068 (16/16)	P-03, Air Station	0.072 (4/4)	0.060 (4/4)	U
		ļ		(0.035-0.091)	0.8 mi @ 313" /NW	(0.043-0.091)	(0.032-0.085)	
	Mn-54		0.0006	< LLD	•	-		U
	Co-58		0.0006	< LLD	•	-	<uo< td=""><td>U</td></uo<>	U
	Co-60		0.0006	< LLD	-	-	< LLD	0
	Zn-65		0.0008	< LLD	-	-		U C
	Zr-Nb-	95	0.0008	< LLD	-	-		
	Ru-10	3	0.0008	< LLD	•	-		
	Ru-10	6 4	0.0052		-	•		
	Cs-13	4	0.0007		-	•		
	Cs-13		0.0007	<uo< td=""><td>•</td><td>-</td><td></td><td></td></uo<>	•	-		
	Ba-La	-14U -	0.0017		-	•		
	Ce-14	1	0.0015	< LLU	•	-		
	Ce-14	4	0.0041	< LLD	•	-		
<u> </u>				···				
Airborne Iodine	1-131	265	0.03	< LLD	-	-		
(point)	ł							
	1		,	F	1		1	

20

.

Name of	Facility
Location	of Facility

Goodhue, Minnesota (County, State)

Prairie Island Nuclear Power Station

Docket No. 50-282, 50-306 Reporting Period January-December, 2005

Location with Highest Control Number Indicator Annual Mean Locations Non-Type and Sample Locations LLD Mean (F)^c Mean (F)^c Routine Mean (F)^c Туре Number of Location^d Results* Range Range^c Analyses" Range^c (Units) Milk (pCI/L) I-131 103 1.0 < LLD -< LLD 0 . GS 103 1973 (13/13) 1382 (18/18) K-40 200 1474 (85/85) P-44, Yoemans Farm 0 (1284-1532) 2.0 mi. / SW (1800-2191) (1219-2191) < LLD Cs-134 0 15 < LLD < LLD 0 Cs-137 15 < LLD _ -< LLD 0 Ba-La-140 15 < LLD -• < LLD 0 **River Water** н-з 8 179 346 (2/4) P-6, Lock and Dam #3 346 (2/4) (pCi/L) (214-478) 1.6 mi @ 129º/SE (214-478) GS 24 < LLD 0 Mn-54 10 < LLD -< LLD 0 Fe-59 30 < LLD -< LLD 0 Co-58 10 < LLD . -< LLD 0 Co-60 < LLD _ -10 < LLD 0 Zn-65 30 < LLD --0 Zr-Nb-95 < LLD -< LLD 15 -< LLD 0 Cs-134 -10 < LLD -< LLD 0 Cs-137 10 < LLD • -0 -< LLD Ba-La-140 15 < LLD Ce-144 . < LLD 0 50 < LLD

Name of Facility	Prairie Island Nuclear Power Station	Docket No.	50-282, 50-306
Location of Facility	Goodhue, Minnesota	Reporting Period	January-December, 2005

(County, State)

Sample	Sample Type and			Indicator Locations	Location with Highest Annual Mean		Control Locations	Number Non-
Type (Units)	Numb Analy	er of ses	LLD ^b	Mean (F) ^c Range ^c	Location ^d	Mean (F) ^c Range ^c	Mean (F) ^c Range ^c	Routine Results [●]
Drinking Water (pCi/L)	GB	12	1.0	11.5 (12/12) (8.3-14.0)	P-11, Red Wing S.C. 3.3 ml @ 158° /SSE	11.5 (12/12) (8.3-14.0)	None	0
	1-131	12	1.0	` < LLD [′]		-	None	o
	H-3	4	179	< LLD	-	-	None	0
	GS	12						_
	Mn-	54	10	< LLD	-	-	None	0
	Fe-5	59	30	< LLD	-	-	None	0
	Co-	58	10	< LLD	-	-	None	0
	C0-6	60	10	< LLD	•	-	None	0
	Zn-6	55	30	< LLD	-	-	None	0
	Zr-N	lb-95	15	< LLD	-	-	None	0
	Cs-'	134	10	< LLD	-	-	None	0
	Cs-'	137	10	< LLD	-	-	None	U
	Ba-l	La-140	15	< LLD	-	-	None	0
	Ce-	144	45		-	-	NOR	0
Well Water (pCi/L)	н-з	20	1 94	< LLD	-	-	< LLD	0
	GS	20						
	Mn-	54	10	< LLD	-	-	< LLD	0
	Fe-5	59	30	< LLD	-	-	< LLD	0
	Co-	58	10	< LLD	-	-	< LLD	0
	Co-l	60	10	< LLD	· <u>-</u>	-	< LLD	o
1	Zn-f	65	30	< LLD	-	-	< LLD	0
	Zr-N	Nb-95	15	< LLD		-	< LLD	0
1	Cs-	134	10	< LLD		-	< LLD	0
	Cs-	137	10	< LLD	.	-	< LLD	0
	Ba-I	La-140	15	< LLD		-	< LLD	0
	Ce-	144	53	< LLD		-	< LLD	0
Crops - Cabbage (pCi/gwet)	ŀ-131	3	0.013	< LLD	-	-	< LLD	0

Name of Facility	Prairie Island Nuclear Power Station	Docket No.	50-282, 50-306
Location of Facility	Goodhue, Minnesota	Reporting Period	January-December, 2005
	(County, State)		

Sample			Indicator	Location with Highest		Control	Number
Type (Units)	Number of Analyses ⁴	uo	Mean (F) ^c Range ^c	Location ^d	Mean (F) ^c Range ^c	Mean (F) ^c Range ^c	Routine Results*
Fish	GS 4						
(pCi/g wet)	K-40	0.10	2.92 (2/2) (2.79-3.04)	P-19, Upstream 1.3 mi @ 0°/N	3.26 (2/2) (3.16-3.35)	3.26 (2/2) (3.16-3.35)	0
	Mn-54	0.018	< LLD	-	-	< LLD	0
	Fe-59	0.049	< LLD	•	-	< LLD	0
	Co-58	0.022	< LLD	-	-	< LLD	0
	Co-60	0.013	< LLD	-	-	< LLD	0
	Zn-65	0.034	< LLD	-	-	< LLD	0
	Zr-Nb-95	0.027	< LLD	•	-	< LLD	0
	Cs-134	0.018	< LLD	-	-	< LLD	0
	Cs-137	0.019	< LLD	-	-	< LLD	0
	Ba-La-140	0.047	< LLD	-	-	< LLD	0
Invertebrates	GS 4						,
(pCi/g wet)	Be-7	0.51	< LLD	-	-	< LLD	0
	K-40	0.90	0.96 (1/2)	P-6, Lock and Dam #3	0.96 (1/2)	< LLD	0
				1.6 mi @ 129°/SE			
	Mn-54	0.047	< LLD	-	-	< LLD	o
	Co-58	0.047	< LLD	•	-	< LLD	O
	Co-60	0.047	< LLD	-	-	< LLD	0
	Zn-65	0.10	< LLD	-	-	< LLD	0
	Zr-Nb-95	0.09	< LLD	-	-	< LLD	0
	Ru-103	0.076	< LLD	-	-	< LLD	0
	Ru-106	0.41	< LLD	-	-	< LLD	0
	Cs-134	0.054	< LLD	-	•	< LLD	0
	Cs-137	0.046	< LLD	-	-	< LLD	0
	Ba-La-140	0.16	< LLD	-	-	< LLD	0
	Ce-141	0.13	< LLD	-	-	< LLD	0

23

Name of Facility	Prairie Island Nuclear Power Station	Docket No.	50-282, 50-306
Location of Facility	Goodhue, Minnesota	Reporting Period	January-December, 2005

(County, State)

]		Indicator	Location with	lighest	Control	Number
Sample	Type and		Locations	Annual Me	an	Locations	Non-
Туре	Number of	LLD ^b	Mean (F) ^c	······································	Mean (F) ^c	Mean (F) ^c	Routine
(Units)	Analyses		Range	Location ^d	Range ^c	Range ^c	Results*
Bottom and	GS 6						
Shoreline	Be-7	0.22	0.40 (1/4)	P-20, Upstream	0.48 (1/2)	0.48 (1/2)	0
Sediments				0.9 mi. @ 45° /NE			
(pCi/g dry)	K-40	0.10	7.48 (4/4)	P-20, Upstream	10.33 (2/2)	10.33 (2/2)	о [.]
			(6.01-8.74)	0.9 mi. @ 45° /NE	(8.67-11.98)	(8.67-11.98)	
	Mn-54	0.016	< LLD	-	-	< LLD	0
	Co-58	0.021	< LLD	-	-	< LLD	0
}	Co-60	0.015	< LLD	-	-	< LLD	0
	Zn-65	0.061	< LLD	-	-	< LLD	0
	Zr-Nb-95	0.025	< LLD	-	-	< LLD	0
	Ru-103	0.030	< LLD	-	-	< LLD	0
-	Ru-106	0.12	< LLD	-	-	< LLD	0
	Cs-134	0.015	< LLD	-	-	< LLD	0
1	Cs-137	0.023	0.026 (1/2)	P-06, P-20	0.026 (1/2)	0.026 (1/2)	0
	Ba-La-140	0.058	< LLD	-	-	< LLD	0
1	Ce-141	0.061	<lld< td=""><td>-</td><td></td><td>< LLD</td><td>0</td></lld<>	-		< LLD	0
	Ce-144	0.13	< LLD	-	-	< LLD	0
1	1				1	l	

^a GB = gross beta, GS = gamma scan.

^b LLD = nominal lower limit of detection based on a 4.66 sigma counting error for background sample.

^c Mean and range are based on detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (F).

^d Locations are specified: (1) by name, and/or station code (Table 2) and (2) by distance (miles) and direction relative to reactor site.

* Non-routine results are those which exceed ten times the control station value. If no control station value is available, the result is considered non-routine if it exceeds ten time the typical preoperational value for the medium or location.

6.0 <u>REFERENCES CITED</u>

Arnold, J. R. and H. A. Al-Salih. 1955. Beryllium-7 Produced by Cosmic Rays. Science 121: 451-453.

Eisenbud, M. 1963. Environmental Radioactivity, McGraw-Hill, New York, New York, pp. 213, 275 and 276.

Environmental, Inc., Midwest Laboratory

2

- _____ 2001a through 2006a. Radiation Environmental Monitoring for Monticello Nuclear Generating Plant, Complete Analysis Data Tables, January-December, 2000 through 2005.
- _____ 2001b through 2006b. Radiation Environmental Monitoring for Prairie Island Nuclear Generating Plant, Complete Analysis Data Tables, January - December, 2000-2005.
- 2003. Quality Assurance Program Manual, Rev. 0, 01 October 2003.
- ______2005. Quality Control Procedures Manual, Rev. 1, 17 September 2005.
- _____ 2003. Quality Control Program, Rev. 0, 21 August 2003.
- Gold, S., H. W. Barkhau, B. Shlein, and B. Kahn, 1964. Measurement of Naturally Occurring Radionuclides in Air, in the Natural Environment, University of Chicago Press, Chicago, Illinois, 369-382.

Hazleton Environmental Sciences Corporation.

_____ 1979a to 1983a. Radiation Environmental Monitoring for Monticello Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1978 through 1982.

_____1979b to 1983b. Radiation Environmental Monitoring for Prairie Island Nuclear Generating Plant, Complete Analysis Data Tables, January - December 1978 through 1982.

- Hohenemser, C. M. Deicher, A. Ernst, H. Hofsass, G. Lindner, E. Racknagel. 1986. "Chernobyl," Chemtech, October 1986, pp. 596-605.
- National Center for Radiological Health, 1968. Radiological Health and Data Reports, Vol. 9, No. 12, 730-746.

Northern States Power Company.

_____1972. Prairie Island Nuclear Generating Plant, Environmental Monitoring and Ecological Studies Program, January 1, 1971 to December 31, 1971. Minneapolis, Minnesota.

_____1973. Prairie Island Nuclear Generating Plant, Environmental Monitoring and Ecological Studies Program, January 1, 1972 to December 31, 1972. Minneapolis, Minnesota.

______1974. Prairie Island Nuclear Generating Plant, Environmental Monitoring and Ecological Studies Program, Volume 1, January 1, 1973 to December 31, 1973. Minneapolis, Minnesota.

_____1979 to 2003. Prairie Island Nuclear Generating Plant, Annual Radiation Environmental Monitoring Report to the U.S. Nuclear Regulatory Commission, January 1 to December 31, 1978 through 2002. Minneapolis, Minnesota.

6.0 REFERENCES CITED (continued)

- Prairie Island Nuclear Generating Plant, 2005. Radiological Environmental Monitoring for Prairie Island Nuclear Generating Plant, Radiation Protection Implementing Procedures, 4700 series.
- Teledyne Brown Engineering Environmental Services, Midwest Laboratory. 1984a to 2000a. Radiation Environmental Monitoring for Monticello Nuclear Generating Plant, Complete Analysis Data Tables, January - December, 1983 through 1999.
 - _____ 1984b to 2000b. Radiation Environmental Monitoring for Prairie Island Nuclear Generating Plant, Complete Analysis Data Tables, January - December, 1983 through 1999.
- U.S. Dep't of Energy 1997 HASL-300, Edition 28, Procedures Manual, Environmental Measurements Laboratory, New York, NY.
- U.S. Environmental Protection Agency. 1980. Prescribed Procedures for Measurement of Radioactivity in Drinking Water, Cincinnati, Ohio (EPA-600/4-80-032).

_____1984. Eastern Environmental Radiation Facility, Radiochemistry Procedures Manual, Montgomery, Alabama (EPA-520/5-84-006).

- Wilson, D. W., G. M. Ward and J. E. Johnson. 1969. In Environmental Contamination by Radioactive Materials, International Atomic Energy Agency. p.125.
- Xcel Energy Corporation. 2006. Monticello Nuclear Generating Plant, Annual Radiation Environmental Monitoring Report to the U.S. Nuclear Regulatory Commission, January 1 to December 31, 2005 (prepared by Environmental, Inc., Midwest Laboratory). Northbrook, Illinois



700 Landwehr Road • Northbrook, IL 60062-2310 ph. (647) 564-0700 • fax (647) 564-4517

APPENDIX A

INTERLABORATORY COMPARISON PROGRAM RESULTS

NOTE: Environmental Inc., Midwest Laboratory participates in intercomparison studies administered by Environmental Resources Associates, and serves as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada. Results are reported in Appendix A. TLD Intercomparison results, in-house spikes, blanks, duplicates and mixed analyte performance evaluation program results are also reported. Appendix A is updated four times a year; the complete Appendix is included in March, June, September and December monthly progress reports only.

January, 2005 through December, 2005

Appendix A

Interlaboratory Comparison Program Results

Environmental, Inc., Midwest Laboratory has participated in interlaboratory comparison (crosscheck) programs since the formulation of it's quality control program in December 1971. These programs are operated by agencies which supply environmental type samples containing concentrations of radionuclides known to the issuing agency but not to participant laboratories. The purpose of such a program is to provide an independent check on a laboratory's analytical procedures and to alert it of any possible problems.

Participant laboratories measure the concentration of specified radionuclides and report them to the issuing agency. Several months later, the agency reports the known values to the participant laboratories and specifies control limits. Results consistently higher or lower than the known values or outside the control limits indicate a need to check the instruments or procedures used.

Results in Table A-1 were obtained through participation in the environmental sample crosscheck program administered by Environmental Resources Associates, serving as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada.

The results in Table A-2 list results for thermoluminescent dosimeters (TLDs), via International Intercomparison of Environmental Dosimeters, when available, and internal laboratory testing.

Table A-3 lists results of the analyses on in-house "spiked" samples for the past twelve months. All samples are prepared using NIST traceable sources. Data for previous years available upon request.

Table A-4 lists results of the analyses on in-house "blank" samples for the past twelve months. Data for previous years available upon request.

Table A-5 list results of the in-house "duplicate" program for the past twelve months. Acceptance is based on the difference of the results being less than the sum of the errors. Data for previous years available upon request.

The results in Table A-6 were obtained through participation in the Mixed Analyte Performance Evaluation Program.

Attachment A lists acceptance criteria for "spiked" samples.

Out-of-limit results are explained directly below the result.

Attachment A

ACCEPTANCE CRITERIA FOR "SPIKED" SAMPLES

LABORATORY PRECISION: ONE STANDARD DEVIATION VALUES FOR VARIOUS ANALYSES^a

Analysis	Level	One standard deviation for single determination
Gamma Emitters	5 to 100 pCi/liter or kg > 100 pCi/liter or kg	5.0 pCi/liter 5% of known value
Strontium-89 ^b	5 to 50 pCi/liter or kg > 50 pCi/liter or kg	5.0 pCi/liter 10% of known value
Strontium-90 ^b	2 to 30 pCi/liter or kg > 30 pCi/liter or kg	5.0 pCi/liter 10% of known value
Potassium-40	≥ 0.1 g/liter or kg	5% of known value
Gross alpha	≤ 20 pCi/liter > 20 pCi/liter	5.0 pCi/liter 25% of known value
Gross beta	≤ 100 pCi/liter > 100 pCi/liter	5.0 pCi/liter 5% of known value
Tritium	≤ 4,000 pCi/liter	± 1σ = (pCi/liter) = 169.85 x (known) ^{0.0933}
	> 4,000 pCi/liter	10% of known value
Radium-226,-228	≥ 0.1 pCi/liter	15% of known value
Plutonium	≥ 0.1 pCi/liter, gram, or sample	10% of known value
lodine-131,	≤ 55 pCi/liter	6.0 pCi/liter
lodine-129 ^b	> 55 pCi/liter	10% of known value
Uranium-238, Nickel-63 ^b Technetium-99 ^b	≤ 35 pCi/liter > 35 pCi/liter	6.0 pCi/liter 15% of known value
Iron-55⁵	50 to 100 pCi/liter > 100 pCi/liter	10 pCi/liter 10% of known value
Others ^b		20% of known value

* From EPA publication, "Environmental Radioactivity Laboratory Intercomparison Studies Program, Fiscal Year, 1981-1982, EPA-600/4-81-004.

^b Laboratory limit.

. .

			Concent	ration (pCi/L)		
Lab Code	Date	Analysis	Laboratory	ERA	Control	
. <u></u> .			Result ^b	Result ^c	Limits	Acceptance
STW-1051	02/15/05	Sr-89	28.0 ± 1.2	29.4	20.7 - 38.1	Pass
STW-1051	02/15/05	Sr-90	25.1 ± 0.7	24.4	15.7 - 33.1	Pass
STW-1052	02/15/05	Ba-133	52.9 ± 2.8	53.4	44.2 - 62.6	Pass
STW-1052	02/15/05	Co-60	54.4 ± 0.4	56.6	47.9 - 65.3	Pass
STW-1052	02/15/05	Cs-134	67.7 ± 1.8	64.9	56.2 - 73.6	Pass
STW-1052	02/15/05	Cs-137	39.6 ± 1.8	40.2	31.5 - 48.9	Pass
STW-1052	02/15/05	Zn-65	159.7 ± 3.0	161.0	133.0 - 189.0	Pass
STW-1053	02/15/05	Gr. Alpha	55.1 ± 1.8	67.9	38.5 - 97.3	Pass
STW-1053	02/15/05	Gr. Beta	46.8 ± 1.3	51.1	38.5 - 97.3	Pass
STW-1054	02/15/05	Ra-226	13.7 ± 1.5	14.1	10.4 - 17.8	Pass
STW-1054	02/15/05	Ra-228	13.3 ± 0.6	13.7	7.8 - 19.6	Pass
STW-1054	02/15/05	Uranium	5.1 ± 0.2	5.0	0.0 - 10.2	Pass
STW-1055	05/17/05	Sr-89	45.1 ± 4.1	41.3	32.6 - 50.0	Pass
STW-1055	05/17/05	Sr-90	7.5 ± 0.9	5.9	0.0 - 14.6	Pass
STW-1056	05/17/05	Ba-133	87.1 ± 2.0	88.4	73.1 - 104.0	Pass
STW-1056	05/17/05	Co-60	38.4 ± 0.8	37.0	28.3 - 45.7	Pass
STW-1056	05/17/05	Cs-134	75.3 ± 0.7	78.6	69.9 - 87.3	Pass
STW-1056	05/17/05	Cs-137	201.0 ± 8.4	194.0	184.0 - 218.0	Pass
STW-1056	05/17/05	Zn-65	130.0 ± 6.7	118.0	97.6 - 138.0	Pass
STW-1057	05/17/05	Gr. Alpha	42.7 ± 2.9	37.0	21.0 - 53.0	Pass
STW-1057	05/17/05	Gr. Beta	34.0 ± 0.4	34.2	25.5 - 42.9	Pass
STW-1058	05/17/05	I-131	14.7 ± 0.5	15.5	10.3 - 20.7	Pass
STW-1059	05/17/05	Ra-226	6.6 ± 0.1	7.6	5.6 - 9.5	Pass
STW-1059	05/17/05	Ra-228	19.3 ± 0.7	18.9	10.7 - 27.1	Pass
STW-1059	05/17/05	Uranium	9.6 ± 0.1	10.1	4.9 - 15.3	Pass
STW-1060	05/17/05	H-3	24100.0 ± 109.0	24400.0	20200.0 - 28600.0	Pass
STW-1067	08/16/05	Sr-89	29.1 + 3.0	28.0	19.3 - 36.7	Pass
STW-1067	08/16/05	Sr-90	36.0 + 0.6	33.8	25.1 - 42.5	Pass
STW-1068	08/16/05	Ba-133	107.0 + 1.7	106.0	87.7 - 124.0	Pass
STW-1068	08/16/05	Co-60	15.2 + 0.2	13.5	4.8 - 22.2	Pass
STW-1068	08/16/05	Cs-134	89.1 ± 0.3	92.1	83.4 - 101.0	Pass
STW-1068	08/16/05	Cs-137	72.1 ± 1.0	72.7	64.0 - 81.4	Pass
STW-1068	08/16/05	Zn-65	67.4 ± 1.4	65.7	54.3 - 77.1	Pass
STW-1069	08/16/05	Gr. Alpha	44.3 ± 1.5	55.7	31.6 - 79.8	Pass
STW-1069	08/16/05	Gr. Beta	58.4 + 2 1	61.3	44.0 - 78.6	Pass
STW-1070	08/16/05	Ra-226	16.6 ± 1.5	16.6	12.3 - 20.9	Pass
STW-1070	08/16/05	Ra-228	6.2 ± 0.3	6.2	3.5 - 8.9	Pass
STW-1070	08/16/05	Uranium	4.5 ± 0.1	4.5	0.0 - 9.7	Pass

TABLE A-1. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)^a.

	Concentration (pCi/L)									
Lab Code	Date	Analysis	Laboratory	ERA	Control					
			Result ^b	Result	Limits	Acceptance				
ST\M_1072	11/15/05	Sr-80	20 6 ± 0 4	10.0	10.3 - 27.7	Pasa				
STW-1072	11/15/05	Sr-90	20.0 ± 0.4 15.0 ± 0.3	16.0	7.3 - 24.7	Pass				
STW-1073	11/15/05	Ba-133	31.8 ± 1.8	31.2	22.5 - 39.9	Pass				
STW-1073	11/15/05	Co-60	85.0 ± 1.4	84.1	75.4 - 92.8	Pass				
STW-1073	11/15/05	Cs-134	37.2 ± 2.1	33.9	25.2 - 42.6	Pass				
STW-1073	11/15/05	Cs-137	27.8 ± 0.7	28.3	19.6 - 37.0	Pass				
STW-1073	11/15/05	Zn-65	109.0 ± 1.0	105.0	86.8 - 123.0	Pass				
STW-1074 d	11/15/05	Gr. Alpha	41.1 ± 1.2	23.3	13.2 - 33.4	Fail				
STW-1074	11/15/05	Gr. Beta	42.7 ± 0.5	39.1	30.4 - 47.8	Pass				
STW-1075	11/15/05	I-131	20.5 ± 0.6	17.4	12.2 - 22.6	Pass				
STW-1076	11/15/05	Ra-226	7.8 ± 0.6	8.3	6.2 - 10.5	Pass				
STW-1076 *	11/15/05	Ra-228	5.5 ± 0.6	3.5	2.0 - 5.0	Fail				
STW-1076	11/15/05	Uranium	15.5 ± 0.3	16.1	10.9 - 21.3	Pass				
STW-1077	11/15/05	H-3	12500.0 ± 238.0	12200.0	10100.0 - 14300.0	Pass				

TABLE A-1. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)^a.

* Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the crosscheck program for proficiency testing in drinking water conducted by Environmental Resources Associates (ERA).

^b Unless otherwise indicated, the laboratory result is given as the mean ± standard deviation for three determinations.

^c Results are presented as the known values, expected laboratory precision (1 sigma, 1 determination) and control limits as provided by ERA.

^d The original samples were calculated using an Am-241 efficiency. The samples were spiked with Th-232. Samples were recounted and calculated using the Th-232 efficiency. Results of the recount: 27.01 ± 2.35 pCi/L.

^a Decay of short-lived radium daughters contributed to a higher counting rate. Delay of counting for 100 minutes provided better results. The reported result was the average of the first cycle of 100 minutes, the average of the second cycle counts was 4.01 pCi/L

Lab Code	Date		Known	Lab Result	Control	
		Description	Value	± 2 sigma	Limits	Acceptance
Environment	al, Inc.					
2005-1	4/4/2005	30 cm	55.01	64.02 ± 2.86	38.51 - 71.51	Pass
2005-1	4/4/2005	60 cm	13.75	15.43 ± 1.02	9.63 - 17.88	Pass
2005-1	4/4/2005	60 cm	13.75	14.98 ± 0.80	9.63 - 17.88	Pass
2005-1	4/4/2005	90 cm	6.11	6.24 ± 0.16	4.28 - 7.94	Pass
2005-1	4/4/2005	90 cm	6.11	5.45 ± 0.48	4.28 - 7.94	Pass
2005-1	4/4/2005	120 cm	3.44	3.50 ± 0.35	2.41 - 4.47	Pass
2005-1	4/4/2005	120 cm	3.44	3.15 ± 0.18	2.41 - 4.47	Pass
2005-1	4/4/2005	150 cm	2.2	2.31 ± 0.25	1.54 - 2.86	Pass
2005-1	4/4/2005	180 cm	1.53	1.65 ± 0.41	1.07 - 1.99	Pass
Environment	<u>al, Inc.</u>					
2005-2	9/12/2005	30 cm	54.84	59.30 ± 2.66	38.39 - 71.29	Pass
2005-2	9/12/2005	60 cm	13.71	17.55 ± 1.30	9.60 - 17.82	Pass
2005-2	9/12/2005	75 cm	8.77	8.24 ± 0.38	6.14 - 11.40	Pass
2005-2	9/12/2005	90 cm	6.09	5.94 ± 0.49	4.26 - 7.92	Pass
2005-2	9/12/2005	90 cm	6.09	5.93 ± 0.37	4.26 - 7.92	Pass
2005-2	9/12/2005	120 cm	3.43	3.42 ± 0.18	2.40 - 4.46	Pass
2005-2	9/12/2005	150 cm	2.19	1.71 ± 0.14	1.53 - 2.85	Pass
2005-2	9/12/2005	150 cm	2.19	1.87 ± 0.27	1.53 - 2.85	Pass
2005-2	9/12/2005	180 cm	1.52	1.58 ± 0.99	1.06 - 1.98	Pass

TABLE A-2. Crosscheck program results; Thermoluminescent Dosimetry, (TLD, CaSO4: Dy Cards).

TABLE A-3. In-House "Spike" Samples

		Concentration (pCi/L) ^a							
Lab Code ^b	Date	Analysis	Laboratory results 2s, n=1 ^c	Known Activity	Control Limits ^d	Acceptance			
W-11105	1/11/2005	Gr Alpha	24.05 + 1.01	20.08	10.04 - 30.12	0.955			
W-11105	1/11/2005	Gr. Beta	24.00 ± 1.01	20.00 65.70	55 70 - 75 70	Pass			
SPW-764	2/18/2005	H-3	77505 00 + 764 00	80543.00	64434 40 - 96651 60	Pass			
SPAP-766	2/18/2005	Gr Beta	416 08 + 5 52	463.00	370 40 - 509 30	Pass			
STW-2887	2/28/2005	Tc-99	32.01 + 1.23	32 98	20 98 - 44 98	Pass			
W-30105	3/1/2005	Gr Ainha	25 22 + 0.45	20.08	10.04 - 30.12	Pass			
W-30105	3/1/2005	Gr. Beta	62 27 + 0.48	65 73	55 73 - 75 73	Pass			
11-30103	0/112000		02.2) 10.40	00.75	00010 - 70010	1 233			
SPW-1836	4/15/2005	I-131	109.79 ± 0.94	106.30	85.04 - 127.56	Pass			
SPW-1836	4/15/2005	l-131(G)	110.25 ± 9.68	106.30	95.67 - 116.93	Pass			
SPMI-1838	4/15/2005	Cs-134	25.94 ± 1.28	26.60	16.60 - 36.60	Pass			
SPMI-1838	4/15/2005	Cs-137	59.31 ± 3.66	60,90	50.90 - 70.90	Pass			
SPMI-1838	4/15/2005	1-131	97.71 ± 0.81	106.30	85.04 - 127.56	Pass			
SPMI-1838	4/15/2005	I-131(G)	109.45 ± 3.06	106.30	95.67 - 116.93	Pass			
SPMI-1838	4/15/2005	Sr-89	104.44 ± 2.89	108.20	86.56 - 129.84	Pass			
SPMI-1838	4/15/2005	Sr-90	8.97 ± 0.79	7.53	0.00 - 17.53	Pass			
SPVE-1932	4/18/2005	l-131(G)	1.00 ± 0.04	0.73	0.44 - 1.02	Pass			
SPCH-1935	4/18/2005	I-131	382.40 ± 14.95	328.64	262.91 - 394.37	Pass			
SPAP-1966	4/18/2005	Cs-134	52.10 ± 7.27	53.35	43.35 - 63.35	Pass			
SPAP-1966	4/18/2005	Cs-134	57.28 ± 13.47	53.35	43.35 - 63.35	Pass			
SPAP-1966	4/18/2005	Cs-137	124.68 ± 18.41	121.77	109.59 - 133.95	Pass			
SPAP-1968	4/18/2005	Cs-134	52.10 ± 7.27	53.35	43.35 - 63.35	Pass			
SPAP-1968	4/18/2005	Cs-137	116.79 ± 14.00	121.77	109.59 - 133.95	Pass			
SPW-2098	4/26/2005	Fe-55	2565.20 ± 63.66	3017.60	2414.08 - 3621.12	Pass			
SPW-2922	5/31/2005	Cs-134	27.01 ± 1.09	25.54	15.54 - 35.54	Pass			
SPW-2922	5/31/2005	Cs-134	65.38 ± 2.92	60.71	50.71 - 70.71	Pass			
SPW-2922	5/31/2005	Sr-89	107.90 ± 3.60	113.90	91.12 - 136.68	Pass			
SPW-2922	5/31/2005	Sr-90	11.11 ± 1.13	6.90	0.00 - 16.90	Pass			
SPAP-2892	6/1/2005	Gr, Beta	420.32 ± 5.55	448.00	358.40 - 492.80	Pass			
SPW-2895	6/1/2005	H-3	75271.00 ± 724.00	78676.00	62940.80 - 94411.20	Pass			
w-6010 5	6/1/2005	Gr. Aipha	23.69 ± 0.52	20.08	10.04 - 30.12	Pass			
w-60105	6/1/2005	Gr. Beta	60.08 ± 0.57	65.73	55.73 - 75.73	Pass			
SPF-3089	6/7/2005	Cs-134	1.08 ± 0.05	1.02	0.61 - 1.43	Pass			
SPF-3089	6/7/2005	Cs-137	2.54 ± 0.10	2.43	1.46 - 3.40	Pass			
SPW-	7/1/2005	NI-63	20.57 ± 1.10	16.75	10.05 - 23.45	Pass			
SPW-47731	8/24/2005	C-14	2112.30 ± 9.13	2370.80	1422.48 - 3319.12	Pass			
SPW-47732	8/24/2005	C-14	2294.10 ± 10.37	2370.80	1422.48 - 3319.12	Pass			
SPW-4775	8/24/2005	Fe-55	2633.50 ± 62.40	2777.50	2222.00 - 3333.00	Pass			
SPMI-4834	8/30/2005	Cs-134	49.27 ± 4.68	47.02	37.02 - 57.02	Pass			
SPMI-4834	8/30/2005	Cs-137	58.17 ± 8.18	60.37	50.37 - 70.37	Pass			
SPMI-4834	8/30/2005	Sr-89	66.39 ± 3.13	65.90	52.72 - 79.08	Pass			
SPMI-4834	8/30/2005	Sr-90	11.15 ± 1.13	9.60	0.00 - 19.60	Pass			

TABLE A-3. In-House "Spike" Samples

		Concentration (pCi/L)								
Lab Code	Date	Analysis	Laboratory results 2s, n=1 ^b	Known Activity	Control Limits ^c	Acceptance				
SPW-4836	8/30/2005	Cs-134	47.35 + 5.19	47.02	37.02 - 57.02	Pass				
SPW-4836	8/30/2005	Cs-137	62.91 ± 9.08	60.37	50.37 - 70.37	Pass				
SPW-4836	8/30/2005	Sr-89	11.04 ± 0.98	9.60	0.00 - 19.60	Pass				
SPW-4836	8/30/2005	Sr-90	65.89 ± 2.79	65.90	52.72 - 79.08	Pass				
SPW-5014	8/30/2005	H-3	77518.20 ± 753.80	77602.52	62082.02 - 93123.02	Pass				
W-90705	9/7/2005	Gr. Alpha	24.61 ± 0.48	20.08	10.04 - 30.12	Pass				
W-90705	9/7/2005	Gr. Beta	58.35 ± 0.49	65.73	55.73 - 75.73	Pass				
SPW-5237	9/22/2005	C-14	2387.40 ± 11.00	2370.80	1422.48 - 3319.12	Pass				
SPW-5508	9/26/2005	Ni-63	20.64 ± 1.23	16.70	10.02 - 23.38	Pass				
SPW-6019	10/24/2005	Tc-99	547.99 ± 6.69	539.22	377.45 - 700.99	Pass				
SPF-6293	11/4/2005	Cs-134	941.30 ± 44.10	886.00	797.40 - 974.60	Pass				
SPF-6293	11/4/2005	Cs-137	2570.40 ± 105.30	2400.00	2160.00 - 2640.00	Pass				
SPAP-6309	11/7/2005	Cs-134	41.24 ± 1.91	44.03	34.03 - 54.03	Pass				
SPAP-6309	11/7/2005	Cs-137	114.03 ± 5.01	120.24	108.22 - 132.26	Pass				
SPAP-6311	11/7/2005	Gr. Beta	1.58 ± 0.02	1.42	1.14 - 11.42	Pass				
SPW-6451	11/10/2005	H-3	77126.00 ± 747.00	76749.00	61399.20 - 92098.80	Pass				
W-120105	12/1/2005	Gr. Alpha	25.16 ± 0.45	20.08	10.04 - 30.12	Pass				
W-120105	12/1/2005	Gr. Beta	74.58 ± 0.81	65.73	55.73 - 75.73	Pass				
SPW-7440	12/30/2005	Cs-134	42.67 ± 4.22	42.03	32.03 - 52.03	Pass				
SPW-7440	12/30/2005	Cs-137	61.19 ± 7.20	59.91	49.91 - 69.91	Pass				
SPMI-7442	12/31/2005	Cs-134	40.41 ± 5.66	42.03	32.03 - 52.03	Pass				
SPMI-7442	12/31/2005	Cs-137	60.05 ± 7.80	59.91	49.91 - 69.91	Pass				

* Liquid sample results are reported in pCl/Liter, air filters(pCl/filter), charcoal (pCl/m³), and solid samples (pCi/g).

^b Laboratory codes as follows: W (water), MI (milk), AP (air filter), SO (soil), VE (vegetation), CH (charcoal canister), F (fish).

^cResults are based on single determinations.

^d Control limits are based on Attachment A, Page A2 of this report.

NOTE: For fish, Jello is used for the Spike matrix. For Vegetation, cabbage is used for the Spike matrix.

					Concentration (pCi/	L) ^a
Lab Code	Sample	Date	Analysis	Laborato	ry results (4.66σ)	Acceptance
<u> </u>	Туре			LLD	Activity ^b	Criteria (4.66 σ)
14/ 11/05	water	4/44/2005	Cr. Alaba	0.055	0.00 + 0.029	
W-11105	water	1/11/2005	Gr. Alpha	0.055	0.00 ± 0.038	1
VV-11105	water	1/11/2005	Gr. Beta	0.15	-0.016 ± 0.10	3.2
SPW-/65	water	2/18/2005	H-3	165.8	7.4 ± 82.5	200
SPAP-766		2/18/2005	Gr. Beta	0.72	0.29 ± 0.48	3.2
S1W-2888	water	2/28/2005	Tc-99	1.32	0.45 ± 0.81	10
W-30105	water	3/1/2005	Gr. Alpha	0.067	-0.007 ± 0.043	1
W-30105	water	3/1/2005	Gr. Beta	0.18	-0.04 ± 0.11	3.2
SPW-1837	water	4/15/2005	Cs-134	4.66		10
SPW-1837	water	4/15/2005	Cs-137	5.38		10
SPW-1837	water	4/15/2005	I-131	0.30	-0.13 ± 0.16	0.5
SPW-1837	water	4/15/2005	l-131(G)	6.56		20
SPMI-1839	Milk	4/15/2005	i-131	0.26	-0.083 ± 0.14	0.5
SPMI-1839	Milk	4/15/2005	Sr-89	0.54	-0.069 ± 0.56	5
SPMI-1839	Milk	4/15/2005	Sr-90	0.53	0.88 ± 0.34	1
SPCH-1934	Charcoal	4/18/2005	I-131(G)	2.34		9.6
SPW-2097	water	4/26/2005	Fe-55	859.0	96.1 ± 528.4	1000
SPW-2923	water	5/31/2005	Cs-134	3.29		10
SPW-2923	water	5/31/2005	Cs-137	3.87		10
SPW-2896	water	6/1/2005	H-3	138.30	48.1 ± 85.9	200
w-60105	water	6/1/2005	Gr. Alpha	0.061	0.002 ± 0.043	1
w-60105	water	6/1/2005	Gr. Beta	0.16	0.056 ± 0.11	3.2
SPF-3090	Fish	6/7/2005	Cs-134	15.69		100
SPF-3090	Fish	6/7/2005	Cs-137	11.71		100
SPW-	water	7/1/2005	NI-63	1.60	0.79 ± 0.99	20
SPW_4774	water	8/24/2005	G-14	12.18	2.84 ± 6.45	200
SPW-4776	water	8/24/2005	Fe-55	833	275 ± 525	1000
SPMI-4835	Milk	8/30/2005	Co-60	4.42		10
SPMI-4835	Milk	8/30/2005	Cs-134	4.18		10
SPMI-4835	Milk	8/30/2005	Cs-137	6.25		10
SPMI-4835	Milk	8/30/2005	I-131(G)	5.37		20
SPMI-4835	Milk	8/30/2005	Sr-89	0.66	-0.23 ± 0.65	5
SPMI-4835 ^d	Milk	8/30/2005	Sr-90	0.66	1.02 ± 0.41	1
SPW-4837	water	8/30/2005	Co-60	2.48		10
SD\A/_4837	water	8/30/2005	Ce-134	3.85		10
SD\// 4837	water	8/30/2005	Cs-137	3.00		10
SDW/_4927	water	8/30/2005	Sr.89	0.00 0 63	0.25 + 0.53	
SPW_4837	water	8/30/2005	Sr-90	0.00	-0.035 + 0.29	- 1
SPW_5015	water	8/30/2005	H-3	142 R	168 + 93	200
SPW-5238	water	9/22/2005	C-14	17.10	3.02 ± 9.04	200
U1 11-0200	THE O	VI	₩ (T			

TABLE A-4. in-House "Blank" Samples

					Concentration (pCi	/L) ^e
Lab Code	Sample	Date	Analysis	Laborato	ry results (4.66σ)	Acceptance
. <u></u>	Туре			LLD	Activity ^b	Criteria (4.66 σ)
·						
W-90705	water	9/7/2005	Gr. Alpha	0.056	0.034 ± 0.04	1
W-90705	water	9/7/2005	Gr. Beta	0.16	0.082 ± 0.11	3.2
SPW-5238	water	9/22/2005	C-14	17.10	3.02 ± 9.04	200
SPW-5509	water	9/26/2005	Ni-63	1.25	1.23 ± 0.79	20
SPW-6020	water	10/24/2005	Tc-99	4.81	-1.75 ± 2.90	10
SPF-6294	Fish	11/4/2005	Cs-134	18.60		100
SPF-6294	Fish	11/4/2005	Cs-137	12.99		100
SPAP-6310	Air Filter	11/7/2005	Cs-134	3.23		100
SPAP-6310	Air Filter	11/7/2005	Cs-137	3.86		100
SPAP-6312	Air Filter	11/7/2005	Gr. Beta	1.22	-0.64 ± 0.64	3.2
W-120105	water	12/1/2005	Gr. Alpha	0.05	0.033 ± 0.04	1
W-120105	water	12/1/2005	Gr. Beta	0.15	-0.043 ± 0.11	3.2
SPMI-7419	Milk	12/22/2005	Co-60	7.24		10
SPMI-7419	Milk	12/22/2005	Cs-137	5.61		10
SPMI-7419	Milk	12/22/2005	I-131(G)	10.96		20
SPW-7421	water	12/22/2005	Co-60	2.43		10
SPW-7421	water	12/22/2005	Cs-137	3.12		10
SPW-7441	water	12/30/2005	Cs-134	4.25		10
SPW-7441	water	12/30/2005	Cs-137	1.63		10
SPMI-7443	Milk	12/30/2005	Cs-134	4.74		10
SPMI-7443	Milk	12/30/2005	Cs-137	8.53		10

TABLE A-4. In-House "Blank" Samples

* Liquid sample results are reported in pCi/Liter, air filters(pCl/filter), charcoal (pCi/charcoal canister), and solid samples (pCi/g).

^b Activity reported is a net activity result. For gamma spectroscopic analysis, activity detected below the LLD value is not reported ^c I-131(G); iodine-131 as analyzed by gamma spectroscopy.

^d Low levels of Sr-90 are still detected in the environment. A concentration of (1-5 pCi/L) in milk is not unusual.

$\begin{tabular}{ c c c c c c c c c c c c c c c c c c c$
Lab CodeDateAnalysisFirst ResultSecond ResultResultAcceptanceSW-62, 63 $1/3/2005$ Gr. Beta 3.01 ± 0.57 2.39 ± 0.58 2.70 ± 0.41 PassSW-62, 63 $1/3/2005$ K-40 2.00 ± 0.20 2.10 ± 0.20 2.05 ± 0.14 PassCF-95, 96 $1/3/2005$ Gr. Beta 6.26 ± 0.23 6.28 ± 0.23 6.27 ± 0.16 PassCF-95, 96 $1/3/2005$ K-40 5.68 ± 0.59 5.37 ± 0.48 5.53 ± 0.38 PassAP-791, 792 $1/14/2005$ Be-7 0.057 ± 0.017 0.07 ± 0.04 0.06 ± 0.02 PassSW-383, 354 $1/19/2005$ Gr. Beta 8.37 ± 1.21 10.28 ± 1.34 9.32 ± 0.90 PassSO-383, 384 $1/19/2005$ Gr. Beta 2.45 ± 0.54 2.20 ± 0.54 2.33 ± 0.38 PassLW-431, 432 $1/27/2005$ Gr. Beta 2.45 ± 0.54 2.20 ± 0.54 2.33 ± 0.38 PassMI-486, 487 $2/1/2005$ K-401319.40 \pm 163.601177.20 \pm 179.701248.30 \pm 121.51PassSW-511, 512 $2/1/2005$ H-3489663 \pm 1918491225 \pm 1915490444 \pm 1355PassDW-538, 539 $2/3/2005$ Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.61 PassSW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSW-925, 926 $2/25/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ </th
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$
CF-95, 961/3/2005Gr. Beta 6.26 ± 0.23 6.28 ± 0.23 6.27 ± 0.16 PassCF-95, 961/3/2005K-40 5.68 ± 0.59 5.37 ± 0.48 5.53 ± 0.38 PassAP-791, 7921/14/2005Be-7 0.057 ± 0.017 0.07 ± 0.04 0.06 ± 0.02 PassWW-353, 3541/19/2005Gr. Beta 8.37 ± 1.21 10.28 ± 1.34 9.32 ± 0.90 PassSO-383, 3841/19/2005H-3 453.50 ± 107.20 417.90 ± 106.00 435.70 ± 75.38 PassLW-431, 4321/27/2005Gr. Beta 2.45 ± 0.54 2.20 ± 0.54 2.33 ± 0.38 PassMI-486, 4872/1/2005K-401319.40 \pm 163.601177.20 \pm 179.701248.30 \pm 121.51PassSW-511, 5122/1/2005I-131 0.37 ± 0.22 0.44 ± 0.23 0.40 ± 0.16 PassDW-538, 5392/3/2005Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassDW-50134, 52/11/2005Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSW-925, 9262/25/2005Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 9513/1/2005Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 9513/1/2005Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-950, 9513/1/2005Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 9513/1/2005
CF-95, 961/3/2005K-40 5.68 ± 0.59 5.37 ± 0.48 5.53 ± 0.38 PassAP-791, 7921/14/2005Be-7 0.057 ± 0.017 0.07 ± 0.04 0.06 ± 0.02 PassWW-353, 3541/19/2005Gr. Beta 8.37 ± 1.21 10.28 ± 1.34 9.32 ± 0.90 PassSO-383, 3841/19/2005H-3 453.50 ± 107.20 417.90 ± 106.00 435.70 ± 75.38 PassLW-431, 4321/27/2005Gr. Beta 2.45 ± 0.54 2.20 ± 0.54 2.33 ± 0.38 PassMI-486, 4872/1/2005K-401319.40 \pm 163.601177.20 \pm 179.701248.30 \pm 121.51PassSW-511, 5122/1/2005I-131 0.37 ± 0.22 0.44 ± 0.23 0.40 ± 0.16 PassTD-628, 6292/1/2005H-3489663 \pm 1918491225 \pm 1915490444 \pm 1355PassDW-538, 5392/3/2005Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassDW-50134, 52/11/2005Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSW-93, 8942/22/2005Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 9513/1/2005Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 9513/1/2005Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-950, 9513/1/2005Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-950, 9513/1/2005 <td< td=""></td<>
AP-791, 792 $1/14/2005$ Be-7 0.057 ± 0.017 0.07 ± 0.04 0.06 ± 0.02 PassWW-353, 354 $1/19/2005$ Gr. Beta 8.37 ± 1.21 10.28 ± 1.34 9.32 ± 0.90 PassSO-383, 384 $1/19/2005$ H-3 453.50 ± 107.20 417.90 ± 106.00 435.70 ± 75.38 PassLW-431, 432 $1/27/2005$ Gr. Beta 2.45 ± 0.54 2.20 ± 0.54 2.33 ± 0.38 PassMI-486, 487 $2/1/2005$ K-40 1319.40 ± 163.60 1177.20 ± 179.70 1248.30 ± 121.51 PassSW-511, 512 $2/1/2005$ I-131 0.37 ± 0.22 0.44 ± 0.23 0.40 ± 0.16 PassDW-528, 629 $2/1/2005$ H-3 489663 ± 1918 491225 ± 1915 490444 ± 1355 PassDW-538, 539 $2/3/2005$ Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassDW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSW-925, 926 $2/22/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 951 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 951 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 Pass
WW-353, 3541/19/2005Gr. Beta 8.37 ± 1.21 10.28 ± 1.34 9.32 ± 0.90 PassSO-383, 3841/19/2005H-3453.50 ± 107.20 417.90 ± 106.00 435.70 ± 75.38 PassLW-431, 4321/27/2005Gr. Beta 2.45 ± 0.54 2.20 ± 0.54 2.33 ± 0.38 PassMI-486, 4872/1/2005K-401319.40 ± 163.60 1177.20 ± 179.70 1248.30 ± 121.51 PassSW-511, 5122/1/2005I-131 0.37 ± 0.22 0.44 ± 0.23 0.40 ± 0.16 PassTD-628, 6292/1/2005H-3489663 ± 1918 491225 ± 1915 490444 ± 1355 PassDW-538, 5392/3/2005Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassDW-50134, 52/11/2005Gr. Beta18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSW-925, 9262/25/2005Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 9513/1/2005Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 9513/1/2005Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-973, 9743/1/2005Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 Pass
SO-383, 384 $1/19/2005$ H-3 453.50 ± 107.20 417.90 ± 106.00 435.70 ± 75.38 PassLW-431, 432 $1/27/2005$ Gr. Beta 2.45 ± 0.54 2.20 ± 0.54 2.33 ± 0.38 PassMI-486, 487 $2/1/2005$ K-40 1319.40 ± 163.60 1177.20 ± 179.70 1248.30 ± 121.51 PassSW-511, 512 $2/1/2005$ I-131 0.37 ± 0.22 0.44 ± 0.23 0.40 ± 0.16 PassTD-628, 629 $2/1/2005$ H-3 489663 ± 1918 491225 ± 1915 490444 ± 1355 PassDW-538, 539 $2/3/2005$ Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassDW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSWU-893, 894 $2/22/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 951 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-973, 974 $3/4/2005$ I.121 1.08 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 Pass
LW-431, 432 $1/27/2005$ Gr. Beta 2.45 ± 0.54 2.20 ± 0.54 2.33 ± 0.38 PassMI-486, 487 $2/1/2005$ K-40 1319.40 ± 163.60 1177.20 ± 179.70 1248.30 ± 121.51 PassSW-511, 512 $2/1/2005$ I-131 0.37 ± 0.22 0.44 ± 0.23 0.40 ± 0.16 PassTD-628, 629 $2/1/2005$ H-3 489663 ± 1918 491225 ± 1915 490444 ± 1355 PassDW-538, 539 $2/3/2005$ Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassDW-564, 565 $2/8/2005$ K-40 1316.20 ± 171.10 1292.60 ± 154.40 1304.40 ± 115.23 PassDW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSWU-893, 894 $2/22/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 951 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-973, 974 $3/1/2005$ I.121 1.09 ± 0.40 2.22 ± 0.44 2.18 ± 0.30 Pass
MI-486, 487 $2/1/2005$ K-40 1319.40 ± 163.60 1177.20 ± 179.70 1248.30 ± 121.51 PassSW-511, 512 $2/1/2005$ I-131 0.37 ± 0.22 0.44 ± 0.23 0.40 ± 0.16 PassTD-628, 629 $2/1/2005$ H-3 489663 ± 1918 491225 ± 1915 490444 ± 1355 PassDW-538, 539 $2/3/2005$ Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassMI-564, 565 $2/8/2005$ K-40 1316.20 ± 171.10 1292.60 ± 154.40 1304.40 ± 115.23 PassDW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSWU-893, 894 $2/22/2005$ Gr. Beta 4.00 ± 0.96 4.20 ± 0.72 4.10 ± 0.60 PassSW-925, 926 $2/25/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-973, 974 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 Pass
SW-511, 512 $2/1/2005$ I-131 0.37 ± 0.22 0.44 ± 0.23 0.40 ± 0.16 PassTD-628, 629 $2/1/2005$ H-3 489663 ± 1918 491225 ± 1915 490444 ± 1355 PassDW-538, 539 $2/3/2005$ Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassMI-564, 565 $2/8/2005$ K-40 1316.20 ± 171.10 1292.60 ± 154.40 1304.40 ± 115.23 PassDW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSWU-893, 894 $2/22/2005$ Gr. Beta 4.00 ± 0.96 4.20 ± 0.72 4.10 ± 0.60 PassSW-925, 926 $2/25/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-973, 974 $3/1/2005$ I.121 1.09 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 Pass
TD-628, 629 $2/1/2005$ H-3 489663 ± 1918 491225 ± 1915 490444 ± 1355 PassDW-538, 539 $2/3/2005$ Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassMI-564, 565 $2/8/2005$ K-40 1316.20 ± 171.10 1292.60 ± 154.40 1304.40 ± 115.23 PassDW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSWU-893, 894 $2/22/2005$ Gr. Beta 4.00 ± 0.96 4.20 ± 0.72 4.10 ± 0.60 PassSW-925, 926 $2/25/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 951 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-973, 974 $3/1/2005$ I 121 1.09 ± 0.10 0.92 ± 0.18 1.00 ± 0.13 Pass
DW-538, 539 $2/3/2005$ Gr. Beta 3.93 ± 1.18 3.62 ± 1.10 3.78 ± 0.81 PassMI-564, 565 $2/8/2005$ K-40 1316.20 ± 171.10 1292.60 ± 154.40 1304.40 ± 115.23 PassDW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSWU-893, 894 $2/22/2005$ Gr. Beta 4.00 ± 0.96 4.20 ± 0.72 4.10 ± 0.60 PassSW-925, 926 $2/25/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 951 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-973, 974 $3/1/2005$ I.121 1.09 ± 0.10 0.92 ± 0.18 1.00 ± 0.13 Pass
MI-564, 565 $2/8/2005$ K-40 1316.20 ± 171.10 1292.60 ± 154.40 1304.40 ± 115.23 PassDW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSWU-893, 894 $2/22/2005$ Gr. Beta 4.00 ± 0.96 4.20 ± 0.72 4.10 ± 0.60 PassSW-925, 926 $2/25/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 951 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-973, 974 $3/1/2005$ 1.121 1.08 ± 0.40 0.92 ± 0.18 1.00 ± 0.13 Pass
DW-50134, 5 $2/11/2005$ Gr. Beta 18.41 ± 0.98 16.76 ± 0.98 17.59 ± 0.69 PassSWU-893, 894 $2/22/2005$ Gr. Beta 4.00 ± 0.96 4.20 ± 0.72 4.10 ± 0.60 PassSW-925, 926 $2/25/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 951 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-973, 974 $3/1/2005$ 1.131 1.08 ± 0.40 0.92 ± 0.18 1.00 ± 0.13 Pass
SWU-893, 894 $2/22/2005$ Gr. Beta 4.00 ± 0.96 4.20 ± 0.72 4.10 ± 0.60 PassSW-925, 926 $2/25/2005$ Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 PassSW-950, 951 $3/1/2005$ Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 PassSW-950, 951 $3/1/2005$ Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 PassSW-973, 974 $3/1/2005$ 1.131 1.08 ± 0.40 0.02 ± 0.18 1.00 ± 0.13 Pass
SW-925, 926 2/25/2005 Gr. Beta 5.97 ± 1.51 6.14 ± 1.55 6.06 ± 1.08 Pass SW-950, 951 3/1/2005 Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 Pass SW-950, 951 3/1/2005 Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 Pass SW-973, 974 3/1/2005 1.131 1.08 ± 0.10 0.92 ± 0.18 1.00 ± 0.13 Pass
SW-950, 951 3/1/2005 Gr. Beta 0.92 ± 0.27 1.21 ± 0.27 1.07 ± 0.19 Pass SW-950, 951 3/1/2005 Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 Pass SW-973, 974 3/1/2005 1.131 1.08 ± 0.40 0.02 ± 0.18 1.00 ± 0.13 Pass
SW-950, 951 3/1/2005 Gr. Beta 2.06 ± 0.40 2.29 ± 0.44 2.18 ± 0.30 Pass SW-973, 974 3/1/2005 1.131 1.09 ± 0.40 0.02 ± 0.48 1.00 ± 0.13 Pass
$S_{1}=0.02 \pm 0.02 \pm 0$
DW-50248, 9 3/16/2005 Gr. Alpha 5.27 ± 1.06 4.17 ± 0.90 4.72 ± 0.70 Pass
DW-1264, 1265 3/19/2005 1-131 0.54 ± 0.21 0.73 ± 0.20 0.63 ± 0.15 Pass
AP-1955, 1956 3/28/2005 Be-7 0.071 ± 0.009 0.071 ± 0.009 0.071 ± 0.006 Pass
AP-1890, 1891 3/29/2005 Be-7 0.060 ± 0.013 0.069 ± 0.013 0.065 ± 0.009 Pass
AP-2025, 2026 3/29/2005 Be-7 0.063 ± 0.012 0.071 ± 0.011 0.067 ± 0.008 Pass
MI-1346, 1347 3/30/2005 K-40 1252.80 ± 120.50 1334.10 ± 106.60 1293.45 ± 80.44 Pass
AP-2048, 2049 3/30/2005 Be-7 0.075 ± 0.018 0.071 ± 0.015 0.073 ± 0.012 Pass
AP-2081, 2082 3/30/2005 Be-7 0.073 ± 0.016 0.061 ± 0.018 0.067 ± 0.012 Pass
SWU-1521, 1522 3/31/2005 Gr. Beta 2.83 ± 1.16 3.46 ± 1.23 3.14 ± 0.85 Pass
WW-1738, 1739 4/5/2005 Gr. Beta 11.44 ± 1.17 11.14 ± 1.62 11.29 ± 1.00 Pass
SW-1857, 1858 4/13/2005 Gr. Beta 7.04 ± 1.71 9.96 ± 1.65 8.50 ± 1.19 Pass
LW-1911, 1912 4/14/2005 Gr. Beta 2.50 ± 0.63 3.23 ± 0.67 2.86 ± 0.46 Pass
F-1976, 1977 4/18/2005 K-40 3.09 ± 0.60 3.33 ± 0.40 3.21 ± 0.36 Pass
MI-2111, 2112 4/26/2005 K-40 1291.50 ± 177.90 1323.70 ± 108.80 1307.60 ± 104.27 Pass
SWU-2158, 2159 4/26/2005 Gr. Beta 3.69 ± 0.74 3.54 ± 0.66 3.62 ± 0.50 Pass
DW-2349, 2350 4/29/2005 I-131 0.58 ± 0.27 0.49 ± 0.27 0.53 ± 0.19 Pass
SO-2305, 2306 5/2/2005 Cs-137 0.11 ± 0.05 0.11 ± 0.04 0.11 ± 0.03 Pass
SO-2305, 2306 5/2/2005 Gr. Alpha 7.55 ± 2.88 12.41 ± 3.38 9.98 ± 2.22 Pass
SO-2305, 2306 5/2/2005 Gr. Beta 28,74 ± 2.57 28.17 ± 2.52 28.46 ± 1.80 Pass
SO-2305, 2306 5/2/2005 K-40 21.51 ± 1.22 21.42 ± 1.24 21.47 ± 0.87 Pass
SO-2305, 2306 5/2/2005 Sr-90 32.90 ± 9.90 29.60 ± 13.90 31.25 ± 8.53 Pass
MI-2260, 2261 5/3/2005 K-40 1028.10 ± 99.36 1206.70 ± 118.50 1117.40 ± 77.32 Pass
F-2630, 2631 5/5/2005 K-40 3.08 ± 0.46 3.04 ± 0.51 3.06 ± 0.34 Pass
VE-2502, 2503 5/10/2005 Gr. Alpha 0.06 ± 0.03 0.07 ± 0.04 0.07 ± 0.03 Pass

. -

				Concentration (pCi/L)*	· · · · · · · · · · · · · · · · · · ·	· <u> </u>
					Averaged	
Lab Code	Date	Analysis	First Result	Second Result	Result	Acceptance
VE 0500 0500	F#0000F	0- D ·	0.04 . 0.40			
VE-2002, 2003	5/10/2005	Gr. Beta	3.81 ± 0.10	3.86 ± 0.10	3.83 ± 0.07	Pass
VE-2002, 2000	5/10/2005	R-40 R- 7	3.79 ± 0.40	4.30 ± 0.59	4.04 ± 0.36	Pass
G-2040, 2047	5/11/2005	D0-7	0.81 ± 0.39	1.20 ± 0.38	1.03 ± 0.27	Pass
G-2040, 2047 SS-2787 2788	5/18/2005	Cr-127	9.43 ± 1.00	7.90 ± 0.05	0.70 ± 0.00	Pass
SS-2787 2788	5/18/2005	K 40	0.13 ± 0.04	0.14 ± 0.00	0.13 ± 0.03	Pass
SO-3056 3057	5/19/2005	Cs-137	0.18 + 0.04	13.33 ± 0.03	12.00 ± 0.00	Pass
SO-3056 3057 b	5/19/2005	K-40	20.06 ± 1.10	21.73 ± 0.36	20.90 ± 0.58	Fa35 Fail
SS-3175_3176	5/23/2005	K-40	606 + 0 AA	5.96 + 0.61	6.01 ± 0.38	Daes
SO-2865 2866	5/25/2005	Cs-137	0.00 ± 0.44	0.18 + 0.03	0.18 ± 0.02	Pass
SO-2865, 2866	5/25/2005	Gr. Beta	32.95 + 2.48	33.88 + 2.36	33.41 + 1.71	Pass
SO-2865, 2866	5/25/2005	K-40	21.93 ± 0.97	22.32 ± 0.98	22.13 ± 0.69	Pass
DW-2935, 2936	5/27/2005	I-131	0.51 ± 0.34	0.56 ± 0.30	0.53 ± 0.23	Pass
SWU-3103, 3104	6/1/2005	Gr. Beta	3.29 ± 0.49	3.75 ± 0.66	3.52 ± 0.41	Pass
G-2958, 2959	6/1/2005	Be-7	1.06 ± 0.40	1.21 ± 0.28	1.14 ± 0.24	Pass
G-2958, 2959 ^b	6/1/2005	Gr. Beta	8.06 ± 0.07	7.79 ± 0.07	7.93 ± 0.05	Fail
G-2958, 2959	6/1/2005	K-40	5.93 ± 0.73	6.05 ± 0.28	5.99 ± 0.39	Pass
BS-4089, 4090	6/3/2005	Co-60	0.11 ± 0.02	0.10 ± 0.02	0.11 ± 0.02	Pass
BS-4089, 4090	6/3/2005	Cs-137	0.60 ± 0.05	0.62 ± 0.05	0.61 ± 0.04	Pass
DW-50527, 8	6/8/2005	Gr. Alpha	11.58 ± 1.31	13.52 ± 1.43	12.55 ± 0.97	Pass
VE-3278, 3279	6/13/2005	K-40	6.34 ± 0.59	7.29 ± 0.68	6.81 ± 0.45	Pass
MI-3299, 3300	6/15/2005	K-40	1215.40 ± 110.20	1250.70 ± 106.70	1233.05 ± 76.70	Pass
BS-3348, 3349	6/17/2005	Co-60	0.20 ± 0.04	0.22 ± 0.04	0.21 ± 0.03	Pass
BS-3348, 3349	6/17/2005	Cs-137	2.59 ± 0.10	2.51 ± 0.07	2.55 ± 0.06	Pass
BS-3348, 3349	6/17/2005	K-40	11.57 ± 0.81	11.82 ± 0.76	11.69 ± 0.56	Pass
DW-3486, 3487	6/28/2005	Gr. Beta	0.97 ± 0.54	1.67 ± 0.58	1.32 ± 0.40	Pass
SWT-3631, 3632	6/28/2005	Gr. Beta	2.12 ± 0.53	1.62 ± 0.56	1.87 ± 0.39	Pass
W-3507, 3508	6/29/2005	H-3	38717 ± 382	38017 ± 535	38367 ± 329	Pass
VE-3555, 3556	6/29/2005	Gr. Beta	7.53 ± 0.18	7.56 ± 0.18	7.55 ± 0.13	Pass
VE-3555, 3556	6/29/2005	K-40	5.70 ± 0.52	5.64 ± 0.53	5.67 ± 0.37	Pass
AP-3781, 3782	6/29/2005	Be-7	0.09 ± 0.02	0.08 ± 0.02	0.09 ± 0.01	Pass
LW-3610, 3611	6/30/2005	Gr. Beta	1.37 ± 0.35	1.40 ± 0.30	1.39 ± 0.23	Pass
SW-3760, 3761	6/30/2005	Gr. Beta	9.70 ± 1.03	9.77 ± 1.61	9.73 ± 1.15	F 855
E-3654, 3655	7/5/2005	Gr. Beta	1.76 ± 0.07	1.69 ± 0.07	1.72 ± 0.05	Pass
E-3654, 3655	7/5/2005	K-40	1.49 ± 0.25	1.05 ± 0.21	1.27 ± 0.16	Pass
MI-3676, 3677	7/5/2005	K-40	1383.90 ± 116.20	1428.20 ± 125.40	1406.05 ± 85.48	Pass
DW-3739, 3740	7/5/2005	I-131	1.93 ± 0.24	2.18 ± 0.23	2.05 ± 0.17	Pass
W-3808, 3809	7/6/2005	H-3	4189.61 ± 196.68	4438.33 ± 201.39	4313.97 ± 140.75	Pass
DW-3938, 3939	7/8/2005	I-131	1.11 ± 0.30	1.26 ± 0.31	1.18 ± 0.22	Pass
VE-3896, 3897	7/12/2005	K-40	3.44 ± 0.62	3.60 ± 0.36	3.52 ± 0.36	Pass
MI-3963, 3964	7/13/2005	K-40	1438.70 ± 102.80	1351.80 ± 100.80	1395.25 ± 71.99	Pass
DW-4068, 4069	7/15/2005	1-131	0.64 ± 0.27	0.91 ± 0.28	0.78 ± 0.20	Pass

			(Concentration (pCi/L)*		
				· · · · · · · · · · · · · · · · · · ·	Averaged	
Lab Code	Date	Analysis	First Result	Second Result	Result	Acceptance
VE-4290, 4291	7/26/2005	Gr. Alpha	0.11 ± 0.04	0.05 ± 0.03	0.08 ± 0.03	Pass
VE-4290, 4291	7/26/2005	Gr. Beta	4.55 ± 0.13	4.69 ± 0.14	4.62 ± 0.09	Pass
SWU-4311, 4312	7/26/2005	Gr. Beta	2.62 ± 0.64	1.67 ± 0.37	2.15 ± 0.37	Pass
SWU-4311, 4312	7/26/2005	H-3	192.30 ± 92.90	304.60 ± 97.40	248.45 ± 67.30	Pass
G-4383, 4384	8/1/2005	Be-7	2.06 ± 0.49	1.76 ± 0.29	1.91 ± 0.28	Pass
G-4383, 4384	8/1/2005	Gr. Beta	8.76 ± 0.22	8.40 ± 0.20	8.58 ± 0.15	Pass
G-4383, 4384	8/1/2005	K-40	6.74 ± 0.64	6.88 ± 0.92	6.81 ± 0.56	Pass
MI-4425, 4426	8/1/2005	K-40	1358.10 ± 169.20	1267.90 ± 164.40	1313.00 ± 117.96	Pass
TD-4446, 4447	8/1/2005	H-3	563.00 ± 252.00	529.00 ± 251.00	546.00 ± 177.84	Pass
SL-4473, 4474	8/4/2005	Gr. Beta	5.44 ± 0.48	4.57 ± 0.42	5.00 ± 0.32	Pass
SL-4473, 4474	8/4/2005	K-40	2.91 ± 0.83	2.74 ± 0.54	2.82 ± 0.49	Pass
VE-4532, 4533	8/5/2005	Gr. Beta	31.20 ± 1.20	31.70 ± 1.20	31.45 ± 0.85	Pass
VE-4618, 4619	8/9/2005	Gr. Alpha	0.09 ± 0.05	0.09 ± 0.04	0.09 ± 0.03	Pass
VE-4618, 4619	8/9/2005	Gr. Beta	4.60 ± 0.13	4.54 ± 0.12	4.57 ± 0.09	Pass
VE-4618, 4619	8/9/2005	K-40	4.19 ± 0.46	4.34 ± 0.47	4.27 ± 0.33	Pass
F-4639, 4640	8/11/2005	Cs-137	0.05 ± 0.02	0.05 ± 0.02	0.05 ± 0.02	Pass
F-4639, 4640	8/11/2005	Gr. Beta	3.33 ± 0.11	3.37 ± 0.10	3.35 ± 0.07	Pass
F-4639, 4640	8/11/2005	K-40	2.62 ± 0.57	2.58 ± 0.59	2.60 ± 0.41	Pass
DW-4730, 4731	8/12/2005	I-131	0.82 ± 0.23	0.83 ± 0.25	0.83 ± 0.17	Pass
MI-4855, 4856	8/28/2005	K-40	1341.50 ± 107.70	1340.00 ± 114.70	1340.75 ± 78.67	Pass
MI-4855, 4856	8/28/2005	Sr-90	0.77 ± 0.37	0.87 ± 0.37	0.82 ± 0.26	Pass
MI-4945, 4946	8/31/2005	K-40	1388.90 ± 158.90	1307.50 ± 165.20	1348.20 ± 114.61	Pass
MI-4945, 4946	8/31/2005	Sr-90	0.67 ± 0.34	0.82 ± 0.36	0.75 ± 0.25	Pass
TD-4921, 4922	9/1/2005	H-3	5737.00 ± 266.00	5860.00 ± 269.00	5798.50 ± 189.15	Pass
VE-4900, 4901	9/2/2005	Gr. Beta	3.40 ± 0.06	3.51 ± 0.06	3.45 ± 0.04	Pass
VE-4900, 4901	9/2/2005	K-40	2.15 ± 0.27	2.27 ± 0.24	2.21 ± 0.18	Pass
DW-50769, 50770) 9/2/2005	Gr. Alpha	6.17 ± 1.42	6.08 ± 1.46	6.13 ± 1.02	Pass
VE-4990, 4991	9/6/2005	K-40	18.81 ± 1.12	19.52 ± 0.86	19.17 ± 0.71	Pass
MI-5011, 5012	9/8/2005	K-40	1584.00 ± 194.00	1707.60 ± 173.00	1645.80 ± 129.97	Pass
VE-5119, 5120	9/12/2005	Gr. Alpha	0.10 ± 0.06	0.09 ± 0.05	0.10 ± 0.04	Pass
VE-5119, 5120	9/12/2005	Gr. Beta	6.05 ± 0.18	5.92 ± 0.17	5.98 ± 0.12	Pass
VE-5119, 5120	9/12/2005	K-40	4.61 ± 0.46	4.74 ± 0.69	4.68 ± 0.41	Pass
LW-5361, 5362	9/12/2005	Gr. Beta	1.09 ± 0.33	1.18 ± 0.34	1.13 ± 0.24	Pass
SW-5098, 5099	9/13/2005	I-131	0.44 ± 0.22	0.31 ± 0.20	0.38 ± 0.15	Pass
LW-5178, 5179	9/14/2005	Gr. Beta	2.92 ± 0.56	2.95 ± 0.59	2.93 ± 0.41	Pass
DW-5239, 5240	9/16/2005	I-131	0.45 ± 0.27	0.55 ± 0.29	0.50 ± 0.20	Pass
CF-5432, 5433	9/19/2005	Be-7	0.91 ± 0.40	0.64 ± 0.30	0.78 ± 0.25	Pass
CF-5432, 5433	9/19/2005	K-40	1.43 ± 0.34	1.38 ± 0.43	1.41 ± 0.27	Pass
MI-5292, 5293	9/21/2005	K-40	1228.80 ± 78.13	1297.00 ± 81.03	1262.90 ± 56.28	Pass
BS-5340, 5341	9/23/2005	Be-7	1286.10 ± 550.80	1222.90 ± 394.40	1254.50 ± 338.72	Pass
BS-5340, 5341	9/23/2005	Cs-137	726.97 ± 76.24	677.49 ± 70.03	702.23 ± 51.76	Pass

				Concentration (pCi/L)) ^a	<u>.</u>
					Averaged	
Lab Code	Date	Analysis	First Result	Second Result	Result	Acceptance
BS-5340 5341	9/23/2005	K-40	12404 + 1154	12033 + 083	12710 + 758	Pass
DW-5382 5383	9/23/2005	1-131	0 70 + 0 31	0.53 + 0.31	0.66 + 0.22	Pass
MI-5405 5406	9/27/2005	K-40	1324 80 + 112 20	1366 80 + 99 44	1345 80 + 74 96	Pase
AP-5769 5770	9/27/2005	Be-7	0.08 + 0.01	0.09 + 0.02	0.08 ± 0.01	Paec
AP-5983 5984	9/27/2005	Be-7	0.08 + 0.01	0.03 ± 0.02	0.00 ± 0.01	Pass
AP-5878, 5879	9/29/2005	Be-7	0.06 ± 0.01	0.00 ± 0.01	0.07 ± 0.01	Pass
G-5526, 5527	10/3/2005	Be-7	4.03 ± 0.62	4.07 ± 0.80	4.05 ± 0.51	Pass
G-5526, 5527	10/3/2005	Gr. Beta	8.10 ± 0.30	8.80 ± 0.40	8.41 ± 0.24	Pass
G-5526, 5527	10/3/2005	K-40	4.93 ± 0.67	6.00 ± 0.72	5.47 ± 0.49	Pass
VE-5721, 5722	10/10/2005	Gr. Alpha	0.07 ± 0.05	0.08 ± 0.06	0.08 ± 0.04	Pass
VE-5721, 5722	10/10/2005	Gr. Beta	5.09 ± 0.15	5.00 ± 0.16	5.05 ± 0.11	Pass
VE-5721, 5722	10/10/2005	K-40	4.27 ± 0.43	4.20 ± 0.34	4.23 ± 0.27	Pass
CF-5695, 5696	10/11/2005	Be-7	2.70 ± 0.37	2.80 ± 0.34	2.75 ± 0.25	Pass
CF-5695, 5696	10/11/2005	K-40	11.79 ± 0.86	13.11 ± 0.68	12.45 ± 0.55	Pass
LW-6129, 6130	10/11/2005	Gr. Beta	1.34 ± 0.25	1.85 ± 0.29	1.59 ± 0.19	Pass
LW-6129, 6130	10/11/2005	H-3	304.35 ± 95.31	369.23 ± 97.88	336.79 ± 68.31	Pass
DW-50844, 5	10/11/2005	Gr. Beta	5.30 ± 1.50	4.20 ± 1.40	4.75 ± 1.03	Pass
LW-5748, 5749 °	10/12/2005	Gr. Beta	1.09 ± 0.25	1.89 ± 0.28	1.49 ± 0.19	Fail
AP-6485, 6486	10/20/2005	Be-7	0.10 ± 0.03	0.09 ± 0.03	0.09 ± 0.02	Pass
SWU-6156, 6157	10/25/2005	Gr. Beta	4.69 ± 1.34	4.18 ± 1.34	4.44 ± 0.95	Pass
VE-6186, 6187	10/26/2005	K-40	2.90 ± 0.49	2.83 ± 0.51	2.87 ± 0.35	Pass
LW-6203, 6204	10/27/2005	Gr. Beta	2.92 ± 0.62	3.09 ± 0.66	3.01 ± 0.45	Pass
SO-6270, 6271	10/28/2005	Cs-137	0.33 ± 0.03	0.34 ± 0.04	0.33 ± 0.03	Pass
SO-6270, 6271	10/28/2005	Gr. Beta	26.85 ± 2.78	22.25 ± 2.41	24.55 ± 1.84	Pass
SO-6270, 6271	10/28/2005	K-40	13.67 ± 0.74	14.02 ± 0.76	13.85 ± 0.53	Pass
TD-6320, 6321	11/1/2005	H-3	444202 ± 1770	446633 ± 1775	445418 ± 1253	Pass
SO-6605, 6606	11/11/2005	Gr. Beta	18.22 ± 2.23	18.47 ± 2.22	18.35 ± 1.57	Pass
CF-6509, 6510	11/14/2005	K-40	0.85 ± 0.14	0.99 ± 0.22	0.92 ± 0.13	Pass
SW-6638, 6639	11/22/2005	I-131	0.95 ± 0.35	0.67 ± 0.31	0.81 ± 0.23	Pass
SO-6887, 6888	11/22/2005	Gr. Alpha	6.80 ± 2.92	10.27 ± 3.26	8.53 ± 2.19	Pass
SO-6887, 6888	11/22/2005	Gr. Beta	19.27 ± 2.16	18.43 ± 2.21	18.85 ± 1.54	Pass
SO-6887, 6888	11/22/2005	K-40	14.29 ± 1.11	13.78 ± 0.78	14.03 ± 0.68	Pass
SWT-6721, 6722	11/29/2005	Gr. Beta	0.98 ± 0.31	0.87 ± 0.31	0.93 ± 0.22	Pass
VE-6775, 6776	11/29/2005	Gr. Beta	12.75 ± 0.28	13.16 ± 0.21	12.96 ± 0.18	Pass
LW-6743, 6744	11/30/2005	Gr. Beta	3.19 ± 0.47	2.50 ± 0.44	2.85 ± 0.32	Pass
DW-51023, 4	12/2/2005	Gr. Alpha	0.55 ± 1.40	2.21 ± 1.31	1.38 ± 0.96	Pass
SWT-7282, 7283	12/27/2005	Gr. Beta	1.62 ± 0.37	1.85 ± 0.38	1.74 ± 0.27	Pass

Note: Duplicate analyses are performed on every twentieth sample received in-house. Results are not listed for those analyses with activities that measure below the LLD.

* Results are reported in units of pCi/L, except for air filters (pCi/Filter), food products, vegetation, soil, sediment (pCi/g).

^b 600 minute count time or longer, resulting in lower error.

^c Recount of W-5748, 2.38 ± 0.85 pCi/L Averaged result; 2.14 ± 0.45 pCi/L

				Known	Control			
Lab Code	Date	Analysis	Laboratory result	Activity		Acceptance		
STW-1045	01/01/05	Gr. Alpha	0.45 ± 0.10	0.53	0.00 - 1.05	Pass		
STW-1045	01/01/05	Gr Beta	1 90 + 0 10	1.67	0.84 - 2.51	Pass		
0.11 1040	0 110 1100	0004	1.00 1 0.10	1.07	0.04 - 2.01	1 003		
STW-1046	01/01/05	Am-241	1.62 ± 0.12	1.72	1.20 - 2.24	Pass		
STW-1046	01/01/05	Co-57	239.40 ± 1.20	227.00	158.90 - 295.10	Pass		
STW-1046	01/01/05	Co-60	248.70 ± 1.00	251.00	175.70 - 326.30	Pass		
STW-1046	01/01/05	Cs-134	115.50 ± 1.80	127.00	88.90 - 165.10	Pass		
STW-1046	01/01/05	Cs-137	328.50 ± 1.70	332.00	232.40 - 431.60	Pass		
STW-1046	01/01/05	Fe-55	64.90 ± 7.00	75.90	53.13 - 98.67	Pass		
STW-1046	01/01/05	H-3	304.00 ± 9.70	280.00	196.00 - 364 .00	Pass		
STW-1046	01/01/05	Mn-54	334.80 ± 1.90	331.00	231.70 - 430.30	Pass		
STW-1046	01/01/05	Ni-63	7.10 ± 1.60	9.00	0.00 - 20.00	Pass		
STW-1046	01/01/05	Pu-238	0.01 ± 0.02	0.02	0.00 - 1.00	Pass		
STW-1046	01/01/05	Pu-239/40	2.50 ± 0.14	2.40	1.68 - 3.12	Pass		
STW-1046	01/01/05	Sr-90	0.70 ± 0.80	0.00	0.00 - 5.00	Pass		
STW-1046	01/01/05	Tc-99	43.20 ± 1.40	42.90	30.03 - 55.77	Pass		
STW-1046	01/01/05	U-233/4	3 31 + 0.20	3 24	2 27 - 4 21	Pass		
STW-1046	01/01/05	U-238	3 38 + 0 20	3.33	2.33 - 4.33	Pass		
STW-1046	01/01/05	Zn-65	538 40 + 3.80	496.00	347.20 - 644.80	Pass		
0/11/1040	0	20.00	000.40 1 0.00	400.00	011.20 011.00	, 200		
STVE-1047	01/01/05	Co-57	10.60 ± 0.20	9.88	6.92 - 12.84	Pass		
STVE-1047	01/01/05	Co-60	3.00 ± 0.20	3.15	2.21 - 4.10	Pass		
STVE-1047	01/01/05	Cs-134	4.80 ± 0.40	5.00	3.50 - 6.50	Pass		
STVE-1047	01/01/05	Cs-137	4.10 ± 0.30	4.11	2.88 - 5.34	Pass		
STVE-1047	01/01/05	Mn-54	5.10 ± 0.30	5.18	3.63 - 6.73	Pass		
STVE-1047	01/01/05	Zn-65	6.20 ± 0.50	6.29	4.40 - 8.18	Pass		
STSO-1048	01/01/05	Am-241	96 60 + 10 00	109.00	76.30 - 141.70	Pass		
STSO-1048	01/01/05	Co-57	264.00 + 2.00	242.00	169 40 - 314.60	Pass		
STSO-1048	01/01/05	Co-60	226 50 + 2.20	212.00	148 40 - 275.60	Pass		
	01/01/05	Cs-134	760 60 + 3 70	759.00	531.30 - 986.70	Pass		
STSC-1048	01/01/05	Cs-137	336 20 + 3 60	315.00	220 50 - 409.50	Pass		
STSO-1048	01/01/05	K-40	663 70 + 18 00	604 00	422 80 - 785 20	Pass		
STSO-1048	01/01/05	Mp.,54	541 30 + 3 90	485.00	339 50 - 630 50	Pass		
STSO-1048	01/01/05	Ni-63	924 30 + 17 20	1220.00	854.00 - 1586.00	Pass		
STSO-1048	01/01/05	Pu-238	0.60 ± 0.80	0.48	0.00 - 1.00	Pass		
STSO_1048	01/01/05	Pu-230/40	78.00 + 4.80	89.50	62.65 - 116.35	Pass		
STSO_1048	01/01/05	Sr-90	514 60 + 18 70	640.00	448.00 - 832.00	Pass		
STSO_1048	01/01/05	11-233/4	47 90 + 4 00	62.50	43.75 - 81.25	Pass		
STSO_1048	01/01/05	1-238	226.30 + 8.60	249 00	174.30 - 323.70	Pass		
STSO-1040	01/01/05	7n-65	220.00 ± 0.00 851 30 ± 7 30	810.00	567.00 - 1053.00	Pass		
5130-1040	01/01/00	20-00	091.00 ± 7.00	010.00	507,00 - 1000.00			
STAP-1050	01/01/05	Gr. Alpha	0.11 ± 0.03	0.23	0.00 - 0.46	Pass		
	01/01/05	Gr Bota	0.38 + 0.05	0.30	0 15 - 0 45	Pass		

TABLE A-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)^e.

			Conce	entration ^b		
				Known	Control	
Lab Code ^c	Date	Analysis	Laboratory result	Activity	Limits ^d	Acceptance
STAP-1049	01/01/05	Am-241	0.10 ± 0.04	0.10	0.07 - 0.13	Pass
STAP-1049	01/01/05	Co-57	4.76 ± 0.64	4.92	3.44 - 6.40	Pass
STAP-1049	01/01/05	Co-60	2.84 ± 0.22	3.03	2.12 - 3.94	Pass
STAP-1049	01/01/05	Cs-134	3.54 ± 0.37	3.51	2.46 - 4.56	Pass
STAP-1049	01/01/05	Cs-137	2.20 ± 0.27	2.26	1.58 - 2.94	Pass
STAP-1049	01/01/05	Mn-54	3.15 ± 0.21	3.33	2.33 - 4.33	Pass
STAP-1049	01/01/05	Pu-238	0.16 ± 0.04	0.20	0.14 - 0.25	Pass
STAP-1049	01/01/05	Pu-239/40	0.17 ± 0.02	0.17	0.14 - 0.25	Pass
STAP-1049*	01/01/05	Sr-90	2.24 ± 0.34	1.35	0.95 - 1.76	Fail
STAP-1049	01/01/05	U-233/4	0.34 ± 0.02	0.34	0.24 - 0.44	Pass
STAP-1049	01/01/05	U-238	0.35 ± 0.02	0.35	0.25 - 0.46	Pass
STAP-1049	01/01/05	Zn-65	3.12 ± 0.15	3.14	2.20 - 4.08	Pass
STW-1061	07/01/05	Am-241	2.21 ± 0.13	2.23	1.56 - 2.90	Pass
STW-1061	07/01/05	Co-57	293.20 ± 7.30	272.00	190.40 - 353.60	Pass
STW-1061	07/01/05	Co-60	275.70 ± 1.30	261.00	182.70 - 339.30	Pass
STW-1061	07/01/05	Cs-134	171.80 ± 4.00	167.00	116.90 - 217.10	Pass
STW-1061	07/01/05	Cs-137	342.10 ± 2.20	333.00	233.10 - 432.90	Pass
STW-1061	07/01/05	Fe-55	167.80 ± 9.30	196.00	137.20 - 254.80	Pass
STW-1061	07/01/05	H-3	514.20 ± 12.60	527.00	368.90 - 685.10	Pass
STW-1061	07/01/05	Mn-54	437.00 ± 2.50	418.00	292.60 - 543.40	Pass
STW-1061	07/01/05	Ni-63	105.10 ± 3.60	100.00	70.00 - 130.00	Pass
STW-1061	07/01/05	Pu-238	1.64 ± 0.12	1.91	1.34 - 2.48	Pass
STW-1061	07/01/05	Pu-239/40	2.32 ± 0.13	2.75	1.93 - 3.58	Pass
STW-1061	07/01/05	Sr-90	9.20 ± 1.30	8.98	6.29 - 11.67	Pass
STW-1061	07/01/05	Tc-99	72.30 ± 2.30	66.50	46.55 - 86.45	Pass
STW-1061	07/01/05	U-233/4	4.11 ± 0.18	4.10	2.87 - 5.33	Pass
STW-1061	07/01/05	U-238	4.14 ± 0.18	4.26	2.98 - 5.54	Pass
STW-1061	07/01/05	Zn-65	364.60 ± 4.90	330.00	231.00 - 429.00	Pass
STW-1062	07/01/05	Gr. Alpha	0.57 ± 0.05	0.79	0.21 - 1.38	Pass
STW-1062	07/01/05	Gr. Beta	1.36 ± 0.05	1.35	0.85 - 1.92	Pass
STSO-1063 1	07/01/05	Am-241	48.40 ± 3.90	81.10	56.77 - 105.43	Fail
STSO-1063	07/01/05	Co-57	608.30 ± 2.80	524.00	366.80 - 681.20	Pass
STSO-1063	07/01/05	Co-60	322.70 ± 2.40	287.00	200.90 - 373.10	Pass
STSO-1063	07/01/05	Cs-134	632.10 ± 5.20	568.00	397.60 - 738.40	Pass
STSO-1063	07/01/05	Cs-137	512.40 ± 4.20	439.00	307.30 - 570.70	Pass
STSO-1063	07/01/05	K-40	720.50 ± 19.00	604.00	422.80 - 785.20	Pass
STSO-1063	07/01/05	Mn-54	516.80 ± 5.10	439.00	307.30 - 570.70	Pass
STSO-1063	07/01/05	Ni-63	366.50 ± 13.30	445.00	311.50 <i>-</i> 578.50	Pass
STSO-1063	07/01/05	Pu-238	68.80 ± 15.00	60.80	42.56 - 79.04	Pass
STSO-1063	07/01/05	Pu-239/40	0.00 ± 0.00	0.00	0.00 - 0.00	_
STSO-1063	07/01/05	Sr-90	602.90 ± 17.20	757.00	529.90 - 984.10	Pass
STSO-1063	07/01/05	U-233/4	61.50 ± 1.00	52.50	36.75 - 68.25	Pass
STSO-1063	07/01/05	U-238	164.50 ± 16.70	168.00	117.60 - 218.40	Pass
STSO-1063	07/01/05	Zn-65	874.70 ± 8.40	823.00	5/6.10 - 10/0.00	Pass

TABLE A-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)".

		Concentration ^b				
				Known	Control	
Lab Code ^c	Date	Analysis	Laboratory result	Activity	Limits	Acceptance
STVE-1064	07/01/05	Am-241	0.18 ± 0.03	0.23	0.16 - 0.30	Pass
STVE-1064	07/01/05	Co-57	15.90 ± 0.20	13.30	9.31 - 17.29	Pass
STVE-1064	07/01/05	Co-60	4.80 ± 0.10	4.43	3.10 - 5.76	Pass
STVE-1064	07/01/05	Cs-134	4.60 ± 0.20	4.09	2.86 - 5.32	Pass
STVE-1064	07/01/05	Cs-137	5.90 ± 0.30	5.43	3.80 - 7.06	Pass
STVE-1064	07/01/ 0 5	Mn-54	7.20 ± 0.20	6.57	4.60 - 8.54	Pass
STVE-1064	07/01/05	Pu-238	0.04 ± 0.02	0.00	0.00 - 1.00	Pass
STVE-1064	07/01/05	Pu-239/40	0.13 ± 0.02	0.16	0.11 - 0.21	Pass
STVE-1064	07/01/05	Sr-90	2.80 ± 0.30	2.42	1.69 - 3.15	Pass
STVE-1064	07/01/05	U-233/4	0.28 ± 0.03	0.33	0.23 - 0.43	Pass
STVE-1064	07/01/05	U-238	0.33 ± 0.04	0.35	0.24 - 0.45	Pass
STVE-1064	07/01/05	Zn-65	11.00 ± 0.50	10.20	7.14 - 13.26	Pass
STAP-1065	07/01/05	Gr. Alpha	0.30 ± 0.04	0.48	0.00 - 0.80	Pass
STAP-1065	07/01/05	Gr. Beta	0.97 ± 0.06	0.83	0.55 - 1.22	Pass
STAP-1066	07/01/05	Am-241	0.14 ± 0.03	0.16	0.11 - 0.21	Pass
STAP-1066	07/01/05	Co-57	5.81 ± 0.17	6.20	4.34 - 8.06	Pass
STAP-1066	07/01/05	Co-60	2.79 ± 0.14	2.85	2.00 - 3.71	Pass
STAP-1066	07/01/05	Cs-134	3.67 ± 0.12	3.85	2.70 - 5.01	Pass
STAP-1066	07/01/05	Cs-137	2.93 ± 0.23	3.23	2.26 - 4.20	Pass
STAP-1066	07/01/05	Mn-54	4.11 ± 0.26	4.37	3.06 - 5.68	Pass
STAP-1066	07/01/05	Pu-238	0.11 ± 0.02	0.10	0.07 - 0.13	Pass
STAP-1066	07/01/05	Pu-239/40	0.10 ± 0.01	0.09	0.06 - 0.12	Pass
STAP-1066	07/01/05	Sr-90	2.25 ± 0.29	2.25	1.58 - 2.93	Pass
STAP-1066	07/01/05	U-233/4	0.28 ± 0.02	0.27	0.19 - 0.35	Pass
STAP-1066	07/01/05	U-238	0.28 ± 0.02	0.28	0.20 - 0.37	Pass
STAP-1066	07/01/05	Zn-65	4.11 ± 0.26	4.33	3.06 - 5.68	Pass

TABLE A-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)*.

^a Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the Department of Energy's Mixed Analyte Performance Evaluation Program, Idaho Operations office, Idaho Falls, Idaho

^b Results are reported in units of Bq/kg (soil), Bq/L (water) or Bq/total sample (filters, vegetation) as requested by the Department of Energy.

^c Laboratory codes as follows: STW (water), STAP (air filter), STSO (soil), STVE (vegetation).

^d MAPEP results are presented as the known values and expected laboratory precision (1 sigma, 1 determination) and control limits as defined by the MAPEP.

^e The strontium carbonate precipitates were redissolved and processed. The average of the three analyses was 1.34 µ although the recovery was only 30%. The result of a new analysis was 1.56 pCi/L.

^f Incorrect sample weight used in calculation. Result of recalculation: 97.0 ± 7.8 Bq/kg.

APPENDIX B

DATA REPORTING CONVENTIONS

~

Data Reporting Conventions

- 1.0. All activities, except gross alpha and gross beta, are decay corrected to collection time or the end of the collection period.
- 2.0. Single Measurements

Each single measurement is reported as follows: x ± s

where: x = value of the measurement;

s = 2σ counting uncertainty (corresponding to the 95% confidence level).

In cases where the activity is less than the lower limit of detection L, it is reported as: < L,

where L = the lower limit of detection based on 4.66σ uncertainty for a background sample.

3.0. Duplicate analyses

3.1	Individual results:	For two analysis result	ts; $x_1 \pm s_1$ and $x_2 \pm s_2$
	Reported result:	$x \pm s$; where $x = (1/2)$	2) $(x_1 + x_2)$ and s = (1/2) $\sqrt{s_1^2 + s_2^2}$
3.2.	Individual results:	< L ₁ , < L ₂	Reported result: < L, where L = lower of L_1 and L
3.3.	Individual results:	x ± s, < L	Reported result: $x \pm s$ if $x \ge L$; <l otherwise<="" td=""></l>

4.0. Computation of Averages and Standard Deviations

4.1 Averages and standard deviations listed in the tables are computed from all of the individual measurements over the period averaged; for example, an annual standard deviation would not be the average of quarterly standard deviations. The average x and standard deviation s of a set of n numbers x₁, x₂... x_n are defined as follows:

$$\overline{x} = \frac{1}{n} \Sigma x$$
 $s = \sqrt{\frac{\sum (x - \overline{x})^2}{n - 1}}$

- 4.2 Values below the highest lower limit of detection are not included in the average.
- 4.3 If all values in the averaging group are less than the highest LLD, the highest LLD is reported.
- 4.4 If all but one of the values are less than the highest LLD, the single value x and associated two sigma error is reported.
- 4.5 In rounding off, the following rules are followed:
 - 4.5.1. If the number following those to be retained is less than 5, the number is dropped, and the retained number s are kept unchanged. As an example, 11.443 is rounded off to 11.44.
 - 4.5.2. If the number following those to be retained is equal to or greater than 5, the number is dropped and the last retained number is raised by 1. As an example, 11.445 is rounded off to 11.45.

APPENDIX C

Maximum Permissible Concentrations of Radioactivity in Air and Water Above Background in Unrestricted Areas Table C-1. Maximum permissible concentrations of radioactivity in air and water above natural background in unrestricted areas^a.

Air (pCi/m ³)		Water (pCi/L)		
Gross alpha	1 x 10 ⁻³	Strontium-89	8,000	
Gross beta	1	Strontium-90	500	
lodine-131 ^b	2.8 x 10 ⁻¹	Cesium-137	1,000	
		Barium-140	8,000	
		lodine-131	1,000	
		Potassium-40 ^c	4,000	
	Gross alpha	Gross alpha	2	
		Gross beta	10	
		Tritium	1 x 10 ⁶	

^a Taken from Table 2 of Appendix B to Code of Federal Regulations Title 10, Part 20, and appropriate footnotes. Concentrations may be averaged over a period not greater than one year.

Value adjusted by a factor of 700 to reduce the dose resulting from the air-grass-cow-milk-child pathway.

A natural radionuclide.

APPENDIX D

.

Sampling Location Maps









- +

.....



10001010110000 0011 0011 100000 01 00 FC DIT

