July 25, 2006

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Mail Stop P1-137 Washington, DC 20555-0001

Ladies and Gentlemen:

ULNRC-05316



DOCKET NUMBER 50-483
CALLAWAY PLANT UNIT 1
UNION ELECTRIC CO.
FACILITY OPERATING LICENSE NPF-30
2005 ANNUAL RADIOLOGICAL
ENVIRONMENTAL OPERATING REPORT

Reference: ULNRC-05276, dated April 20, 2006

Please find enclosed a revision to the referenced 2005 Annual Radiological Environmental Operating Report for the Callaway Plant. This revision includes a previously omitted Airborne Pathway Indicator mean value for Gross Beta activity. The data is provided in the Attachment to this letter. This report is submitted in accordance with Section 5.6.2 of the Technical Specification and Appendix B to the Callaway Plant Operating License.

Very truly yours,

Manager, Regulatory Affairs

DJW/jdg

Attachment

IE25

ULNRC-05316 July 25, 2006 Page 2

cc: U.S. Nuclear Regulatory Commission (Original and 1 copy)

Attn: Document Control Desk Mail Stop P1-137 Washington, DC 20555-0001

Mr. Bruce S. Mallett
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Senior Resident Inspector Callaway Resident Office U.S. Nuclear Regulatory Commission 8201 NRC Road Steedman, MO 65077

Mr. Jack N. Donohew (2 copies)
Licensing Project Manager, Callaway Plant
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop 7E1
Washington, DC 20555-2738

Missouri Public Service Commission Governor Office Building 200 Madison Street PO Box 360 Jefferson City, MO 65102-0360

Mr. Edward Everett ANI Account Engineer 95 Glastonbury Glastonbury, CT 06033

Regional Administrator Department of Natural Resources Central Regional Office P.O. Box 176 Jefferson City, MO 65102-0176

REMP Summary

Medium or Pathwa Sampled (Unit of Measurement)	Type and ay Total Number of Analysis Performed		Lower Limit of Detection (LLD) ¹	All Indicator Locations Mean (f) ² Range	Location Wi Annual Name Distance and Direction	•	Control Location Mean (f) ² Range	Number of Non-routine Reported Measurements
Direct Radiation								
Quarterly TLDs	Gamma	(170)		16.2 (158/160)	20	17.7 (4/4)	14.9 (12/12)	0
(mRem/Standard Quarter)	Dose			(11.1 - 19.3)	4.7 mi. NE	(15.6 - 18.4)	(10.1 - 19.0)	
Airborne Pathway								
Airborne Particulate	Gross	(255)	0.010	0.024 (255/260)	B -3	0.026 (51/52)		0 .
(pCi/m³)	Beta			(0.005-0.052)	1.8 mi. NNW	(0.008 - 0.052)		
	1-131	(255)	0.070	< LLD		< LLD		0
	Cs-134	(24)	0.050	< LLD		< LLD	-	0
	Cs-137	(24)	0.060	< LLD	-	< LLD		0