



August 14, 2006

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Serial No.	06-670
NSS&L/DF	R0
Docket No.	50-423
License No.	NPF-49

**DOMINION NUCLEAR CONNECTICUT, INC.**  
**MILLSTONE POWER STATION UNIT 3**  
**IMPLEMENTATION PERIOD FOR PROPOSED TECHNICAL**  
**SPECIFICATION CHANGE FOR RECIRCULATION SPRAY SYSTEM**

In a letter dated September 13, 2005, as supplemented by letter dated June 13, 2006, Dominion Nuclear Connecticut, Inc. (DNC) requested an amendment to Operating License NPF-49 for Millstone Power Station Unit 3 (MPS3). The proposed amendment revises surveillance requirements for the recirculation spray system (RSS) to verify proper initiation of the RSS through actuation of the refueling water storage tank low-low level signal instead of actuation by a timer. The design change to install the necessary circuitry to support the license amendment request is currently planned for implementation during the upcoming spring 2007 refueling outage (3R11). For this reason, the implementation of the proposed license amendment is tied to startup from 3R11. Therefore DNC respectfully requests the license amendment for the RSS be made effective as of the date of issuance with completion of implementation no later than startup from 3R11.

If you should have any questions regarding this submittal, please contact Mr. Paul R. Willoughby at (804) 273-3572.

Very truly yours,

A handwritten signature in black ink, appearing to read "G. T. Bischof", written in a cursive style.

G. T. Bischof  
Vice President - Nuclear Engineering

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406-1415

Mr. V. Nerses  
Senior Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Mail Stop 8C2  
Rockville, MD 20852-2738

Mr. S. M. Schneider  
NRC Senior Resident Inspector  
Millstone Power Station

Director  
Bureau of Air Management  
Monitoring and Radiation Division  
Department of Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127