

R2/E42

DAVID AYRES BI-WEEKLY OPERATIONS STATUS REPORTDon Goldbach, Manager
Environment, Health & Safety

Thursday August 10, 2000

OPERATIONS SUMMARY**LAST WEEK (7/31-8/4)**Conversion = 4 UF₆ lines + Line 1 on nitratePelleting = 4 lines + Line 5 on annulars**LAST WEEKEND (8/5-6)**Conversion = DownPelleting = 2 lines + Line 5 on annulars (Saturday & Sunday)**THIS WEEK (8/7-11)**Conversion = 4 UF₆ lines + Line 5 on nitrate for 1 day, scrap Defluorination/Oxidation for 1 dayPelleting = 4 lines + Line 5 on annulars**THIS WEEKEND (8/12-13)**Conversion = 4 UF₆ lines (Saturday & Sunday)Pelleting = 1 line + Line 5 down (Saturday & Sunday)**UNUSUAL INCIDENTS**

Dropped bulk container = Root Cause Analysis (RCA) complete and reviewed by Incident Review Committee (IRC) this past Tuesday. Corrective Action team kickoff tomorrow.

URRS "Absolute Filter Disassembly" procedure SSC violation = RCA complete. Review by IRC next Thursday.

Pressurized ADU elevator on Conversion Line 2 released ADU into area (August 6th) when opened for maintenance. Nobody put on restriction. Investigation continuing.

MISCELLANEOUS

PHA for Hematite operations being moved to Columbia as-is was completed last week at Hematite.

SSC training (operators and maintenance) for Conversion vaporizers and URRS SOLX / C4 Dissolver systems completed last week.

This week, made about 4 MTU of UO₂ powder for Japan Nuclear Corp (JNC) and packaged up for shipment.

A-13