August 11, 2006

LICENSEE: AmerGen Energy Company, LLC

FACILITY: Oyster Creek Nuclear Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 12, 2006,

BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND AMERGEN ENERGY COMPANY, LLC, CONCERNING RESPONSE TO A REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE OYSTER

CREEK NUCLEAR GENERATING STATION, LICENSE RENEWAL

APPLICATION

The U.S. Nuclear Regulatory Commission staff (NRC or the staff), and representatives of AmerGen Energy Company, LLC (AmerGen), held a telephone conference call on April 12, 2006, to discuss and clarify the applicant's response to the staff's request for additional information (RAI) concerning the Oyster Creek Nuclear Generating Station license renewal application. The conference call was useful in clarifying the applicant's response to the staff's RAI.

Enclosure 1 provides a listing of the conference call participants. Enclosure 2 contains a listing of the information discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Donnie J. Ashley, Project Manager License Renewal Branch A Division of License Renewal Office of Nuclear Reactor Regulation

Docket No. 50-219

Enclosures: As Stated

cc w/encls: See next page

August 11, 2006

LICENSEE: AmerGen Energy Company, LLC

FACILITY: Oyster Creek Nuclear Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 12, 2006,

BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND AMERGEN ENERGY COMPANY, LLC, CONCERNING RESPONSE TO A REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE OYSTER

CREEK NUCLEAR GENERATING STATION, LICENSE RENEWAL

APPLICATION

The U.S. Nuclear Regulatory Commission staff (NRC or the staff), and representatives of AmerGen Energy Company, LLC(AmerGen), held a telephone conference call on April 12, 2006, to discuss and clarify the applicant's response to the staff's request for additional information (RAI) concerning the Oyster Creek Nuclear Generating Station license renewal application. The conference call was useful in clarifying the applicant's response to the staff's RAI.

Enclosure 1 provides a listing of the conference call participants. Enclosure 2 contains a listing of the information discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Donnie J. Ashley, Project Manager License Renewal Branch A Division of License Renewal Office of Nuclear Reactor Regulation

Docket No. 50-219

Enclosures: As Stated

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: ML062270631

DOCUMENT NAME: E:\Filenet\ML062270631.wpd

OFFICE	PM:RLRA:DLR	LA:RLRA:DLR	BC:RLRA:DLR
NAME	DAshley	YEdmonds	LLund
DATE	08/ 09 /06	08/ 09 /06	08/11/06

OFFICIAL RECORD COPY

Oyster Creek Nuclear Generating Station

CC:

Site Vice President - Oyster Creek Nuclear Generating Station AmerGen Energy Company, LLC P.O. Box 388 Forked River, NJ 08731

Senior Vice President of Operations AmerGen Energy Company, LLC 200 Exelon Way, KSA 3-N Kennett Square, PA 19348

Kathryn M. Sutton, Esquire Morgan, Lewis, & Bockius LLP 1111 Pennsylvania Avenue, NW Washington, DC 20004

Kent Tosch, Chief New Jersey Department of Environmental Protection Bureau of Nuclear Engineering CN 415 Trenton, NJ 08625

Vice President - Licensing and Regulatory Affairs AmerGen Energy Company, LLC 4300 Winfield Road Warrenville, IL 60555

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406-1415

Mayor of Lacey Township 818 West Lacey Road Forked River, NJ 08731

Senior Resident Inspector U.S. Nuclear Regulatory Commission P.O. Box 445 Forked River, NJ 08731 Director - Licensing and Regulatory Affairs AmerGen Energy Company, LLC Correspondence Control P.O. Box 160 Kennett Square, PA 19348

Manager Licensing - Oyster Creek Exelon Generation Company, LLC Correspondence Control P.O. Box 160 Kennett Square, PA 19348

Regulatory Assurance Manager Oyster Creek AmerGen Energy Company, LLC P.O. Box 388 Forked River, NJ 08731

Assistant General Counsel AmerGen Energy Company, LLC 200 Exelon Way Kennett Square, PA 19348

Ron Bellamy, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406-1415

Correspondence Control Desk AmerGen Energy Company, LLC 200 Exelon Way, KSA 1—1 Kennett Square, PA 19348

Oyster Creek Nuclear Generating Station Plant Manager AmerGen Energy Company, LLC P.O. Box 388 Forked River, NJ 08731

License Renewal Manager Exelon Generation Company, LLC 200 Exelon Way, Suite 230 Kennett Square, PA 19348

Oyster Creek Nuclear Generating Station

CC:

Mr. James Ross Nuclear Energy Institute 1776 I Street, NW, Suite 400 Washington, DC 20006-3708

Mr. Michael P. Gallagher Vice President License Renewal Exelon Generation Company, LLC 200 Exelon Way, Suite 230 Kennett Square, PA 19348

Mr. Christopher M. Crane President and Chief Nuclear Officer AmerGen Energy Company, LLC 4300 Winfield Road Warrenville, IL 60555 Note to: AmerGen Energy Company, LLC, Facility: Oyster Creek Nuclear Generating Station from Donnie Ashley dated August 11, 2006.

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 12, 2006,

BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND AMERGEN ENERGY COMPANY, LLC, CONCERNING RESPONSE TO A REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE OYSTER

CREEK NUCLEAR GENERATING STATION, LICENSE RENEWAL

APPLICATION

DISTRIBUTION:

HARD COPY

DLR R/F

E-MAIL:

JFair

RWeisman

AMurphy

RPettis

GGalletti

CLi

GBagchi

SSmith (srs3)

SDuraiswamy

YL (Renee) Li

RidsNrrDlr

RidsNrrDlrRlra

RidsNrrDlrRlrb

RidsNrrDe

RidsNrrDci

RidsNrreEemb

RidsNrrDeEeeb

RidsNrrDeEqva

RidsNrrDss

RidsNrrDnrl

RidsOgcMailCenter

RidsNrrAdes

DLR Staff

RLaufer

GMiller

RBellamy, RI

RCureton, RI

JLilliendahl, RI

MModes, RI

MSykes, RI

MYoung

RidsOpaMail

LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE CALL TO DISCUSS THE OYSTER CREEK NUCLEAR GENERATING STATION LICENSE RENEWAL APPLICATION

April 12, 2006

<u>Participants</u> <u>Affiliations</u>

Donnie Ashley

U.S. Nuclear Regulatory Commission (NRC)

Roy Mathew NRC Muhammad Razzaque NRC

Don Warfel AmerGen Energy Company, LLC (AmerGen)

John Hufnagel AmerGen George Beck AmerGen Kevin Muggleston AmerGen

DISCUSSION OF RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION (RAI) OYSTER CREEK NUCLEAR GENERATING STATION LICENSE RENEWAL APPLICATION

April 12, 2006

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of AmerGen Energy Company, LLC (AmerGen), held a telephone conference call on April 12, 2006, to discuss and clarify the applicant's response to the staff's request for additional information (RAI) concerning the Oyster Creek Nuclear Generating Station (OCNGS), license renewal application (LRA). The following RAI response was discussed during the telephone conference call.

RAI 2.3.1.6-1

In LRA Page 2.3-22, it was stated that the reactor vessel head spray nozzle is not required to support any intended functions delineated in the rule, and therefore, are not included within the scope of license renewal. It was further stated that a safety assessment for this component was performed and reported in Boiling Water Reactor Vessel and Internals Project (BWRVIP)-06. The staff, however, could not locate the referenced safety assessment in the referenced document. The staff requests the applicant to clarify.

Response:

AmerGen concurs that the BWRVIP-06 does not include an assessment of the reactor vessel head spray nozzle, as stated in Paragraph 2.3.1.6 of the OCNGS LRA. The head spray integral nozzle does not perform a safety related function nor is it credited for any of the regulated events. No failure of the head spray integral nozzle has been postulated that could cause subsequent failure of safety related equipment. Therefore, as stated in the LRA, the head spray integral nozzle is not required to support intended functions and is not included within the scope of license renewal.

The reference to BWRVIP-06 was included in the response in error. During the call the individuals discussed the information in the Oyster Creek Final Safety Analysis Report (FSAR) Page 5.4-18. The applicant stated that the nozzle did not meet the criteria for selection for in-scope components and is used only for normal shutdown. The applicant and the reviewer discussed the requirements of the FSAR and the Appendix R safe shutdown requirements and agree that the nozzle is not needed to meet the safe shutdown requirements of Appendix R. The reviewer understands the logic used to exclude the nozzle from the aging management program and accepts the response.