

From: Rani Franovich *NRR/DIPM*
 To: Gary Sanborn *Region IV*
 Date: Wed, Jul 7, 2004 5:02 PM
 Subject: Re: Cooper SERP planned July 15

NRR release

Thanks for the heads-up, Gary. I think our risk analysts are expecting the panel. Please provide the package as soon as possible.
 Thanks,
 Rani

RIV

>>> Gary Sanborn 07/07/04 04:26PM >>> *NV*
 This is a heads up we anticipate sending you a worksheet as soon as possible to support a Cooper SERP on July 15 at our normal panel time - 12:30 Central / 1:30 Eastern. The performance deficiency involved the service water system and is described as follows: Operators failed to restore the normal valve alignment for the Division II service water pump gland water supply following maintenance and prior to returning the system to service. This configuration resulted in the Division II service water gland sealing system being provided by the Division I service water pumps. In this configuration, a failure of the Division I pumps would result in loss of gland water to the Division II pumps. [

Region IV
EX 5

Gary

CC: Art Howell; Chris Nolan; David Loveless; David Nelson (HQ-OE); Doug Coe; Kriss Kennedy; Michael Tschiltz; Michael Vasquez; Michelle Honcharik; Mike Franovich; Peter Habighorst; Peter Wilson; Russell Gibbs; Scott Schwind; Stuart Richards

Information in this record was deleted
 in accordance with the Freedom of Information
 Act, exemptions 5
 FOIA 2006-007

U-2