



- NOTES:**
- FOR NOTES, SYMBOLS AND UNIT #2 ABBREVIATIONS SEE 26001 SH. 1, 2 & 3. FOR ALL OTHER ABBREVIATIONS SEE ANSI STANDARD Y1.1.
 - THIS SECTION OF 3" HRC-6 WILL BE REMOVED AS AN INTERFERENCE WHEN CACS/CONTAINMENT PURGE SYSTEM CROSS CONNECT DUCTWORK IS INSTALLED DURING MODES 5 OR 6.
 - THE PRESSURIZER SURGE LINE MATERIAL IS 12" SCH. 160, STAINLESS STEEL, TYPE 316, SEAMLESS ASTM-A-351, CR CFBM

CHANGES MADE TO THIS P&ID MUST ALSO BE REFLECTED ON THE INSERVICE INSPECTION PROGRAM DRAWING 25203-26700 SH. 9

FSAR FIGURE OPERATIONS CRITICAL
 SAFETY EVALUATION MAYBE REQUIRED PRIOR TO CHANGES

CAD		REVISIONS DURING CONSTRUCTION	
NO.	DATE	NO.	DATE

NO.	DATE	REVISIONS	BY	CHK.	APP.
32	5-15-05	INC. DCN DM2-00-0103-04	EAL	RFI	WBZ
31	4-17-05	INC. DCN DM2-00-0278-04	DLW	MP	WBZ
30	5-03-02	INC. DCN DM2-00-0544-01	BLM	TP	SBR
29	3-13-02	INC. DCN DM2-00-0415-01	SCM	LJC	JGR
28	3-7-02	INC. DCN DM2-00-0752-00	JCV	MP	DLW

Q.A.

Dominion Nuclear Connecticut, Inc.
 Millstone Power Station

TITLE: MILLSTONE NUCLEAR POWER STATION - UNIT 2
 PIPING AND INSTRUMENTATION DIAGRAM
 REACTOR COOLANT SYSTEM
 WATERFORD, CT

BY: M.R. BIBISI
 DATE: 6-26-87
 SCALE: NONE

CHKD: S. REINHART
 DATE: 6-26-87

APP: GC/FAD
 DATE: 11-12-87

REV: SBR
 DATE: 11-12-87

DWG. NO.: 25203-26014 SH. 1 OF 3