



- NOTES:
- FOR NOTES, SYMBOLS AND UNIT #2 ABBREVIATIONS SEE 26001 SH. 1, 2 & 3. FOR ALL OTHER ABBREVIATIONS SEE ANSI STANDARD Y1.1.
  - VALVES 2-SI-701A, 2-SI-702A THRU 2-SI-701D, 2-SI-702D, SHOULD BE LOCATED OUTSIDE THE SECONDARY SHIELD WALL AT EL. 1414" IF AS CLOSE AS PRACTICAL TO A DRAIN.
  - CLOSE COIL REMOVED FROM MCC CONTACTOR WHEN UNIT IS IN MODES 1, 2, OR 3 (2-SI-614, 2-SI-624, 2-SI-634 & 2-SI-644)
  - PORTIONS OF LINE HCD-31 (S.I. TEST HEADER) WAS UPGRADED TO SEISMIC CLASS I PER PDCR 2-222-76. THE UPGRADED PORTIONS OF THE LINE TO SEISMIC CLASS I ARE NOW REFLECTED AS HCD-31C1

CHANGES MADE TO THIS P&ID MUST ALSO BE REFLECTED ON THE INSERVICE INSPECTION PROGRAM DRAWING 25203-26700 SH. 13

OPERATIONS CRITICAL

FSAR FIGURE

SAFETY EVALUATION MAY BE REQUIRED PRIOR TO CHANGES

CAD		REVISIONS DURING CONSTRUCTION	
NO.	DATE	BY	CHKD.

NO.	DATE	REVISIONS	BY	CHKD.	APP.
N/A	24	INC. DCN DM2-00-0150-02	DWJ	MP	DLW
N/A	23	INC. DCN DM2-00-0545-01	BLM	TP	SBB

TITLE		DATE		DATE		DATE	
MILLSTONE NUCLEAR POWER STATION - UNIT 2		3-1-87		4-9-87		4-9-87	
PIPING AND INSTRUMENTATION DIAGRAM		3-1-87		4-9-87		4-9-87	
SAFETY INJECTION TANKS		3-1-87		4-9-87		4-9-87	
WATERFORD, CT		3-1-87		4-9-87		4-9-87	

**Dominion Nuclear Connecticut, Inc.**  
**Millstone Power Station**

BY: **M. 00151** CHKD: SBR  
 DATE: 4-1-87 APP: WCF JGR APP: SBR  
 SCALE: NONE DWG. NO.: 25203-26015 SH. 3 OF 3  
 NO. DATE REVISIONS BY CHK. APP. APP.