



- NOTES:
- FOR GENERAL NOTES AND REFERENCE DRAWINGS SEE EM-102A (26902 SH 1).
 - VALVE 3RCS#V103 IS FOR REACTOR VESSEL OUTER O-RING LEAKOFF ISOLATION AND VALVE 3RCS#V104 IS FOR REACTOR VESSEL INNER O-RING LEAKOFF ISOLATION.
 - THE "SPARE" REACTOR COOLANT PUMP MOTOR (SERIAL NO. 91P0641) DOES NOT HAVE THE UPPER AND LOWER OIL LEVEL INDICATION TEST VALVES INSTALLED AS OPPOSED TO THE FOUR ORIGINAL MOTORS SUPPLIED BY WESTINGHOUSE. TEST VALVES V902/V907, V903/V908, V904/V905, AND V906/V909 ASSOCIATED WITH REACTOR COOLANT PUMPS 3RCS#P1A, 3RCS#P1B, 3RCS#P1C AND 3RCS#P1D RESPECTIVELY, WILL NOT PHYSICALLY EXIST AT WHICHEVER LOCATION THE "SPARE" REACTOR COOLANT PUMP MOTOR IS INSTALLED. FURTHERMORE, IF THE "SPARE" REACTOR COOLANT PUMP MOTOR IS NOT INSTALLED DURING ANY OPERATING CYCLE, ALL TEST VALVES NOTED ABOVE WILL EXIST IN THE PLANT.

NUCLEAR SAFETY RELATED
QA CAT. I, II

FSAR FIGURE
OPERATIONS CRITICAL

REV. NO.	DATE	DESCRIPTION	BY	CHK	CORR	APP

REVISIONS DURING CONSTRUCTION

REV. NO.	DATE	DESCRIPTION	BY	CHK	CORR	APP

Dominion Millstone Power Station

MILLSTONE POWER STATION-UNIT NO. 3
PIPING & INSTRUMENTATION DIAGRAM
REACTOR COOLANT SYSTEM

BY: ASK / SGA CRD, RSH / GMD APP: DAS / DJR APP: FJL
DATE: 2/2/88 DATE: 2/11/88 DATE: 2/11/88 DATE: 2/11/88

SCALE: NONE MICROFILM DATE: DWG. NO.: 25212-26902 SH 4 OF 6 REV: 17
71-156

STONE & WEBSTER ENGINEERING CORPORATION
BOSTON, MASS.

CAD

NOTE: MANUAL REVISIONS TO THIS DOCUMENT WHEN AS-BUILT ARE PROHIBITED.

NO.	DATE	REVISIONS
17	10-24-05	INCCORP. DCN DM3-00-0440-05 DLW ASK WBZ MP
16	5-7-01	INCCORP. DCN DM3-00-0114-01 JCV NJB DLW RJY
N/A	3-10-99	INCCORP. DCN DM3-00-1072-98 KF CSJ AJS MP
N/A	14-28-98	INCCORP. DCN DM3-00-0682-98 KF RJK RFL RFL
N/A	4-9-98	INCCORP. DCN DM3-00-0347-98 KF RFL AJS MP
N/A	10-29-97	INCCORP. DCN DM3-00-0941-97 AC MP PAM PAM
N/A	10-2-97	INCCORP. DCN DM3-00-1186-97 AC RJK PAM PAM
N/A	6-25-97	INCCORP. DCN DM3-00-0590-97 KF RFL AJS PAM PAM