



- NOTES:
- FOR GENERAL NOTES AND REFERENCE DRAWINGS SEE EM-102A (26902 SH 1).
 - DELETED.
 - RUPTURE DISCS, 3RCS-PSE37 AND 3RCS-PSE38, ARE SET AT A NOMINAL VALUE OF 31 PSIG WITH A RANGE OF 66 TO 100 PSIG AT 200°F. REFER TO EDS-AT-002 WHICH WAS TRANSMITTED VIA LETTER NEU-1895. REFERENCE DCN DM3-00-1029-97.
 - VALVE IS INSTALLED WITH FLOW OVER THE DISC.

NUCLEAR SAFETY RELATED
QA CAT. I, II

**FSAR FIGURE
OPERATIONS CRITICAL**

--	--	--	--	--	--	--	--	--	--

CAD
NOTE: MANUAL REVISIONS TO THIS DOCUMENT WHEN AS-BUILT ARE PROHIBITED.

REV.	DATE	DESCRIPTION	BY	CHK	CORR	APP
REVISIONS DURING CONSTRUCTION						

P.L.#	NO.	DATE	REVISIONS	BY	CHK	CORR	APP.
N/A	16	11-7-05	INCRP. DCN DM3-00-0460-05	SMC	MP	DLW	DED
N/A	15	2-25-04	INCRP. DCN DM3-00-0013-04	EAL	MP	DLW	DED
N/A	14	10-13-99	INCRP. DCN DM3-00-0961-98	KF	RFL	AJS	AGR
N/A	13	3-10-99	INCRP. DCN DM3-00-1072-98	KF	CSJ	AJS	MP
N/A	12	1-7-99	INCRP. DCN DM3-00-0749-98	KF	MP	AJS	RFL
N/A	11	7-28-98	INCRP. DCN DM3-00-0682-98	KF	RJK	RFL	RFL
N/A	10	1-6-98	INCRP. DCN DM3-00-1905-97	KF	RFL	AJS	MP
N/A	9	10-29-97	INCRP. DCN'S DM3-00-1029-97 & DM3-00-0941-97	AC	MP	PAM	PAM

Dominion Nuclear Connecticut, Inc.
Millstone Power Station

MILLSTONE POWER STATION-UNIT NO. 3
PIPING & INSTRUMENTATION DIAGRAM
REACTOR COOLANT SYSTEM

BY: SEB/SBR CMO:RSH APP: DAS DJR APP: F.J.L.
DATE: 2-2-08 DATE: 2-11-08 DATE: 2-11-08

SCALE: NONE MICROFILM DATE: 71-156

25212-26902 SH 6 OF 6 16

STONE & WEBSTER ENGINEERING CORPORATION
BOSTON, MASS.