



NOTES:
 1. FOR GENERAL NOTES AND REFERENCE DRAWINGS SEE EM-113A (26913 SH 1)
 2. VALVES 3S11MV8804A, B, 3S11MV8802B AND 3S11MV8839 SHALL BE LOCKED LOCALLY PER OP 3260B-1 "LOCKED COMPONENT CHECKLIST". PROTECTION OF THE REACTOR COOLANT SYSTEM, THE COMBINATION OF THE LOCAL LOCKS AND REMOVING POWER FROM CLOSED VALVES IS CONSIDERED AN EQUIVALENT MEANS TO ENSURE THE SAFETY INJECTION PUMPS ARE INCAPABLE OF INJECTING INTO THE RCS, THEN THEY MAY BE USED FOR TESTING OR FILLING THE ACCUMULATORS, IF REQUIRED.

FSAR FIGURE
 NUCLEAR SAFETY RELATED
 QA CAT. I, II

OPERATIONS CRITICAL

REV.	DATE	DESCRIPTION	BY	CHK	CORR	APP

NO.	DATE	REVISIONS	BY	CHK	CORR	APP
N/A	31-9-20-01	INCORP. DCN DM3-00-0368-01	RJH	TP	SBB	CAW
N/A	30-3-00	INCORP. DCN DM3-00-0797-99	RJK	RFL	AJS	MP
N/A	29-7-99	INCORP. DCN DM3-00-0184-99	CMC	MP	AJS	RFL
N/A	28-6-14-99	INCORP. DCN DM3-00-0002-99	KF	RJK	DLW	MP
N/A	27-7-28-98	INCORP. DCN DM3-00-0682-98	KF	RJK	RFL	MP
N/A	26-3-28-98	INCORP. DCN'S DM3-00-1605-97 & DM3-01-1605-97	KF	MP	GUZ	RWS
N/A	25-1-17-97	INCORP. DCN'S DM3-00-0479-97 & DM3-01-1605-97	KF	RFL	AJS	RWS
N/A	24-11-10-97	INCORP. DCN DM3-00-1225-97	AC	MP	AJS	PAM