



NOTES:
 1. FOR GENERAL NOTES AND REFERENCE DRAWINGS SEE EM-113A (26913 SH 1)
 2. VALVES 3S1H*MB8004A, B, 3S1H*MB8028 AND 3S1H*MB839 SHALL BE LOCKED LOCALLY PER OP 32608-1 "LOCKED COMPONENT CHECKLIST". PROTECTION OF THE REACTOR COOLANT SYSTEM, THE COMBINATION OF THE LOCAL LOCKS AND REMOVING POWER FROM CLOSED VALVES IS CONSIDERED AN EQUIVALENT MEANS TO ENSURE THE SAFETY INJECTION PUMPS ARE INCAPABLE OF INJECTING INTO THE RCS, THEN THEY MAY BE USED FOR TESTING OR FILLING THE ACCUMULATORS, IF REQUIRED.

FSAR FIGURE
 NUCLEAR SAFETY RELATED
 QA CAT. I, II

OPERATIONS CRITICAL

| REV. | DATE | DESCRIPTION | BY | CHK | CORR | APP |
|-------------------------------|------|-------------|----|-----|------|----------|
| REVISIONS DURING CONSTRUCTION | | | | | | |
| | | | | | | P.A. No. |

| NO. | DATE | REVISIONS | BY | CHK | CORR | APP |
|-----|-------------|--|-----|-----|------|-----|
| N/A | 31-9-20-01 | INCRP. DCN DM3-00-0368-01 | RJH | TP | SBB | CAW |
| N/A | 30-3-00 | INCRP. DCN DM3-00-0797-99 | RJK | RFL | AJS | MP |
| N/A | 29-7-99 | INCRP. DCN DM3-00-0184-99 | CMC | MP | AJS | RFL |
| N/A | 28-6-14-99 | INCRP. DCN DM3-00-0002-99 | KF | RJK | DLW | MP |
| N/A | 27-7-28-98 | INCRP. DCN DM3-00-0682-98 | KF | RJK | RFL | MP |
| N/A | 26-3-28-98 | INCRP. DCN'S DM3-00-1605-97 & DM3-01-1605-97 | KF | MP | GUZ | RWS |
| N/A | 25-1-17-97 | INCRP. DCN'S DM3-00-0479-97 & DM3-01-1605-97 | KF | RFL | AJS | RWS |
| N/A | 24-11-10-97 | INCRP. DCN DM3-00-1225-97 | AC | MP | AJS | PAM |