



Entergy Operations, Inc.
River Bend Station
5485 U.S. Highway 61N
St. Francisville, LA 70775
Tel 225 381 4157
Fax 225 635 5068
dlorfin@entergy.com

David N. Lorfing
Manager-Licensing

August 24, 2006

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: River Bend Station - Unit 1
Docket No. 50-458
License No. NPF-47
10 CFR 50.46 (a)(3)(ii) Report

File No. G9.5

RBG-46615
RBF1-06-0136

Ladies and Gentlemen:

In accordance with 10 CFR 50.46 (a)(3)(ii), River Bend Station (RBS) is required to report changes to or errors discovered in acceptable ECCS evaluation models on an annual basis. RBS is obligated to report the nature of the change or error and its estimated effect on calculated Peak Clad Temperature (PCT).

General Electric/Global Nuclear Fuel (GE/GNF) has issued Notification Letter (NL-2006-01) to River Bend Station (RBS) on the impact of errors/changes in the SAFER methodology used by GE/GNF. No PCT error associated with the ATRIUM-10 methodology is reported by AREVA or Framatome ANP (FANP) during this period. A summary of these notifications follows:

A002


Notification	Nature of change	Estimated PCT Effect	
		GENE	FANP
GE/GNF NL2006-01	Impact of Top Peaked Power Shape for Small Break LOCA Analysis	0	--
Sum of absolute magnitude of errors during this period		0	0
Cumulative sum of absolute magnitude of errors prior to this period		25	0
Cumulative sum of absolute magnitude of errors including this period		25	0

The LOCA analysis results continue to meet the acceptance criteria of 10CFR50.46(b)(1) that the PCT shall not exceed 2200 deg F. No reanalysis is required per 10CFR50.46(a)(3)(ii) and the errors are not considered significant change.

In summary, the LOCA analysis results for PCT continue to meet the acceptance criteria and there is no safety concern.

For further information, contact Mr. B. M. Burmeister at (225) 381-4148.

Sincerely,



DNL/BMB

cc: U. S. Nuclear Regulatory Commission
 Region IV
 611 Ryan Plaza Drive, Suite 400
 Arlington, TX 76011

10 CFR 50.46 (a)(3)(ii) Report
RBG-46615
RBF1-06-0136
Page 3 of 3

NRC Sr. Resident Inspector
P. O. Box 1050
St. Francisville, LA 70775

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Mr. Jim Calloway
Public Utility Commission of Texas
1701 N. Congress Avenue
Austin, TX 78711-3326

Louisiana Department of Environmental Quality
Radiation Protection Division
P. O. Box 82135
Baton Rouge, LA 70884-2135
ATTN: Administrator