

- (5) Pursuant to the Act and 10 CFR Parts 30 and 70, NMC to possess but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility;
  - (6) Pursuant to the Act and 10 CFR Parts 30 and 70, NMC to transfer byproduct materials from other job sites owned by Northern States Power Company for the purposes of volume reduction and decontamination.
- C. This amended license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

NMC is authorized to operate the facility at steady state reactor core power levels not in excess of 1650 megawatts thermal.

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 163, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) Physical Protection

NMC shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contains Safeguards Information protected under 10 CFR 73.21, is entitled "Prairie Island Nuclear Generating Plant Security Plan, Training and Qualification Plan, Safeguards Contingency Plan, and Independent Spent Fuel Storage Installation Security Program," Revision 0, submitted by letter dated October 18, 2004.

Unit 2

Amendment No. 163 |

- (4) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, NMC to receive, possess and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument and equipment calibration or associated with radioactive apparatus or components;
  - (5) Pursuant to the Act and 10 CFR Parts 30 and 70, NMC to possess but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility;
  - (6) Pursuant to the Act and 10 CFR Parts 30 and 70, NMC to transfer byproduct materials from other job sites owned by Northern States Power Company for the purpose of volume reduction and decontamination.
- C. This amended license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

NMC is authorized to operate the facility at steady state reactor core power levels not in excess of 1650 megawatts thermal.

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 173, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) Physical Protection

NMC shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contains Safeguards Information protected under 10 CFR 73.21, is entitled: "Prairie Island Nuclear Generating Plant Security Plan, Training and Qualification Plan, Safeguards Contingency Plan, and Independent Spent Fuel Storage Installation Security Program," Revision 0, submitted by letter dated October 18, 2004.

Unit 1  
Amendment No. 173 |

Revised by letter dated August 29, 2006.

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. One or both containment cooling fan coil unit(s) (FCU) in one train inoperable.</p>	<p>C.1 Restore containment cooling FCU(s) to OPERABLE status.</p>	<p>7 days <u>AND</u> 10 days from discovery of failure to meet the LCO</p>
<p>D. One containment cooling FCU in each train inoperable.</p>	<p>D.1 Initiate action to isolate both inoperable FCUs. <u>AND</u> D.2 Restore all FCUs to OPERABLE status.</p>	<p>Immediately  7 days <u>AND</u> 10 days from discovery of failure to meet the LCO</p>
<p>E. Required Action and associated Completion Time of Condition C or D not met.</p>	<p>E.1 Be in MODE 3. <u>AND</u> E.2 Be in MODE 5.</p>	<p>6 hours  36 hours</p>

**SURVEILLANCE REQUIREMENTS**

SURVEILLANCE	FREQUENCY
SR 3.6.5.1 Verify each containment spray manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in the correct position.	31 days
SR 3.6.5.2 Operate each containment fan coil unit on low motor speed for $\geq 15$ minutes.	31 days
SR 3.6.5.3 Verify cooling water flow rate to each containment fan coil unit is $\geq 900$ gpm.	24 months
SR 3.6.5.4 Verify each containment spray pump's developed head at the flow test point is greater than or equal to the required developed head.	In accordance with the Inservice Testing Program
SR 3.6.5.5 Verify each automatic containment spray valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	24 months
SR 3.6.5.6 Verify each containment spray pump starts automatically on an actual or simulated actuation signal.	24 months

Prairie Island  
Units 1 and 2

3.6.5-3

Unit 1 – Amendment No. 458 173  
Unit 2 – Amendment No. 449 163

Revised by letter dated August 29, 2006.