



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

REGION II  
SAM NUNN ATLANTA FEDERAL CENTER  
61 FORSYTH STREET, SW, SUITE 23T85  
ATLANTA, GEORGIA 30303-8931

August 31, 2006

Florida Power and Light Company  
ATTN: Mr. J. A. Stall, Senior Vice President  
Nuclear and Chief Nuclear Officer  
P. O. Box 14000  
Juno Beach, FL 33408-0420

SUBJECT: MID-CYCLE PERFORMANCE REVIEW AND INSPECTION PLAN - TURKEY  
POINT NUCLEAR PLANT

Dear Mr. Stall:

On August 2, 2006, the NRC staff completed its performance review of the Turkey Point Nuclear Power Plant for the first half of the calendar year 2006 assessment cycle. Our technical staff reviewed performance indicators (PIs) for the most recent quarter and inspection results over the previous twelve months. The purpose of this letter is to inform you of our assessment of your safety performance during this period and our plans for future inspections at your facility.

This performance review and the enclosed inspection plan do not include physical protection information. A separate letter designated and marked as "Exempt from Public Disclosure in Accordance with 10 CFR 2.390" will include the physical protection review and a resultant inspection plan.

Overall, Turkey Point Units 3 and 4 operated in a manner that preserved public health and safety and fully met all cornerstone objectives. Plant performance for the most recent quarter for both units was within the Regulatory Response column of the NRC's Action Matrix due to a White finding associated with extended inoperability of the B Auxiliary Feedwater Pump due to an incorrectly installed bearing. This White inspection finding, involving the mitigating systems cornerstone, reflected performance at a level requiring increased regulatory response. A Supplemental Inspection using Inspection Procedure (IP) 95001, "Inspection for One or Two White Inputs In a Strategic Performance Area," was conducted the week of May 15, 2006 and no findings of significance were identified. Additionally, both units crossed the threshold from Green to White for the PI "Heat Removal System Unavailability" in the fourth quarter 2005. However with implementation of the Mitigating Systems Performance Index in the second quarter 2006, both units were determined to be Green.

Additionally, the NRC has identified a substantive cross-cutting issue in the area of problem identification and resolution (PI&R). This substantive cross-cutting issue was based on five findings identified in the last 12-month assessment period which share a cross-cutting theme involving the thoroughness with which your staff has evaluated problems and the completeness of the subsequent corrective actions.

Examples in the Mitigating Systems cornerstone involved inadequate corrective action associated with; a longstanding issue with incorrectly setting the Auxiliary Feedwater system manual speed control knob; extended inoperability of the B Turbine Driven Auxiliary Feedwater pump due to an incorrectly installed bearing; repeated heat damage to pressurizer level instrument cables; and multiple examples of scaffolds erected in the area of safety related equipment. One example in the Public Radiation Safety cornerstone involved inadequate corrective action associated with the main plant vent radiation monitor. The NRC is aware that you have already initiated some corrective actions to address the individual cross-cutting aspects, but have only recently initiated corrective actions to address the substantive cross-cutting theme. Therefore, in the Fall of 2006, the NRC will conduct an assessment of the effectiveness of your actions as a PI&R follow-up inspection item in accordance with Inspection Procedure 71152, "Identification and Resolution of Problems," section 03.02. Additionally, because your actions taken to date have not been effective in resolving this cross-cutting theme, we intend to conduct an additional PI&R team inspection during the Spring 2007, as described in section 06.06.i of Manual Chapter 0305, "Operating Reactor Assessment Program." Upon completion of these inspections, the NRC will consider this substantive cross-cutting theme clear if there is evidence that your corrective actions have been effective; specifically, that there are no new greater-than-green findings that share this cross-cutting theme, there is no increasing trend in green findings that share this cross-cutting theme, and that the entry conditions for the cross-cutting theme are no longer met.

The enclosed inspection plan details the inspections, less those related to physical protection, scheduled through March 31, 2008. In addition, we plan to conduct non-ROP inspections involving containment sump blockage, Implementation of Key Shutdown Voluntary Initiatives, and verification of Mitigating Systems Performance Index. We will contact you to schedule the inspection involving Implementation of Key Shutdown Voluntary Initiatives. The inspection plan is provided to minimize the resource impact on your staff and to allow for the resolution of any scheduling conflicts and personnel availability issues well in advance of inspector arrival onsite. Routine resident inspections are not listed due to their ongoing and continuous nature. The inspections in the last twelve months of the inspection plan are tentative and may be revised at the end-of-cycle review meeting.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be made available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

If circumstances arise which cause us to change the inspection plan, we will contact you to discuss the change as soon as possible. Please contact Joel Munday at (404) 562-4560 with any questions you may have regarding this letter or the inspection plan.

Sincerely,

*/RA/*

Charles A. Casto, Director  
Division of Reactor Projects

Docket Nos.: 50-250, 50-251  
License Nos.: DPR-31, DPR-41

Enclosure: Turkey Point Inspection/Activity Plan

cc w/encl: (See page 4)

If circumstances arise which cause us to change the inspection plan, we will contact you to discuss the change as soon as possible. Please contact Joel Munday at (404) 562-4560 with any questions you may have regarding this letter or the inspection plan.

Sincerely,

***/RA/***

Charles A. Casto, Director  
 Division of Reactor Projects

Docket Nos.: 50-250, 50-251  
 License Nos.: DPR-31, DPR-41

Enclosure: Turkey Point Inspection/Activity Plan

cc w/encl: (See page 4)

PUBLICLY AVAILABLE       NON-SENSITIVE

ADAMS:  Yes      ACCESSION NUMBER: ML062430288

OFFICE	RII:DRP	RII:DRP					
SIGNATURE	SON	SON for					
NAME	SNinh	JMunday					
DATE	08/29/2006	08/28/2006	9/ /2006	9/ /2006	9/ /2006	9/ /2006	9/ /2006
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

cc w/encl:

T. O. Jones  
Site Vice President  
Turkey Point Nuclear Plant  
Florida Power and Light Company  
Electronic Mail Distribution

Walter Parker  
Licensing Manager  
Turkey Point Nuclear Plant  
Florida Power and Light Company  
Electronic Mail Distribution

Michael O. Pearce  
Plant General Manager  
Turkey Point Nuclear Plant  
Florida Power and Light Company  
Electronic Mail Distribution

William E. Webster  
Vice President, Nuclear Operations  
Florida Power & Light Company  
Electronic Mail Distribution

Mark Warner, Vice President  
Nuclear Operations Support  
Florida Power & Light Company  
Electronic Mail Distribution

Rajiv S. Kundalkar  
Vice President - Nuclear Engineering  
Florida Power & Light Company  
Electronic Mail Distribution

M. S. Ross, Managing Attorney  
Florida Power & Light Company  
Electronic Mail Distribution

Marjan Mashhadi, Senior Attorney  
Florida Power & Light Company  
Electronic Mail Distribution

Alejandro Sera  
Miami-Dade County  
Emergency Management Coordinator  
Electronic Mail Distribution

Attorney General  
Department of Legal Affairs  
The Capitol  
Tallahassee, FL 32304

William A. Passetti  
Bureau of Radiation Control  
Department of Health  
Electronic Mail Distribution

County Manager  
Metropolitan Dade County  
Electronic Mail Distribution

Craig Fugate, Director  
Division of Emergency Preparedness  
Department of Community Affairs  
Electronic Mail Distribution

Curtis Ivy  
City Manager of Homestead  
Electronic Mail Distribution

Distribution w/encl: (See page 5)

Letter to J. A. Stall from Charles A. Casto dated August 31, 2006

SUBJECT: MID-CYCLE PERFORMANCE REVIEW AND INSPECTION PLAN - TURKEY  
POINT NUCLEAR PLANT

Distribution w/encl:

B. Moroney, NRR

C. Evans

L. Slack, RII EICS

OE Mail

RIDSNRRDIRS

PUBLIC