

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-06-010

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility

Seabrook Power Station
Seabrook, NH
Docket: 05000443

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: SHUTDOWN GREATER THAN 72 HOURS - BOTH EMERGENCY DIESEL GENERATORS INOPERABLE DUE TO PROBLEMS IN THE VOLTAGE REGULATION CIRCUITRY

On August 31, 2006, at 3:30 p.m., FPL Seabrook operators initiated a plant shutdown per Technical Specification (TS) 3.8.1.1 due to two inoperable emergency diesel generators (EDGs). The shutdown was necessitated by problems in the voltage regulation circuitry of both the "A" and "B" EDGs.

Previously, on August 28, the "A" EDG was removed from service for planned maintenance and declared inoperable. During a slow start maintenance run on August 30, the "A" EDG came up to rated speed and voltage and was loaded to the E5 safety bus for 1 hour. During a fast start run on the evening of August 30, the "A" EDG initially came up to rated speed and voltage (not loaded). However, a diode trouble light illuminated on the local EDG panel during the run. Because of the potential operability implications of this light, the licensee decided to shutdown the "A" EDG and to schedule a run of the "B" EDG per the TS. Concurrently, licensee personnel began troubleshooting activities on the "A" EDG. During a subsequent fast start operability run on August 31, the "A" EDG came up to rated speed and voltage (not loaded) with no anomalous indications. The licensee further refined its troubleshooting activities by developing a plan which identified seven likely causes. Later that day, the "B" EDG was tested per technical specifications and initially came up to rated speed, but output voltage failed high. The "B" EDG was promptly shutdown and declared inoperable per TS 3.8.1.1 at 2:15 p.m., on August 31. This TS required the restoration of one EDG to an operable status within 2 hours, or a plant shut down to hot standby within the next 6 hours. Based on the lack of a clearly definable success path, FPL Seabrook management initiated a plant shutdown per the TS at 3:30 p.m., on August 31. The plant reached Mode 3 (hot shutdown) at normal operating temperature and pressure at approximately 9:00 p.m., August 31.

Throughout the event, the licensee considered the "A" EDG functional. All off-site power lines, and the supplemental emergency power system (a separate EDG capable of supplying a safety bus), have been maintained available.

The NRC Resident Inspector staff has been following EDG troubleshooting activities since August 28 and observed portions of the Unit shutdown and cooldown. The Senior Resident Inspector accompanied the licensee during its Mode 3 Containment walkdown in which a Safety Injection Vent Valve (SI-V-265) was noted to have a very small active leak which will be addressed prior to startup.

On September 1, at approximately 2:00 p.m., following replacement of several failed capacitors on "B" EDG and satisfactory post maintenance testing, the "B" EDG was declared operable.

The facts of this PN were verified with John Dent, Assistant Plant Manager. This information is current as of 2:30 p.m. EST on September 1, 2006.

The Region I Public Affairs Office has responded to media inquiries. The States of Massachusetts and New Hampshire have been informed.

ADAMS Accession Number: ML062440470

CONTACT: Paul Krohn
(610) 337-5120

DISTRIBUTION: (PN Recipient List)

<u>OWFN</u>		<u>TWFN</u>	<u>LST</u>
Chairman Klein			
Comm. Lyons		NMSS	
Comm. Jazcko		ACRS	
Comm. McGaffigan Jr.		OIG	
Comm. Merrifield		RES	
OIP		NSIR	
OCA			
OGC			
OPA			
EDO			
OE			
NRR			
SECY			
Regional Offices			

By Fax:
 DOT:Trans
 INPO
 NSAC
 RI Resident Office
 Licensee: Dominion

ADAMS Accession Number: ML062440470

SUNSI Review Complete: PGK (Reviewer's Initials)

DOCUMENT NAME: E:\Filenet\ML062440470.wpd

After declaring this document "An Official Agency Record" it **will** be released to the Public.
To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP		RI/DRP	RI/ORA		RI/DRP		RI/DRP	
E								P	
NAME	SBarber		PKrohn	NSheehan		MMcLaughlin		BHolian	
DATE	09/01/06		09/01/06	09/01/06		09/01/06		09/01/06	

OFFICIAL RECORD COPY