

Secondary Containment Isolation Instrumentation
3.3.6.2

Table 3.3.6.2-1 (page 1 of 1)
Secondary Containment Isolation Instrumentation

| FUNCTION | APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS | REQUIRED CHANNELS PER TRIP SYSTEM | SURVEILLANCE REQUIREMENTS | ALLOWABLE VALUE |
|---|--|--|--|--------------------|
| 1. Reactor Vessel Water Level - Low Low (Level 2) | 1,2,3, (a) | 2 | SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.3 SR 3.3.6.2.4 | \geq - 42 inches |
| 2. Drywell Pressure - High | 1,2,3 | 2 | SR 3.3.6.2.2 SR 3.3.6.2.3 SR 3.3.6.2.4 | \leq 1.84 psig |
| 3. Reactor Building Ventilation Exhaust Plenum Radiation - High | 1,2,3, (a),(b) | 2 | SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.3 SR 3.3.6.2.4 | \leq 49 mR/hr |

- (a) During operations with a potential for draining the reactor vessel.
- (b) During movement of recently irradiated fuel assemblies in secondary containment.

Table 3.3.7.1-1 (page 1 of 1)
Control Room Emergency Filter System Instrumentation

| FUNCTION | APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS | REQUIRED CHANNELS PER TRIP SYSTEM | SURVEILLANCE REQUIREMENTS | ALLOWABLE VALUE |
|---|--|--|--|--------------------|
| 1. Reactor Vessel Water Level - Low Low (Level 2) | 1,2,3, (a) | 2 | SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.3 SR 3.3.7.1.4 | ≥ - 42 inches |
| 2. Drywell Pressure - High | 1,2,3 | 2 | SR 3.3.7.1.2 SR 3.3.7.1.3 SR 3.3.7.1.4 | ≤ 1.84 psig |
| 3. Reactor Building Ventilation Exhaust Plenum Radiation - High | 1,2,3, (a),(b) | 2 | SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.3 SR 3.3.7.1.4 | ≤ 49 mR/hr |

(a) During operations with a potential for draining the reactor vessel.

(b) During movement of lately irradiated fuel assemblies in the secondary containment.

3.6 CONTAINMENT SYSTEMS

3.6.4.1 Secondary Containment

LCO 3.6.4.1 The secondary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in the secondary containment,
During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. Secondary containment inoperable in MODE 1, 2, or 3. | A.1 Restore secondary containment to OPERABLE status. | 4 hours |
| B. Required Action and associated Completion Time of Condition A not met. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 36 hours |
| C. Secondary containment inoperable during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs. | C.1 NOTE LCO 3.0.3 is not applicable. Suspend movement of recently irradiated fuel assemblies in the secondary containment. | Immediately |
| | <u>AND</u> | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| C. (continued) | C.2 Initiate action to suspend OPDRVs. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-------------------------------------|
| SR 3.6.4.1.1 Verify secondary containment vacuum is ≥ 0.25 inch of vacuum water gauge. | 24 hours |
| SR 3.6.4.1.2 Verify all secondary containment equipment hatches are closed and sealed. | 31 days |
| SR 3.6.4.1.3 Verify one secondary containment access door in each access opening is closed. | 31 days |
| SR 3.6.4.1.4 Verify each SGT subsystem can maintain ≥ 0.25 inch of vacuum water gauge in the secondary containment for 1 hour at a flow rate ≤ 1780 cfm. | 18 months on a STAGGERED TEST BASIS |

3.6 CONTAINMENT SYSTEMS

3.6.4.2 Secondary Containment Isolation Valves (SCIVs)

LCO 3.6.4.2 Each SCIV shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in the secondary containment,
During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

NOTES

1. Penetration flow paths may be unisolated intermittently under administrative controls.
2. Separate Condition entry is allowed for each penetration flow path.
3. Enter applicable Conditions and Required Actions for systems made inoperable by SCIVs.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|--|
| A. One or more penetration flow paths with one SCIV inoperable. | A.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange. <u>AND</u> | 8 hours (continued) |

ACTIONS (continued)

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|--------------------|
| <p>D. Required Action and associated Completion Time of Condition A or B not met during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.</p> | <p>D.1 NOTE LCO 3.0.3 is not applicable.</p> <hr/> <p>Suspend movement of recently irradiated fuel assemblies in the secondary containment.</p> | <p>Immediately</p> |
| | <p>AND</p> <p>D.2 Initiate action to suspend OPDRVs.</p> | <p>Immediately</p> |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|---------------------------------------|
| C. (continued) | <p>C.2.1 Suspend movement of recently irradiated fuel assemblies in secondary containment.</p> <p><u>AND</u></p> <p>C.2.2 Initiate action to suspend OPDRVs.</p> | <p>Immediately</p> <p>Immediately</p> |
| D. Two SGT subsystems inoperable in MODE 1 2, or 3. | D.1 Enter LCO 3.0.3 | Immediately |
| E. Two SGT subsystems inoperable during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs. | <p>E.1 NOTE LCO 3.0.3 is not applicable.</p> <p>Suspend movement of recently irradiated fuel assemblies in secondary containment.</p> <p><u>AND</u></p> | <p>Immediately</p> <p>(continued)</p> |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| E. (continued) | E.2 Initiate action to suspend OPDRVs. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|-----------------------------|
| SR 3.6.4.3.1 | Operate each SGT subsystem for ≥ 10 continuous hours with heaters operating. | 31 days |
| SR 3.6.4.3.2 | Perform required SGT filter testing in accordance with the Ventilation Filter Testing Program (VFTP). | In accordance with the VFTP |
| SR 3.6.4.3.3 | Verify each SGT subsystem actuates on an actual or simulated initiation signal. | 18 months |
| SR 3.6.4.3.4 | Verify the SGT units cross tie damper is in the correct position, and each SGT room air supply check valve and SGT dilution air shutoff valve can be opened. | 18 months |

3.7 PLANT SYSTEMS

3.7.4 Control Room Emergency Filter (CREF) System

LCO 3.7.4 The CREF System shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of lately irradiated fuel assemblies in the secondary
containment,
During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. CREF System inoperable. | A.1 Restore CREF System to OPERABLE status. | 7 days |
| B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 36 hours |

(continued)

