

September 11, 2006

Mr. J. A. Stall  
Senior Vice President, Nuclear and  
Chief Nuclear Officer  
Florida Power and Light Company  
P.O. Box 14000  
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT NUCLEAR PLANT, UNIT 3 — NOTICE OF CONSIDERATION  
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE,  
PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION  
DETERMINATION, AND OPPORTUNITY FOR A HEARING (TAC NO. MD2961)

Dear Mr. Stall:

Enclosed is a copy of the subject notice for your information. This notice relates to your amendment application for Turkey Point, Unit 3, dated September 8, 2006, which would revise the Technical Specifications to allow the use of an alternate method of determining rod position for a control rod with an inoperable rod position indication. This would be effective during the current Unit 3 operating cycle until repair of the indication system can be completed, but no later than the Unit 3 outage scheduled for the fall of 2007.

This notice has been sent to the Office of the Federal Register for publication.

Sincerely,

/RA by Douglas V. Pickett for/

Brendan T. Moroney, Project Manager  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-250

Enclosure: Notice

cc w/encl: See next page

September 11, 2006

Mr. J. A. Stall  
Senior Vice President, Nuclear and  
Chief Nuclear Officer  
Florida Power and Light Company  
P.O. Box 14000  
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT NUCLEAR PLANT, UNIT 3 — NOTICE OF CONSIDERATION  
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE,  
PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION  
DETERMINATION, AND OPPORTUNITY FOR A HEARING (TAC NO. MD2961)

Dear Mr. Stall:

Enclosed is a copy of the subject notice for your information. This notice relates to your amendment application for Turkey Point, Unit 3, dated September 8, 2006, which would revise the Technical Specifications to allow the use of an alternate method of determining rod position for a control rod with an inoperable rod position indication. This would be effective during the current Unit 3 operating cycle until repair of the indication system can be completed, but no later than the Unit 3 outage scheduled for the fall of 2007.

This notice has been sent to the Office of the Federal Register for publication.

Sincerely,

/RA by Douglas V. Pickett for/

Brendan T. Moroney, Project Manager  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-250

Enclosure: Notice

cc w/encl: See next page

DISTRIBUTION:

PUBLIC PDII-2 R/F RidsNrrLABClayton RidsNrrPMBMoroney  
RidsNrrDorlLpl2-2 RidsOGCRp RidsAcrsAcnwMailCenter  
RidsRgn2MailCenter RidsNrrDorlDpr

ADAMS ACCESSION NUMBER: ML062540317

NRR-041

OFFICE	LPLII-2	LPLII-2/PM	LPLII-2/LA	LPLII-2/BC
NAME	JPaige	DPickett for BMoroney	BClayton	EMarinos for JDixon-Herrity
DATE	9/ 11 /06	9/ 11 /06	9/ 11 /06	9/ 11 /06

**OFFICIAL RECORD COPY**

UNITED STATES NUCLEAR REGULATORY COMMISSIONFLORIDA POWER AND LIGHT COMPANYDOCKET NO. 50-250NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO  
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS  
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DPR-31, issued to Florida Power and Light Company (the licensee), for operation of the Turkey Point Nuclear Plant, Unit 3, located in Miami-Dade County, Florida.

The proposed amendment would revise Technical Specifications (TSs) 3/4.1.3.1, 3/4.1.3.2, 3/4.1.3.5, and 3/4.1.3.6 to allow the use of an alternate method of determining rod position for the control rod M-6, which has an inoperable rod position indicator (RPI), until repairs can be conducted but no later than the next outage, which is scheduled for fall 2007.

The proposed amendment also includes administrative changes to remove the existing notes regarding the RPI of the Unit 4 Rod F-8. The RPI system for F-8 was repaired during Unit 4 refueling operations in 2005; thus, the associated TS revisions are no longer in effect.

The reason for the exigency is the unanticipated failure of the Turkey Point Unit 3 Analog RPI for control rod M-6 in Control Rod Bank C. Additionally, there is a concern that exercising the movable incore detectors every 8 hours (90 times per month) to comply with the compensatory actions required by the current Action Statement a. of TS 3.1.3.2 will result in excessive wear.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

Pursuant to Title 10, *Code of Federal Regulations* (10 CFR), Section 50.91(a)(6) for amendments to be granted under exigent circumstances, the NRC staff must determine that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Will operation of the facility in accordance with this proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

No. The proposed change provides an alternative method for verifying rod position of one control rod. The proposed change meets the intent of the current specification in that it ensures verification of position of the control rod once every eight (8) hours. The proposed change provides only an alternative method of monitoring control rod position and does not change the assumption or results of any previously evaluated accident.

Therefore, operation of the facility in accordance with the proposed amendment would not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Will operation of the facility in accordance with this proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

No. As described above, the proposed change provides only an alternative method of determining the position of one control rod. No new accident initiators are introduced by the proposed alternative manner of performing rod position verification. The proposed change does not affect the reactor protection system or the reactor control system. Hence, no new failure modes are created that

would cause a new or different kind of accident from any accident previously evaluated.

Therefore, operation of the facility in accordance with the proposed amendments would not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Will operation of the facility in accordance with this proposed change involve a Significant reduction in a margin of safety?

No. The bases of Specification 3.1.3.2 state that the operability of the rod position indicators is required to determine control rod positions and thereby ensure compliance with the control rod alignment and insertion limits. The proposed change does not alter the requirement to determine rod position but provides an alternative method for determining the position of the affected rod. As a result, the initial conditions of the accident analysis are preserved and the consequences of previously analyzed accidents are unaffected.

Therefore, operation of the facility in accordance with the proposed amendments would not involve a significant reduction in the margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 14 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 14-day notice period. However, should circumstances change during the notice period, such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 14-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the *Federal Register* a

notice of issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rulemaking, Directives, and Editing Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page number of this *Federal Register* notice. Written comments may also be delivered to Room 6D59, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland.

The filing of requests for hearing and petitions for leave to intervene is discussed below. Within 60 days after the date of publication of this notice, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.309, which is available at the Commission's PDR, located at One White Flint North, Public File Area 01F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management System's (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or a presiding officer designated by the Commission or by the Chief Administrative Judge of the Atomic Safety and Licensing Board Panel, will rule on

the request and/or petition; and the Secretary or the Chief Administrative Judge of the Atomic Safety and Licensing Board will issue a notice of a hearing or an appropriate order.

As required by 10 CFR 2.309, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements: (1) the name, address and telephone number of the requestor or petitioner; (2) the nature of the requestor's/petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the requestor's/petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the requestor's/petitioner's interest. The petition must also identify the specific contentions which the petitioner/requestor seeks to have litigated at the proceeding.

Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner/requestor shall provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner/requestor must also provide references to those specific sources and documents of which the petitioner/requestor is aware and on which the petitioner/requestor intends to rely to establish those facts or expert opinion. The petitioner/requestor must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner/requestor to relief. A petitioner/requestor who fails to satisfy these requirements with respect to at least one contention will not be permitted to participate as

a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

Nontimely requests and/or petitions and contentions will not be entertained absent a determination by the Commission or the presiding officer of the Atomic Safety and Licensing Board that the petition, request and/or the contentions should be granted based on a balancing of the factors specified in 10 CFR 2.309(a)(1)(i)-(viii).

A request for a hearing or a petition for leave to intervene must be filed by: 1) first class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; 2) courier, express mail, and expedited delivery services: Office of the Secretary, Sixteenth Floor, One White Flint North, 11555 Rockville Pike, Rockville, Maryland, 20852, Attention: Rulemaking and Adjudications Staff; 3) E-mail addressed to the Office of the Secretary, U.S. Nuclear Regulatory Commission, [HEARINGDOCKET@NRC.GOV](mailto:HEARINGDOCKET@NRC.GOV); or 4) facsimile transmission addressed to the Office of the Secretary, U.S. Nuclear Regulatory Commission, Washington, DC, Attention: Rulemakings and Adjudications Staff at (301) 415-1101, verification number is

(301) 415-1966. A copy of the request for hearing and petition for leave to intervene should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and it is requested that copies be transmitted either by means of facsimile transmission to 301-415-3725 or by email to [OGCMailCenter@nrc.gov](mailto:OGCMailCenter@nrc.gov). A copy of the request for hearing and petition for leave to intervene should also be sent to M. S. Ross, Managing Attorney, Florida Power & Light Company, P.O. Box 14000, Juno Beach, FL 33408-0420, attorney for the licensee.

For further details with respect to this action, see the application for amendment dated September 8, 2006, which is available for public inspection at the Commission's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management System's (ADAMS) Public Electronic Reading Room on the Internet at the NRC web site <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, 301-415-4737, or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov).

Dated at Rockville, Maryland, this 11th day of September 2006.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Douglas V. Pickett, Project Manager  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Mr. J. A. Stall  
Florida Power and Light Company

cc:

M. S. Ross, Managing Attorney  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Marjan Mashhadi, Senior Attorney  
Florida Power & Light Company  
801 Pennsylvania Avenue, NW.  
Suite 220  
Washington, DC 20004

T. O. Jones, Site Vice President  
Turkey Point Nuclear Plant  
Florida Power and Light Company  
9760 SW. 344th Street  
Florida City, FL 33035

County Manager  
Miami-Dade County  
111 Northwest 1 Street, 29th Floor  
Miami, Florida 33128

Senior Resident Inspector  
Turkey Point Nuclear Plant  
U.S. Nuclear Regulatory Commission  
9762 SW. 344<sup>th</sup> Street  
Florida City, Florida 33035

Mr. William A. Passetti, Chief  
Department of Health  
Bureau of Radiation Control  
2020 Capital Circle, SE, Bin #C21  
Tallahassee, Florida 32399-1741

Mr. Craig Fugate, Director  
Division of Emergency Preparedness  
Department of Community Affairs  
2740 Centerview Drive  
Tallahassee, Florida 32399-2100

## **TURKEY POINT PLANT**

Attorney General  
Department of Legal Affairs  
The Capitol  
Tallahassee, Florida 32304

Michael O. Pearce  
Plant General Manager  
Turkey Point Nuclear Plant  
Florida Power and Light Company  
9760 SW. 344th Street  
Florida City, FL 33035

Walter Parker  
Licensing Manager  
Turkey Point Nuclear Plant  
9760 SW 344th Street  
Florida City, FL 33035

David Moore, Vice President  
Nuclear Operations Support  
Florida Power and Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar  
Vice President - Nuclear Engineering  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420