



ELECTRIC POWER
RESEARCH INSTITUTE

New Plant Seismic Issues Resolution Program

Presentation to USNRC

By NEI/EPRI

August 29, 2006

R. P. Kassawara




Purpose of Meeting

- Discuss NRC comments on G-task reports and responses to NRC RAIs
- Resolve any remaining open issues
- Discuss plans and schedule for completion of:
 - Task I1.1, Integration report
 - Task S2.1, Effect of incoherency
- Discuss Industry needs for acceptance of Task S2.1 results

Topics to be Discussed

- Activities since NRC meetings on May 11 and 12, 2006
- EPRI Phase II reports and responses to NRC RAIs on:
 - Task G1.1a, Sensitivity of performance goal-based methodology; 28 sites
 - Task G1.2, Use of CAV-filtering in PHSA
 - Task G1.3, Updated variability on median ground motion, sigma for CEUS ground motion model (EPRI 04)
- Plans and schedule for remaining activities

New Plant Seismic Issues Resolution Program – Tasks for Near-Term Resolution



Early 2006 Activities

- Issued reports of initial (Ph I) tasks on:
 - G1.1 – Performance goal-based method verification and results
 - G1.2 – CAV-filtering in PHSA
 - G1.3 – Variability of ground motion; Sigma
 - S2.1 – Effect of spatial incoherence
 - S2.2 – Effect of negligible inelastic deformation
- Initiated new (Ph II) tasks on:
 - Development of CDF-based, performance goal-based method, re-calculation of SSRS for 28 test sites
 - Development of integration report (Task I1.1)
 - Performance of evaluations requested by NRC (RAIs)

Activities and actions since May NRC/Industry meeting

- NEI/EPRI issued response (June 23rd) to NRC requests for basis of:
 - Annual probability of unacceptable performance (FOSID)
 - CAV threshold value of 0.16 g-sec
- NRC issued RAIs on all Tasks (June 1st):
 - 3 on Task G1.1
 - 15 on Task G1.2
 - 13 on Task G1.3
 - 53 on Task S2.1a (Structure response)
 - 22 on Task S2.1b (Coherency model)
 - 48 on Task S2.2
- NEI/EPRI issued (July 20th) Phase II task reports on all 3 G-tasks, with responses to RAIs, and draft I-task (Integration report)
- NRC issued letter to NEI (July 25th) agreeing with use of RIPB method at FOSID of 1E-5, and with CAV threshold value of 0.16 g-sec.
- Further work on Task S2.2 placed on “hold”

Main technical results of G-tasks

- Performance goal-based method based on FOSID results in lower DRS for most of the 28 test sites compared to RG 1.165 method
- CAV-based lower bound magnitude distribution reduces SSRS significantly for all sites whose SSRSs are not controlled by seismic sources with frequent, large earthquakes (e.g., Charleston and New Madrid)
- Truncation of variability not supportable, but change in sigma proposed. Minor impact

Sigma and CAV Corrections – Small Effect




Figure 4-1
Sensitivity of ASCE DRS to Sigma and CAV Assumptions at Site With Small Effect.

Sigma and CAV Corrections – Major Effect




Figure 4-3
Sensitivity of ASCE DRS to Sigma and CAV Assumptions at Site With Major Effect.




Figure 2-2
ASCR-DRS Spectra Using Revised-Sigma Ground Motions, Compared to RG1.60 Spectrum
Anchored to 0.3g.




Figure 3-5
ASCE DRS Calculated With CAV Filter for 28 Sites

Current status and schedule

- Report of Ph II task S2.1 with responses to all RAIs to be submitted end of September
- Final Task I1.1 integration report to be issued after S2.1 task is completed
- Meetings with NRC on Tasks S2.1 and I1.1 expected in 4th quarter of 2006.

Backup

Task I1.1 - Guidance for Determining RIPB Site Specific SSE Response Spectra

1. Introduction
2. Generic updating of CEUS seismic hazard model
 - 2.1 Lower bound earthquake magnitude – CAV filter
 - 2.2 Updated CEUS ground motion model
3. Site response analysis for UHRS at ground surface
4. Site-specific response spectra (SSRS) and RIPB response spectra (DRS)